



Comfort. Under control.

## 12-05 CULVERS - LAKE CITY, FL

### Project Issue Information

**Issue Name :** EF#2 is not getting power

**Description :** Potentiometer and switch are on for fan to run, however, fan is not turning on.

**Created By :** National TAB

**Assigned To :** National TAB - Will Turnbough

**Status :** Open

**Originated Date :** 12/07/2022 - Ian Fuller - National TAB

#### Project Issue File Details



EF2.jpeg



Comfort. Under control.

## 12-05 CULVERS - LAKE CITY, FL

### Project Issue Information

**Issue Name :** EF#3C is not completely wired.

**Description :** Bathroom lights are on and potentiometer is turned on, however, fan is not getting power due to wiring incomplete.


**Created By :** National TAB

**Assigned To :** National TAB - Will Turnbough

**Status :** Open

**Originated Date :** 12/07/2022 - Ian Fuller - National TAB

#### Project Issue File Details



EF3C.jpeg



Comfort. Under control.

## 12-05 CULVERS - LAKE CITY, FL

### Project Issue Information

**Issue Name :** PRV4 is not wired in yet.

**Description :** Conduit needs to be run to through raceway in fan and wired in to get power.

**Created By :** National TAB

**Assigned To :** National TAB - Will Turnbough

**Status :** Open

**Originated Date :** 12/07/2022 - Ian Fuller - National TAB

#### Project Issue Response Details

- **12/07/2022**    **National TAB - Ian Fuller**

▪ .