

ION

852 CFM
662 CFM
300 CFM
500 CFM
4314 CFM

SUPPLY RISER WITH VOLUME DAMPER AS PART OF EXHAUST HOOD CONSTRUCTION BY CAPTIVE AIRE. EACH DIFFUSER 292 CFM PER CAPTIVE AIRE DESIGN. HVAC CONTRACTOR TO CONNECT TO TRUNK WITH 10" Ø BRANCH. TYP. OF 4 AS SHOWN

14" Ø TYPE I EXHAUST DUCT FROM HOOD COLLAR ROUTED UP TO FAN; DUCT AND DUCT-TO-CURB TRANSITIONS SUPPLIED BY CAPTIVE AIRE AND INSTALLED BY HVAC CONTRACTOR.

14" Ø TYPE I EXHAUST DUCT FROM HOOD COLLAR ROUTED UP TO FAN; DUCT AND DUCT-TO-CURB TRANSITIONS SUPPLIED BY CAPTIVE AIRE AND INSTALLED BY HVAC CONTRACTOR.

WITHIN DINING AREA ALL SUPPLY DUCT SHALL BE RAN EXPOSED BELOW CEILING UNLESS NOTED OTHERWISE. EXPOSED DUCT SHALL BE SPIRAL MATERIAL AS MANUFACTURED BY LINX INDUSTRIES

MOUNT GRILLES ON DUCT AT 45° ANGLE TO FLOOR/CEILING (T.U.N.O.)

NOTE: THIS DUCT IS TO BE ROUTED ABOVE THE CEILING

