



NOTE: ALL DUCTWORK TO BE LOCATED IN TRUSS SPACE WHERE POSSIBLE. SEE FRAMING PLAN.

HVAC SETPOINTS RECOMMENDED BY CORPORATE OPERATIONAL GUIDELINES

1. DINING: HEATING 70 DEGF, COOLING 72 DEGF
2. KITCHEN: HEATING 65 DEGF, COOLING 74 DEGF