



### AIR BALANCE SCHEDULE

UNIT	AREA SERVED	HOOD ON OA		HOOD OFF OA		HOOD ON EXHAUST		HOOD OFF EXHAUST	
		DESIGN	ACTUAL	DESIGN	ACTUAL	DESIGN	ACTUAL	DESIGN	ACTUAL
RTU 1	SALES	800	841	350	365				
RTU-2	SALES	800	862	350	350				
RTU-3	BOH/KITCHEN	800	827	350	354				
EF-1	RR/JANITOR					750	727	750	727
EF-3	HOOD					1350	1310	0	0
<b>TOTALS</b>		<b>2400</b>	<b>2530</b>	<b>1050</b>	<b>1069</b>	<b>2100</b>	<b>2037</b>	<b>750</b>	<b>727</b>

### HOODS ON

#### NET AIRFLOW CALCULATION

TOTALS	DESIGN	ACTUAL
TOTAL OA	2400	2530
TOTAL EXHAUST	2100	2037
<b>NET AIRFLOW</b>	<b>300</b>	<b>493</b>

DOOR TESTED	BUILDING PRESSURE MEASUREMENTS
FRONT	[1]
SIDE	
REAR	
<b>AVERAGE</b>	

### HOODS OFF

#### NET AIRFLOW CALCULATION

TOTALS	DESIGN	ACTUAL
TOTAL OA	1050	1069
TOTAL EXHAUST	750	727
<b>NET AIRFLOW</b>	<b>300</b>	<b>342</b>

DOOR TESTED	BUILDING PRESSURE MEASUREMENTS
FRONT	[1]
SIDE	
REAR	
<b>AVERAGE</b>	

NOTES:

[1] ACCURATE BUILDING PRESSURE COULD NOT BE TAKEN DUE TO UNSEALED BUILDING / IN-OUT TRAFFIC; BUILDING POSITIVELY PRESSURIZED.