



# National TAB

Project: CW 2999 - UTSW (DALLAS, TX)

Comfort. Under control.

## Diffuser Supply (GRD)

### FPB-3-01/300D

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
F01-2	300D	S5	10	305	161	277	90.8
F01-2	300D	S5	10	305	314	318	104.3
F01-2	300D	S5	10	305	255	301	98.7
F01-4	300D	S5	10	305	295	323	105.9
F01-5	300D	S5	10	305	325	310	101.6
F01-6	300D	S5	10	305	399	320	104.9

### FPB-3-02/300E

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
F02-2	300F	S5	10	305	243	292	95.7
F02-2	300F	S5	10	305	231	284	93.1
F02-2	300F	S5	10	305	83	287	94.1
F02-4	300F	S5	10	305	305	299	98.0
F02-5	300F	S5	10	305	380	301	98.7
F02-6	300F	S5	10	305	303	285	93.4