

CheckList List

- Walgreens Survey-Electrical Panel # ()
- Walgreens Survey-Electrical Panel # ()



08-12-24 WALGREENS #6197 DALLAS, TX (SURVEY)

CheckList Information

Name : Walgreens Survey-Electrical Panel # () **Status :** Not Completed
Assigned Organization : National TAB **Asset :**
Requesting Organization : National TAB
Created Date : 08/14/2024 - Megan McKelvey - National TAB

CheckList Item Details

Unit label or markings. Picture of front of panel.

Comment:



Open the panel door and take picture of all the breakers and a picture of the inside door panel where label / information is applied.

Comment:

BREAKERS ARE OPEN AIR. THERE IS NO DOOR COVERING THEM.

Size and type of main breaker.

Comment:

Size and type of RTU unit breaker 1.

Comment:

50 AMP 3 POLE

Size and type of RTU unit breaker 2.

Comment:

60 AMP 3 POLE

Size and type of RTU unit breaker 3.

Comment:

60 AMP 3 POLE

Size and type of RTU unit breaker 4.

Comment:

50 AMP 3 POLE

Size and type of RTU unit breaker 5.

Comment:

40 AMP 3 POLE

Size and type of RTU unit breaker 6

Comment:

50 AMP 3 POLE

Size and type of RTU unit breaker 7

Comment:

UNABLE TO LOCATE BREAKER.

Size and type of exhaust fan #1 breaker.

Comment:

UNABLE TO LOCATE EF-1 BREAKER.

Size and type of exhaust fan #2 breaker.

Comment:

UNABLE TO LOCAGE EF-2 BRAEKER

Size and type of exhaust fan #3 breaker.

Comment:

UNABLE TO LOCATE EF-3 BREAKER



08-12-24 WALGREENS #6197 DALLAS, TX (SURVEY)

CheckList Information

Name : Walgreens Survey-Electrical Panel # () **Status :** Not Completed
Assigned Organization : National TAB **Asset :**
Requesting Organization : National TAB
Created Date : 08/14/2024 - Megan McKelvey - National TAB

CheckList Item Details

Unit label or markings. Picture of front of panel.

Comment:

Open the panel door and take picture of all the breakers and a picture of the inside door panel where label / information is applied.

Comment:

Size and type of main breaker.

Comment:

Size and type of RTU unit breaker 1.

Comment:

RTU-6 50 AMP 3 POLE

Size and type of RTU unit breaker 2.

Comment:

RTU-7 UNABLE TO LOCATE BREAKER.

Size and type of RTU unit breaker 3.

Comment:

Size and type of RTU unit breaker 4.

Comment:

Size and type of RTU unit breaker 5.

Comment:

Size and type of exhaust fan #1 breaker.

Comment:

Size and type of exhaust fan #2 breaker.

Comment:

Size and type of exhaust fan #3 breaker.

Comment:

Size and type of exhaust fan #4 breaker.

Comment:
