

PlanGrid Task Report - Nov 1, 2024

Prepared by Dale Wheeler

Nov 1, 2024

Description

3 tasks in this report.

Contents

#10 [SITE 500] [NEW] TAB is complete.	2
#9 [REFG 505] [NEW] WIC door sweep vs threshold.....	3
#7 [UNIT 517] [NEW] Condensate piping construction.	4

#10 [SITE 500] [NEW] TAB is complete.

Status Open	Start Date Nov 1, 2024
Type Planned Work	Created Nov 1, 2024 12:34 PM dale@nationaltab.com
Description TAB is complete with only non-critical tasks open	Last Updated Nov 1, 2024 12:34 PM

#9 [REFG 505] [NEW] WIC door sweep vs threshold.

Status Open	Start Date Oct 31, 2024
Type Planned Work	Created Nov 1, 2024 12:13 PM dale@nationaltab.com
Description WIC door sweep needs to be adjusted.	Last Updated Nov 1, 2024 12:18 PM

Photos



IMG_6051
Dale Wheeler
Nov 1, 2024 12:13 PM

#7 [UNIT 517] [NEW] Condensate piping construction.

Status

Open

Start Date

Oct 31, 2024

Type

Planned Work

Created

Nov 1, 2024 12:12 PM
dale@nationaltab.com

Description

AC1, AC2, AC3 P-traps are missing one union. Unions should be installed on both sides of p-trap.

Last Updated

Nov 1, 2024 12:21 PM

Photos



IMG_6015

Dale Wheeler

Nov 1, 2024 12:12 PM