

Report By:

National TAB
1329 E. KEMPER ROAD
SUITE 4210
CINCINNATI, OH 45246



Report: TAB Punch List
Function: Test, Adjust, & Balance
Date: 03/16/2026
Completed By: National TAB

PROJECT
Marshalls (Cold Spring, KY)

5315 Alexandria Pike

Cold Spring, KY 41076

Client

Champion Commercial HVAC
2638 Tem Mile Rd.

Melbourne, KY 41059

National TAB

Project: Marshalls (Cold Spring, KY)

Table Of Contents

Section	Page #
Issues	3

Issue List

- RTU-6 Alarm
- RTU-7 & 9 Alarms
- RTU-7 Volume Damper
- RTU-8 Alarms



Marshalls (Cold Spring, KY)

Project Issue Information

Issue Name : RTU-6 Alarm
Description : RTU-6 not running, displaying alarm " HS1 shutdown due to limit switch ". Cycled power several times in attempt to clear alarm unsuccessfully.
Created By : National TAB **Assigned To :** National TAB - Jordan Best
Status : Open
Priority : High **Asset Tag :**
Originated Date : 03/16/2026 - Jordan Best - National TAB



Marshalls (Cold Spring, KY)

Project Issue Information

Issue Name : RTU-7 & 9 Alarms
Description : RTU's 7 & 9 are displaying “economizer source unavailable” alarms.
Created By : National TAB **Assigned To :** National TAB - Jordan Best
Status : Open
Priority : High **Asset Tag :**
Originated Date : 03/16/2026 - Jordan Best - National TAB




Marshalls (Cold Spring, KY)

Project Issue Information

Issue Name : RTU-7 Volume Damper
Description : RTU-7 is at design airflow, but trunk totals are off. To achieve design totals for each diffuser we will need a volume damper in the 16" round duct.
Created By : National TAB
Status : Open
Priority : Medium
Originated Date : 03/16/2026 - Jordan Best - National TAB
Assigned To : National TAB - Jordan Best
Asset Tag :

Project Issue File Details





Marshalls (Cold Spring, KY)

Project Issue Information

Issue Name : RTU-8 Alarms
Description : RTU-8 not running, displaying " economizer communication failure " and " outputs disabled due to low input" alarms.
Created By : National TAB **Assigned To :** National TAB - Jordan Best
Status : Open
Priority : High **Asset Tag :**
Originated Date : 03/16/2026 - Jordan Best - National TAB