

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: AHU/RTU

Asset: RTU-1

AREA:

Unit Data	
	Actual
MFG	TRANE
Serial Num	
Model Num	WHK180A4S0P
Configuration	VERTICAL
Num OA Filters 1	
OA Filter Size 1	
Num OA Filters 2	
OA Filter Size 2	
Num PreFilter 1	4
PreFilter Size 1	20X24X2
Num PreFilter 2	
PreFilter Size 2	
Num Final Filter 1	
Final Filter Size 1	
Num Final Filter 2	
Final Filter Size 2	

Motor Data	
	Actual
Motor MFG	
Frame	
Horsepower	
Motor Rpm	
Phase	
Rated Voltage	
Rated Amperage	
Service Factor	

Test Data		
	Design	Actual
SF CFM	5550	
RA CFM	4500	
OA CFM	1050	
RL Voltage	460	
RL Amperage	-	
SF Motor Freq(HZ)	-	
SF System SetPt	-	
OA Damper Position	-	
Brake Horse Power	-	

Performance Data		
	Design	Actual
Fan Suction SP	-	
Fan Discharge SP	-	
Total ESP	1.500	
Fan Total SP	1.835	
Pre-Filter P.D.	-	
Cooling Coil P.D.	-	
Heating Coil P.D.	-	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: AHU/RTU

Asset: RTU-2A 1

AREA:

Unit Data	
	Actual
MFG	TRANE
Serial Num	
Model Num	WHK240A4S0R
Configuration	VERTICAL
Num OA Filters 1	
OA Filter Size 1	
Num OA Filters 2	
OA Filter Size 2	
Num PreFilter 1	4
PreFilter Size 1	20X24X2
Num PreFilter 2	
PreFilter Size 2	
Num Final Filter 1	
Final Filter Size 1	
Num Final Filter 2	
Final Filter Size 2	

Motor Data	
	Actual
Motor MFG	
Frame	
Horsepower	
Motor Rpm	
Phase	
Rated Voltage	
Rated Amperage	
Service Factor	

Test Data		
	Design	Actual
SF CFM	7050	
RA CFM	4975	
OA CFM	2075	
RL Voltage	460	
RL Amperage	-	
SF Motor Freq(HZ)	-	
SF System SetPt	-	
OA Damper Position	-	
Brake Horse Power	-	

Performance Data		
	Design	Actual
Fan Suction SP	-	
Fan Discharge SP	-	
Total ESP	1.400	
Fan Total SP	1.858	
Pre-Filter P.D.	-	
Cooling Coil P.D.	-	
Heating Coil P.D.	-	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: AHU/RTU

Asset: RTU-2B 1

AREA:

Unit Data	
	Actual
MFG	TRANE
Serial Num	
Model Num	WHK240A4S0R
Configuration	VERTICAL
Num OA Filters 1	
OA Filter Size 1	
Num OA Filters 2	
OA Filter Size 2	
Num PreFilter 1	4
PreFilter Size 1	20X24X2
Num PreFilter 2	
PreFilter Size 2	
Num Final Filter 1	
Final Filter Size 1	
Num Final Filter 2	
Final Filter Size 2	

Motor Data	
	Actual
Motor MFG	
Frame	
Horsepower	
Motor Rpm	
Phase	
Rated Voltage	
Rated Amperage	
Service Factor	

Test Data		
	Design	Actual
SF CFM	7050	
RA CFM	4975	
OA CFM	2075	
RL Voltage	460	
RL Amperage	-	
SF Motor Freq(HZ)	-	
SF System SetPt	-	
OA Damper Position	-	
Brake Horse Power	-	

Performance Data		
	Design	Actual
Fan Suction SP	-	
Fan Discharge SP	-	
Total ESP	1.400	
Fan Total SP	1.858	
Pre-Filter P.D.	-	
Cooling Coil P.D.	-	
Heating Coil P.D.	-	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: AHU-DUAL FAN

Asset: DOAS-1

AREA:

UNIT DATA - SUPPLY	
	Actual
Manufacturer	TRANE
Model Number	OAD
Serial Number	
No. Pre-Filters / Size (1)	
No. Pre-Filters / Size (2)	
No. Pre-Filters / Size (3)	
No. Final Filters / Size (1)	
No. Final Filters / Size (2)	
No. Final Filters / Size (3)	

MOTOR DATA - SUPPLY	
	Actual
Motor MFG / Frame	
Horsepower / RPM	
Rated Volts / Phase	
Rated Amperage / SF	

TEST DATA - SUPPLY		
	Design	Actual
Total CFM	6000	
Fan RPM	1644	
VFD Speed	-	
RL Voltage	460	
RL Amperage	-	
Motor B.H.P.	6.32	

PERFORMANCE DATA - SUPPLY		
	Design	Actual
Suction S.P.	-	
Discharge S.P.	-	
Total S.P.	3.95	
DX Coil P.D.	0.24	
Heat Wheel P.D.	0.87	
Pre-Filters P.D.	0.59	
Total ESP	2.00	

UNIT DATA - EXHAUST/RETURN	
	Actual
Manufacturer	TRANE
Model Number	OAD
Serial Number	
No. Pre-Filters / Size (1)	
No. Pre-Filters / Size (2)	
No. Pre-Filters / Size (3)	

MOTOR DATA - EXHAUST/RETURN	
	Actual
Motor MFG / FRAME	
Horsepower / RPM	
Rated Volts / Phase	
Rated Amperage / SF	

TEST DATA - EXHAUST/RETURN		
	Design	Actual
Total CFM	4085	
Relief CFM	-	
Fan RPM	1517	
VFD Speed	-	
RL Voltage	460	
RL Amperage	-	
Motor B.H.P.	2.53	

PERFORMANCE DATA - EXHAUST/RETURN		
	Design	Actual
Static Pressure Stpt	-	
Suction S.P.	-	
Discharge S.P.	-	
Total S.P.	2.59	
Heat Wheel P.D.	0.60	
Pre-Filters P.D.	0.20	
Total ESP	1.79	

TEMPERATURES		
	Design	Actual
OA Temp (db/wb)	-	
RA Temp (db/wb)	75	
MA Temp (db/wb)	-	
SA Temp (db/wb)	-	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Energy Recovery Unit

Asset: ER-1

AREA:

Supply Unit Data	
	Actual
Manufacturer	TRANE
Model Number	FV-2000
Serial Number	
Configuration	
No. Pre Filters/Size	

Exhaust Unit Data	
	Actual
Manufacturer	
Model Number	
Serial Number	
Configuration	
No. Pre Filters/Size	

Supply Motor Data	
	Actual
Motor MFG	
Frame	
Horsepower	
Motor Rpm	
Phase	
Voltage (rated)	
Amperage (rated)	
Service Factor	

Exhaust Motor Data	
	Actual
Motor MFG	
Frame	
Horsepower	
Motor Rpm	
Phase	
Voltage (rated)	
Amperage (rated)	
Service Factor	

Supply Test Data		
	Design	Actual
Total CFM	-	
Fan RPM	-	
VFD Speed	-	
RL Voltage	-	
RL Amperage	-	
Motor B.H.P.	-	

Exhaust Test Data		
	Design	Actual
Total CFM	-	
Fan RPM	-	
VFD Speed	-	
RL Voltage	-	
RL Amperage	-	
Motor B.H.P.	-	

Supply Performance Data		
	Design	Actual
Suction S.P.	-	
Discharge S.P.	-	
Total S.P.	-	
Cooling Coil P.D.	-	
Heating Coil P.D.	-	
Heat Exchanger P.D.	-	
Heat Wheel P.D.	-	
Pre Filters P.D.	-	
Total ESP	-	
EAT Summer DB/WB	-	
LAT Summer DB/WB	-	
EAT Winter DB/WB	-	
LAT Winter DB/WB	-	

Exhaust Performance Data		
	Design	Actual
Suction S.P.	-	
Discharge S.P.	-	
Total S.P.	-	
Cooling Coil P.D.	-	
Heating Coil P.D.	-	
Heat Exchanger P.D.	-	
Heat Wheel P.D.	-	
Pre-Filters P.D.	-	
Total ESP	-	
EAT Summer DB/WB	-	
LAT Summer DB/WB	-	
EAT Winter DB/WB	-	
LAT Winter DB/WB	-	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Energy Recovery Unit

Asset: ER-2A 1

AREA:

Supply Unit Data	
	Actual
Manufacturer	TRANE
Model Number	FV-2000
Serial Number	
Configuration	
No. Pre Filters/Size	

Exhaust Unit Data	
	Actual
Manufacturer	
Model Number	
Serial Number	
Configuration	
No. Pre Filters/Size	

Supply Motor Data	
	Actual
Motor MFG	
Frame	
Horsepower	
Motor Rpm	
Phase	
Voltage (rated)	
Amperage (rated)	
Service Factor	

Exhaust Motor Data	
	Actual
Motor MFG	
Frame	
Horsepower	
Motor Rpm	
Phase	
Voltage (rated)	
Amperage (rated)	
Service Factor	

Supply Test Data		
	Design	Actual
Total CFM	-	
Fan RPM	-	
VFD Speed	-	
RL Voltage	-	
RL Amperage	-	
Motor B.H.P.	-	

Exhaust Test Data		
	Design	Actual
Total CFM	-	
Fan RPM	-	
VFD Speed	-	
RL Voltage	-	
RL Amperage	-	
Motor B.H.P.	-	

Supply Performance Data		
	Design	Actual
Suction S.P.	-	
Discharge S.P.	-	
Total S.P.	-	
Cooling Coil P.D.	-	
Heating Coil P.D.	-	
Heat Exchanger P.D.	-	
Heat Wheel P.D.	-	
Pre Filters P.D.	-	
Total ESP	-	
EAT Summer DB/WB	-	
LAT Summer DB/WB	-	
EAT Winter DB/WB	-	
LAT Winter DB/WB	-	

Exhaust Performance Data		
	Design	Actual
Suction S.P.	-	
Discharge S.P.	-	
Total S.P.	-	
Cooling Coil P.D.	-	
Heating Coil P.D.	-	
Heat Exchanger P.D.	-	
Heat Wheel P.D.	-	
Pre-Filters P.D.	-	
Total ESP	-	
EAT Summer DB/WB	-	
LAT Summer DB/WB	-	
EAT Winter DB/WB	-	
LAT Winter DB/WB	-	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Energy Recovery Unit

Asset: ER-2B 1

AREA:

Supply Unit Data	
	Actual
Manufacturer	TRANE
Model Number	FV-2000
Serial Number	
Configuration	
No. Pre Filters/Size	

Exhaust Unit Data	
	Actual
Manufacturer	
Model Number	
Serial Number	
Configuration	
No. Pre Filters/Size	

Supply Motor Data	
	Actual
Motor MFG	
Frame	
Horsepower	
Motor Rpm	
Phase	
Voltage (rated)	
Amperage (rated)	
Service Factor	

Exhaust Motor Data	
	Actual
Motor MFG	
Frame	
Horsepower	
Motor Rpm	
Phase	
Voltage (rated)	
Amperage (rated)	
Service Factor	

Supply Test Data		
	Design	Actual
Total CFM	-	
Fan RPM	-	
VFD Speed	-	
RL Voltage	-	
RL Amperage	-	
Motor B.H.P.	-	

Exhaust Test Data		
	Design	Actual
Total CFM	-	
Fan RPM	-	
VFD Speed	-	
RL Voltage	-	
RL Amperage	-	
Motor B.H.P.	-	

Supply Performance Data		
	Design	Actual
Suction S.P.	-	
Discharge S.P.	-	
Total S.P.	-	
Cooling Coil P.D.	-	
Heating Coil P.D.	-	
Heat Exchanger P.D.	-	
Heat Wheel P.D.	-	
Pre Filters P.D.	-	
Total ESP	-	
EAT Summer DB/WB	-	
LAT Summer DB/WB	-	
EAT Winter DB/WB	-	
LAT Winter DB/WB	-	

Exhaust Performance Data		
	Design	Actual
Suction S.P.	-	
Discharge S.P.	-	
Total S.P.	-	
Cooling Coil P.D.	-	
Heating Coil P.D.	-	
Heat Exchanger P.D.	-	
Heat Wheel P.D.	-	
Pre-Filters P.D.	-	
Total ESP	-	
EAT Summer DB/WB	-	
LAT Summer DB/WB	-	
EAT Winter DB/WB	-	
LAT Winter DB/WB	-	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-100

AREA:103 FIELD STAFF

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFYP015MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	660	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:  
SUBMITTAL MAX AIRFLOW: 494 CFM  
DIFFUSER TOTAL: 660 CFM

Written By: Michael Gabbert on 01/09/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



### Diffuser Supply (GRD)

#### FC-100/103 FIELD STAFF

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
100-1	103 FIELD STAFF	S3	8	165			-
100-2	103 FIELD STAFF	S3	8	165			-
100-3	103 FIELD STAFF	S3	8	165			-
100-4	103 FIELD STAFF	S3	8	165			-
Total				660	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-101

AREA:103 FIELD STAFF

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFYP015MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	660	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 494 CFM  
DIFFUSER TOTAL: 660 CFM

Written By: Michael Gabbert on 01/09/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



### Diffuser Supply (GRD)

#### FC-101/103 FIELD STAFF

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
101-1	103 FIELD STAFF	S3	8	165			-
101-2	103 FIELD STAFF	S3	8	165			-
101-3	103 FIELD STAFF	S3	8	165			-
101-4	103 FIELD STAFF	S3	8	165			-
Total				660	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-102

AREA:102 LARGE BREAK

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFYP048MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	1935	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:  
SUBMITTAL MAX AIRFLOW: 1306 CFM  
DIFFUSER TOTAL: 1935 CFM

Written By: Michael Gabbert on 01/09/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-102/102 LARGE BREAK

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
102-1	102 LARGE BREAK	S1	8	215			-
102-2	102 LARGE BREAK	S1	8	215			-
102-3	102 LARGE BREAK	S1	8	215			-
102-4	102 LARGE BREAK	S1	8	215			-
102-5	102 LARGE BREAK	S1	8	215			-
102-6	102 LARGE BREAK	S1	8	215			-
102-7	102 LARGE BREAK	S1	8	215			-
102-8	102 LARGE BREAK	S1	8	215			-
102-9	102 LARGE BREAK	S1	8	215			-
Total				1935	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-103

AREA:104 FITNESS

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFYYP008MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	300	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 300 CFM  
DIFFUSER TOTAL: 350 CFM

Written By: Michael Gabbert on 01/09/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-103/104 FITNESS

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
103-1	104 FITNESS	S3	8	150			-
103-2	104 FITNESS	S3	8	150			-
103-3	104 FITNESS	S2	8X8	50			-
Total				350	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-104

AREA:101 KITCHEN

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFYYP008MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	400	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 300 CFM  
DIFFUSER TOTAL: 400 CFM

Written By: Michael Gabbert on 01/09/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-104/101 KITCHEN

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
104-1	101 KITCHEN	S3	8	200			-
104-2	101 KITCHEN	S3	8	200			-
Total				400	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-105

AREA:101A SMALL BREAK

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFYP015MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	1000	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 494 CFM

DIFFUSER TOTAL: 1000 CFM

Written By: Michael Gabbert on 01/09/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-105/101A SMALL BREAK

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
105-1	101A SMALL BREAK	S1	8	200			-
105-2	101A SMALL BREAK	S1	8	200			-
105-3	101A SMALL BREAK	S1	8	200			-
105-4	101A SMALL BREAK	S1	8	200			-
105-5	101A SMALL BREAK	S1	8	200			-
Total				1000	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-106

AREA:100 ENTRY

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFY012MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	550	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 371 CFM  
DIFFUSER TOTAL: 550 CFM

Written By: Michael Gabbert on 01/09/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



### Diffuser Supply (GRD)

#### FC-106/100 ENTRY

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
106-1	100 ENTRY	S1	8	150			-
106-2	109 LAUNDRY	S3	8	50			-
106-3	100 ENTRY	S1	8	150			-
106-4	100 ENTRY	S1	8	150			-
106-5	100 ENTRY	S3	8	50			-
Total				550	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-107

AREA:112 WOMEN LOCKER

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFY024MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	1050	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 883 CFM

DIFFUSER TOTAL: 1050 CFM

Written By: Michael Gabbert on 01/09/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



### Diffuser Supply (GRD)

#### FC-107/112 WOMEN LOCKER

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
107-1	112 WOMEN LOCKER	S3	8	250			-
107-2	112 WOMEN LOCKER	S3	8	250			-
107-3	112 WOMEN LOCKER	S3	8	250			-
107-4	112 WOMEN LOCKER	S3	8	250			-
107-5	112 WOMEN LOCKER	S3	8	50			-
Total				1050	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-108

AREA:111 MENS LOCKER

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFYP048MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	2200	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:  
SUBMITTAL MAX AIRFLOW: 1306 CFM  
DIFFUSER TOTAL: 2200 CFM

Written By: Michael Gabbert on 01/09/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



### Diffuser Supply (GRD)

#### FC-108/111 MENS LOCKER

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
108-1	111 MENS LOCKER	S3	10	275			-
108-2	111 MENS LOCKER	S3	10	275			-
108-3	111 MENS LOCKER	S3	10	275			-
108-4	111 MENS LOCKER	S3	10	275			-
108-5	111 MENS LOCKER	S3	10	275			-
108-6	111 MENS LOCKER	S3	10	275			-
108-7	111 MENS LOCKER	S3	10	275			-
108-8	111 MENS LOCKER	S3	10	275			-
Total				2200	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-109

AREA:131 LIGHTWELL

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFY024MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	1000	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 883 CFM

DIFFUSER TOTAL: 1000 CFM

Written By: Michael Gabbert on 01/09/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-109/131 LIGHTWELL

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
109-1	110 MUDROOM	S3	10	235			-
109-2	131 LIGHTWELL	S2	14X8	255			-
109-3	131 LIGHTWELL	S2	14X8	255			-
109-4	128 HALL	S2	14X8	255			-
Total				1000	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-110

AREA:126 WAREHOUSE OFFICE

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFYP015MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	290	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 494 CFM

DIFFUSER TOTAL: 290 CFM

Written By: Michael Gabbert on 01/09/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-110/126 WAREHOUSE OFFICE

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
110-1	126 WAREHOUSE OFFICE	S3	10	290			-
Total				290	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-111

AREA:100B HALL

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFYYP008MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	400	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 300 CFM

DIFFUSER TOTAL: 400 CFM

Written By: Michael Gabbert on 01/09/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



### Diffuser Supply (GRD)

#### FC-111/100B HALL

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
111-1	100B HALL	S3	8	200			-
111-2	100B HALL	S3	8	200			-
Total				400	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-112

AREA:102 LARGE BREAK

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFYP048MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	2150	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:  
SUBMITTAL MAX AIRFLOW: 1306 CFM  
DIFFUSER TOTAL: 2150 CFM

Written By: Michael Gabbert on 01/09/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-112/102 LARGE BREAK

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
112-1	102 LARGE BREAK	S1	8	215			-
112-2	102 LARGE BREAK	S1	8	215			-
112-3	102 LARGE BREAK	S1	8	215			-
112-4	102 LARGE BREAK	S1	8	215			-
112-5	102 LARGE BREAK	S1	8	215			-
112-6	102 LARGE BREAK	S1	8	215			-
112-7	102 LARGE BREAK	S1	8	215			-
112-8	102 LARGE BREAK	S1	8	215			-
112-9	102 LARGE BREAK	S1	8	215			-
112-10	102 LARGE BREAK	S1	8	215			-
Total				2150	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-201

AREA:203 ADMIN DIRECTOR

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFYP030MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	1300	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 883 CFM

DIFFUSER TOTAL: 1300 CFM

Written By: Michael Gabbert on 01/09/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



### Diffuser Supply (GRD)

#### FC-201/203 ADMIN DIRECTOR

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
201-1	203 ADMIN DIRECTOR	S3	10	400			-
201-2	204 ADMIN OFFICE	S3	10	300			-
201-3	205 ADMIN OFFICE	S3	10	300			-
201-4	206 ADMIN OFFICE	S3	10	300			-
Total				1300	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-202

AREA:200 CORRIDOR

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFYP012MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	465	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 371 CFM  
DIFFUSER TOTAL: 465 CFM

Written By: Michael Gabbert on 01/09/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-202/200 CORRIDOR

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
202-1	200 CORRIDOR	S4	24X4	155			-
202-2	200 CORRIDOR	S4	24X4	155			-
202-3	200 CORRIDOR	S4	24X4	155			-
Total				465	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-203

AREA:209 ADMIN DIRECTOR

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFY030MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	1000	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 883 CFM

DIFFUSER TOTAL: 1000 CFM

Written By: Michael Gabbert on 01/09/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



### Diffuser Supply (GRD)

#### FC-203/209 ADMIN DIRECTOR

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
203-1	207 ADMIN OFFICE	S3	8	300			-
203-2	208 ADMIN OFFICE	S3	8	300			-
203-3	209 ADMIN DIRECTOR	S3	8	200			-
203-4	209 ADMIN DIRECTOR	S3	8	200			-
Total				1000	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-204

AREA:

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFY024MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	735	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 883 CFM

DIFFUSER TOTAL: 735 CFM

Written By: Michael Gabbert on 01/09/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



### Diffuser Supply (GRD)

#### FC-204/

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
204-1	202 OPEN OFFICE	S4	24X4	105			-
204-2	202 OPEN OFFICE	S4	24X4	105			-
204-3	202 OPEN OFFICE	S4	24X4	105			-
204-4	202 OPEN OFFICE	S4	24X4	105			-
204-5	202 OPEN OFFICE	S4	24X4	105			-
204-6	202 OPEN OFFICE	S4	24X4	105			-
204-7	202 OPEN OFFICE	S4	24X4	105			-
Total				735	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-205

AREA:210 ADMIN OFFICE

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFY015MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	645	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 494 CFM  
DIFFUSER TOTAL: 645 CFM

Written By: Michael Gabbert on 01/09/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



### Diffuser Supply (GRD)

#### FC-205/210 ADMIN OFFICE

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
205-1	212 AMI OFFICE	S3	8	215			-
205-2	211 ADMIN OFFICE	S3	8	215			-
205-3	210 ADMIN OFFICE	S3	8	215			-
Total				645	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-206

AREA:215 ADMIN OFFICE

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFYP015MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	645	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 494 CFM  
DIFFUSER TOTAL: 645 CFM

Written By: Michael Gabbert on 01/09/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



### Diffuser Supply (GRD)

#### FC-206/215 ADMIN OFFICE

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
206-1	217 ADMIN OFFICE	S3	8	215			-
206-2	216 ADMIN OFFICE	S3	8	215			-
206-3	215 ADMIN OFFICE	S3	8	215			-
Total				645	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-207

AREA:201 OPEN OFFICE

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFY030MA145A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	960	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:  
SUBMITTAL MAX AIRFLOW: 1271 CFM  
DIFFUSER TOTAL: 960 CFM

Written By: Michael Gabbert on 01/09/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



### Diffuser Supply (GRD)

#### FC-207/201 OPEN OFFICE

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
207-1	201 OPEN OFFICE	S4	24X4	120			-
207-2	201 OPEN OFFICE	S4	24X4	120			-
207-3	201 OPEN OFFICE	S4	24X4	120			-
207-4	201 OPEN OFFICE	S4	24X4	120			-
207-5	201 OPEN OFFICE	S4	24X4	120			-
207-6	201 OPEN OFFICE	S4	24X4	120			-
207-7	201 OPEN OFFICE	S4	24X4	120			-
207-8	201 OPEN OFFICE	S4	24X4	120			-
Total				960	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-208

AREA:

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFYP012MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	490	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 371 CFM  
DIFFUSER TOTAL: 490 CFM

Written By: Michael Gabbert on 01/09/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



### Diffuser Supply (GRD)

#### FC-208/

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
208-1	213 COLLAB	A1	8	245			-
208-2	213 COLLAB	A1	8	245			-
Total				490	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-209

AREA:201A RECEPTION

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFY008MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	280	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-209/201A RECEPTION

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
209-1	201A RECEPTION	S4	24X4	70			-
209-2	201A RECEPTION	S4	24X4	70			-
209-3	201A RECEPTION	S4	24X4	70			-
209-4	201A RECEPTION	S4	24X4	70			-
Total				280	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-210

AREA:292 CMED DIRECTOR

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFY030MA145A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	1050	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 1271 CFM

DIFFUSER TOTAL: 1050 CFM

Written By: Michael Gabbert on 01/09/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



### Diffuser Supply (GRD)

#### FC-210/292 CMED DIRECTOR

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
210-1	294 CMED OFFICE	S3	10	320			-
210-2	293 CMED OFFICE	S3	10	320			-
210-3	292 CMED DIRECTOR	S3	8	205			-
210-4	292 CMED DIRECTOR	S3	8	205			-
Total				1050	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-211

AREA:296 CMED OFFICE

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFY024MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	960	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 883 CFM  
DIFFUSER TOTAL: 960 CFM

Written By: Michael Gabbert on 01/09/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



### Diffuser Supply (GRD)

#### FC-211/296 CMED OFFICE

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
211-1	297 CMED OFFICE	S3	10	320			-
211-2	296 CMED OFFICE	S3	10	320			-
211-3	295 CMED OFFICE	S3	10	320			-
Total				960	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-212

AREA:298 FITNESS

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFYP015MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	410	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 494 CFM  
DIFFUSER TOTAL: 410 CFM

Written By: Michael Gabbert on 01/09/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-212/298 FITNESS

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
212-1	298 FITNESS	S3	8	205			-
212-2	298 FITNESS	S3	8	205			-
Total				410	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-213

AREA:283 OPEN OFFICE

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFY030MA145A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	1200	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-213/283 OPEN OFFICE

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
213-1	283 OPEN OFFICE	S4	24X4	120			-
213-2	283 OPEN OFFICE	S4	24X4	120			-
213-3	283 OPEN OFFICE	S4	24X4	120			-
213-4	283 OPEN OFFICE	S4	24X4	120			-
213-5	283 OPEN OFFICE	S4	24X4	120			-
213-6	283 OPEN OFFICE	S4	24X4	120			-
213-7	283 OPEN OFFICE	S4	24X4	120			-
213-8	283 OPEN OFFICE	S4	24X4	120			-
213-9	283 OPEN OFFICE	S4	24X4	120			-
213-10	283 OPEN OFFICE	S4	24X4	120			-
Total				1200	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-214

AREA:283 OPEN OFFICE

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFYP024MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	960	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 883 CFM  
DIFFUSER TOTAL: 960 CFM

Written By: Michael Gabbert on 01/09/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-214/283 OPEN OFFICE

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
214-1	283 OPEN OFFICE	S4	24X4	120			-
214-2	283 OPEN OFFICE	S4	24X4	120			-
214-3	283 OPEN OFFICE	S4	24X4	120			-
214-4	283 OPEN OFFICE	S4	24X4	120			-
214-5	283 OPEN OFFICE	S4	24X4	120			-
214-6	283 OPEN OFFICE	S4	24X4	120			-
214-7	283 OPEN OFFICE	S4	24X4	120			-
214-8	283 OPEN OFFICE	S4	24X4	120			-
Total				960	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-215

AREA:271 PLOTTING

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFY008MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	150	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-215/271 PLOTTING

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
215-1	271 PLOTTING	S3	8	150			-
Total				150	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-216

AREA:289 CMED OFFICE

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFY024MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	920	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 883 CFM

DIFFUSER TOTAL: 920 CFM

Written By: Michael Gabbert on 01/12/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



### Diffuser Supply (GRD)

#### FC-216/289 CMED OFFICE

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
16-1	291 CMED COLLAB	S3	8	230			-
16-2	290 CMED OFFICE	S3	8	230			-
16-3	289 CMED OFFICE	S3	8	230			-
16-4	288 CMED OFFICE	S3	8	230			-
Total				920	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-217

AREA:286 CMED OFFICE

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFY024MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	920	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 883 CFM  
DIFFUSER TOTAL: 920 CFM

Written By: Michael Gabbert on 01/12/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



### Diffuser Supply (GRD)

#### FC-217/286 CMED OFFICE

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
217-1	284 CMED OFFICE	S3	8	230			-
217-2	285 CMED OFFICE	S3	8	230			-
217-3	286 CMED OFFICE	S3	8	230			-
217-4	287 CMED OFFICE	S3	8	230			-
Total				920	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-218

AREA:NOT FOUND

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFY012MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	371	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-219

AREA:277 BOOTH

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	NA
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	150	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-219/277 BOOTH

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
219-1	277 BOOTH	S3	8	150			-
Total				150	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-220

AREA:282 CMED OFFICE

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFYP015MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	420	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-220/282 CMED OFFICE

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
220-1	282 CMED OFFICE	S3	10	210			-
220-2	282 CMED OFFICE	S3	10	210			-
Total				420	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-221

AREA:279 CMED OFFICE

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFYP015MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	1140	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 494 CFM  
DIFFUSER TOTAL: 1140 CFM

Written By: Michael Gabbert on 01/12/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



### Diffuser Supply (GRD)

#### FC-221/279 CMED OFFICE

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
221-1	281 CMED OFFICE	S3	10	285			-
221-2	280 CMED OFFICE	S3	10	285			-
221-3	279 CMED OFFICE	S3	10	285			-
221-4	278 CMED OFFICE	S3	10	285			-
Total				1140	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-222

AREA:266 BREAKROOM

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFY018MA145A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	750	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-222/266 BREAKROOM

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
222-1	266 BREAKROOM	S4	24X4	150			-
222-2	266 BREAKROOM	S4	24X4	150			-
222-3	266 BREAKROOM	S4	24X4	150			-
222-4	266 BREAKROOM	S4	24X4	150			-
222-5	266 BREAKROOM	S4	24X4	150			-
Total				750	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-223

AREA:270 OPEN CONF

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFY008MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	380	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	-	
RL Amperage	208	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 300 CFM  
DIFFUSER TOTAL: 380 CFM

Written By: Michael Gabbert on 01/12/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-223/270 OPEN CONF

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
223-1	270 OPEN CONF	S3	8	190			-
223-2	270 OPEN CONF	S3	8	190			-
Total				380	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-224

AREA:269 LARGE CONF/TRAINING

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFYP018MA145A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	840	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



### Diffuser Supply (GRD)

#### FC-224/269 LARGE CONF/TRAINING

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
224-1	269 LG CONF/TRAINING	S3	8	210			-
224-2	269 LG CONF/TRAINING	S3	8	210			-
224-3	269 LG CONF/TRAINING	S3	8	210			-
224-4	269 LG CONF/TRAINING	S3	8	210			-
Total				840	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-225

AREA:268 MED CONF

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFY008MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	440	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	-	

Notes:  
SUBMITTAL MAX AIRFLOW: 300 CFM  
DIFFUSER TOTAL: 440 CFM

Written By: Michael Gabbert on 01/12/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-225/268 MED CONF

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
225-1	268 MED CONF	S3	8	220			-
225-2	268 MED CONF	S3	8	220			-
Total				440	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-226

AREA:267 MED CONF

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFYP008MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	440	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 300 CFM  
DIFFUSER TOTAL: 440 CFM

Written By: Michael Gabbert on 01/12/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-226/267 MED CONF

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
226-1	267 MED CONF	S3	8	220			-
226-2	267 MED CONF	S3	8	220			-
Total				440	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-227

AREA:236 CONF

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFYYP008MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	280	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-227/236 CONF

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
227-1	236 CONF	S3	8	140			-
227-2	237 CONF	S3	8	140			-
Total				280	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-228

AREA:239 CONF

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFYP008MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	370	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 300 CFM  
DIFFUSER TOTAL: 370 CFM

Written By: Michael Gabbert on 01/12/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-228/239 CONF

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
228-1	239 CONF	S2	14X8	185			-
228-2	238 CONF	S2	14X8	185			-
Total				370	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-229

AREA:233 WELLNESS

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFYYP008MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	300	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-229/233 WELLNESS

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
229-1	233 WELLNESS						
229-2	233 WELLNESS						
Total				0	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-230

AREA:241 TRAFFIC CENTRAL UNIT

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFY048MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	950	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



### Diffuser Supply (GRD)

#### FC-230/241 TRAFFIC CENTRAL UNIT

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
230-1	228 WORK ROOM	S3	8	50			-
230-2	241 TRAFFIC CENTRAL UNIT	S3	10	300			-
230-3	241 TRAFFIC CENTRAL UNIT	S3	10	300			-
230-4	241B STOR	S3	10	300			-
Total				950	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-231

AREA:240B IT

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFY036MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	1271	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-231/240B IT

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
231-1	240B IT						
231-2	240B IT						
Total				0	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-232

AREA:200 CORRIDOR

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFY008MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	1400	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 300 CFM  
DIFFUSER TOTAL: 1400 CFM

Written By: Michael Gabbert on 01/12/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-232/200 CORRIDOR

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
232-1	200 CORRIDOR	S7	12	350			-
232-2	200 CORRIDOR	S7	12	350			-
232-3	200 CORRIDOR	S7	12	350			-
232-4	200 CORRIDOR	S7	12	350			-
Total				1400	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-233

AREA:223 SMALL CONF/FUTURE

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFYYP008MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	265	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-233/223 SMALL CONF/FUTURE

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
233-1	223 SMALL CONF/FUTURE	S3	10	265			-
Total				265	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-234

AREA:

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFYP012MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	520	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 371 CFM  
DIFFUSER TOTAL: 520 CFM

Written By: Michael Gabbert on 01/12/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



### Diffuser Supply (GRD)

#### FC-234/

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
234-1	224 MED CONF	S3	10	260			-
234-2	224 MED CONF	S3	10	260			-
Total				520	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-235

AREA:225 SMALL CONF/FUTURE

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFY018MA145A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	795	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



### Diffuser Supply (GRD)

#### FC-235/225 SMALL CONF/FUTURE

Asset													
Asset Name	Location	Type	MFG	Size	Model Num	DESIGN CFM	AK	VEL(1)	CFM(1)	VEL(2)	CFM(2)	FINAL CFM	% to design
235-1	225 SMALL CONF/FUTURE	S3	NA	10	NA	265							-
235-2	225 SMALL CONF/FUTURE	S3	NA	10	NA	265							-
235-3	227 SMALL CONF/FUTURE	S3	NA	10	NA	265							-
Total						795			0		0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-236

AREA:

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFY008MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	490	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 300 CFM  
DIFFUSER TOTAL: 490 CFM

Written By: Michael Gabbert on 01/12/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



### Diffuser Supply (GRD)

#### FC-236/

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
236-1	248 COLLAB	S1	8	245			-
236-2	248 COLLAB	S1	8	245			-
Total				490	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-237

AREA:218 ADMIN OFFICE

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFY024MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	600	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



### Diffuser Supply (GRD)

#### FC-237/218 ADMIN OFFICE

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
237-1	219 BOOTH	S1	6	50			-
237-2	218 ADMIN OFFICE	S1	8	200			-
237-3	220 BOOTH	S1	6	50			-
237-4	221 BOOTH	S1	6	50			-
237-5	214 AMI OFFICE	S1	8	200			-
237-6	222 BOOTH	S1	6	50			-
Total				600	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-238

AREA:246 OPEN OFFICE

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFY030MA145A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	1200	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-238/246 OPEN OFFICE

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
238-1	246 OPEN OFFICE	S4	24X4	150			-
238-2	246 OPEN OFFICE	S4	24X4	150			-
238-3	246 OPEN OFFICE	S4	24X4	150			-
238-4	246 OPEN OFFICE	S4	24X4	150			-
238-5	246 OPEN OFFICE	S4	24X4	150			-
238-6	246 OPEN OFFICE	S4	24X4	150			-
238-7	246 OPEN OFFICE	S4	24X4	150			-
238-8	246 OPEN OFFICE	S4	24X4	150			-
Total				1200	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-239

AREA:246 OPEN OFFICE

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFY030MA145A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	1200	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-239/246 OPEN OFFICE

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
239-1	246 OPEN OFFICE	S4	24X4	150			-
239-2	246 OPEN OFFICE	S4	24X4	150			-
239-3	246 OPEN OFFICE	S4	24X4	150			-
239-4	246 OPEN OFFICE	S4	24X4	150			-
239-5	246 OPEN OFFICE	S4	24X4	150			-
239-6	246 OPEN OFFICE	S4	24X4	150			-
239-7	246 OPEN OFFICE	S4	24X4	150			-
239-8	246 OPEN OFFICE	S4	24X4	150			-
Total				1200	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-240

AREA:261 OPEN OFFICE

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFYP015MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	600	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 494 CFM

DIFFUSER TOTAL: 600 CFM

Written By: Michael Gabbert on 01/12/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



### Diffuser Supply (GRD)

#### FC-240/261 OPEN OFFICE

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
240-1	261 OPEN OFFICE	S4	24X4	120			-
240-2	261 OPEN OFFICE	S4	24X4	120			-
240-3	261 OPEN OFFICE	S4	24X4	120			-
240-4	261 OPEN OFFICE	S4	24X4	120			-
240-5	261 OPEN OFFICE	S4	24X4	120			-
Total				600	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-241

AREA:261 OPEN OFFICE

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFYP015MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	600	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 494 CFM  
DIFFUSER TOTAL: 600 CFM

Written By: Michael Gabbert on 01/12/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



### Diffuser Supply (GRD)

#### FC-241/261 OPEN OFFICE

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
241-1	261 OPEN OFFICE	S4	24X4	100			-
241-2	261 OPEN OFFICE	S4	24X4	100			-
241-3	261 OPEN OFFICE	S4	24X4	100			-
241-4	261 OPEN OFFICE	S4	24X4	100			-
241-5	261 OPEN OFFICE	S4	24X4	100			-
241-6	261 OPEN OFFICE	S4	24X4	100			-
Total				600	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-242

AREA:244 PHONE BOOTH

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFYP018MA145A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	200	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-242/244 PHONE BOOTH

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
242-1	242 PHONE BOOTH	S1	6	50			-
242-2	243 PHONE BOOTH	S1	6	50			-
242-3	244 PHONE BOOTH	S1	6	50			-
242-4	245 PHONE BOOTH	S1	6	50			-
Total				200	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-243

AREA:265 TRAF OFFICE

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFYYP008MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	460	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 300 CFM  
DIFFUSER TOTAL: 460 CFM

Written By: Michael Gabbert on 01/12/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-243/265 TRAF OFFICE

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
243-1	265 TRAF OFFICE	S3	8	230			-
243-2	265 TRAF OFFICE	S3	8	230			-
Total				460	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-244

AREA:263 STRTS OFFICE

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFYP015MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	690	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 494 CFM  
DIFFUSER TOTAL: 690 CFM

Written By: Michael Gabbert on 01/12/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



### Diffuser Supply (GRD)

#### FC-244/263 STRTS OFFICE

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
244-1	264 STRTS OFFICE	S3	8	230			-
244-2	263 STRTS OFFICE	S3	8	230			-
244-3	262 STRTS OFFICE	S3	8	230			-
Total				690	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-245

AREA:250 INS OFFICE

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFYP015MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	690	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 494 CFM  
DIFFUSER TOTAL: 690 CFM

Written By: Michael Gabbert on 01/12/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-245/250 INS OFFICE

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
245-1	251 WTRT OFFICE	S3	8	230			-
245-2	250 INS OFFICE	S3	8	230			-
245-3	249 INS OFFICE	S3	8	230			-
Total				690	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-246

AREA:252 DEPUTY OFFICE

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFY024MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	615	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



### Diffuser Supply (GRD)

#### FC-246/252 DEPUTY OFFICE

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
246-1	253 WSWT OFFICE	S3	10	295			-
246-2	252 DEPUTY OFFICE	S3	10	320			-
Total				615	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-247

AREA:254 WTDT OFFICE

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFY024MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	885	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-247/254 WTDT OFFICE

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
247-1	256 WTDT OFFICE	S3	10	295			-
247-2	255 WTDT OFFICE	S3	10	295			-
247-3	254 WTDT OFFICE	S3	10	295			-
Total				885	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-248

AREA:260 FOB OFFICE

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFY024MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	1305	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 883 CFM

DIFFUSER TOTAL: 1305 CFM

Written By: Michael Gabbert on 01/12/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



### Diffuser Supply (GRD)

#### FC-248/260 FOB OFFICE

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
248-1	257 STRT OFFICE	S3	10	295			-
248-2	258 INS OFFICE	S3	10	295			-
248-3	259 STWT OFFICE	S3	10	295			-
248-4	260 FOB OFFICE	S3	10	210			-
248-5	260 FOB OFFICE	S3	10	210			-
Total				1305	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-249

AREA:261 OPEN OFFICE

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFYP012MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	440	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 371 CFM  
DIFFUSER TOTAL: 440 CFM

Written By: Michael Gabbert on 01/12/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-249/261 OPEN OFFICE

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
249-1	261 OPEN OFFICE	S4	24X4	110			-
249-2	261 OPEN OFFICE	S4	24X4	110			-
249-3	261 OPEN OFFICE	S4	24X4	110			-
249-4	261 OPEN OFFICE	S4	24X4	110			-
Total				440	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-250

AREA:202 OPEN OFFICE

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFY024MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	735	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



### Diffuser Supply (GRD)

#### FC-250/202 OPEN OFFICE

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
250-1	202 OPEN OFFICE	S4	24X4	105			-
250-2	202 OPEN OFFICE	S4	24X4	105			-
250-3	202 OPEN OFFICE	S4	24X4	105			-
250-4	202 OPEN OFFICE	S4	24X4	105			-
250-5	202 OPEN OFFICE	S4	24X4	105			-
250-6	202 OPEN OFFICE	S4	24X4	105			-
250-7	202 OPEN OFFICE	S4	24X4	105			-
Total				735	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-251

AREA:200 CORRIDOR

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFY024MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	300	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-251/200 CORRIDOR

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
251-1	200 CORRIDOR	S3	10	300			-
Total				300	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Fan Coil

Asset: FC-252

AREA:200 CORRIDOR

Unit Data		
	Design	Actual
MFG	TRANE	TRANE
Model Num	NA	TPEFYP024MA144A
Serial Num	-	
Type	-	
Num Filters Size 1	-	
Filter Size 1	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	
Brake Horse Power	-	

Test Data		
	Design	Actual
SFAN CFM	1395	
SFAN RPM	-	
Motor Frequency	-	
Motor Speed SetPt	-	
RL Voltage	208	
RL Amperage	-	
RA CFM	-	
OA CFM	-	

Performance Data		
	Design	Actual
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.60	

Notes:

SUBMITTAL MAX AIRFLOW: 1306 CFM

DIFFUSER TOTAL: 1395 CFM

Written By: Michael Gabbert on 01/12/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## Fan Coil



Diffuser Supply (GRD)

### FC-252/200 CORRIDOR

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
252-1	200 CORRIDOR	S7	12	465			-
252-2	200 CORRIDOR	S7	12	465			-
252-3	200 CORRIDOR	S7	12	465			-
Total				1395	0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: FAN - Exhaust

Asset: EF-1

AREA:113 INSPECTIONS

Unit Data		
	Design	Actual
MFG	GREENHECK	GREENHECK
Model Num	NA	SQ-90-VG
Serial Num	-	
Type	INLINE	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	

Test Data		
	Design	Actual
CFM	595	
Motor Frequency	-	
System SetPt	-	
RL Voltage	115	
RL Amperage	1.38	
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.20	
Brake Horse Power	-	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: FAN - Exhaust

Asset: EF-2

AREA:118 OUTFITTING SHOP

Unit Data		
	Design	Actual
MFG	GREENHECK	GREENHECK
Model Num	NA	SQ-140-VG
Serial Num	-	
Type	INLINE	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	

Test Data		
	Design	Actual
CFM	2185	
Motor Frequency	-	
System SetPt	-	
RL Voltage	115	
RL Amperage	8.80	
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.20	
Brake Horse Power	-	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: FAN - Exhaust

Asset: EF-3

AREA:118 FAB SHOP

Unit Data		
	Design	Actual
MFG	GREENHECK	GREENHECK
Model Num	NA	SQ-140-VG
Serial Num	-	
Type	INLINE	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	

Test Data		
	Design	Actual
CFM	2185	
Motor Frequency	-	
System SetPt	-	
RL Voltage	115	
RL Amperage	8.80	
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.20	
Brake Horse Power	-	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: FAN - Exhaust

Asset: EF-4

AREA:118 FAB SHOP

Unit Data		
	Design	Actual
MFG	GREENHECK	GREENHECK
Model Num	NA	SQ-140-VG
Serial Num	-	
Type	INLINE	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	

Test Data		
	Design	Actual
CFM	2185	
Motor Frequency	-	
System SetPt	-	
RL Voltage	115	
RL Amperage	8.80	
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.20	
Brake Horse Power	-	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: FAN - Exhaust

Asset: EF-5

AREA:117 WSWT SHOP

Unit Data		
	Design	Actual
MFG	GREENHECK	GREENHECK
Model Num	NA	SQ-95-VG
Serial Num	-	
Type	INLINE	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	

Test Data		
	Design	Actual
CFM	785	
Motor Frequency	-	
System SetPt	-	
RL Voltage	115	
RL Amperage	2.20	
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.20	
Brake Horse Power	-	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: FAN - Exhaust

Asset: EF-6

AREA:129 SIGN FAB SHOP

Unit Data		
	Design	Actual
MFG	GREENHECK	GREENHECK
Model Num	NA	SQ-90-VG
Serial Num	-	
Type	INLINE	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	

Test Data		
	Design	Actual
CFM	540	
Motor Frequency	-	
System SetPt	-	
RL Voltage	115	
RL Amperage	1.38	
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.20	
Brake Horse Power	-	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: FAN - Exhaust

Asset: EF-7

AREA:131 CONDITIONED STORAGE

Unit Data		
	Design	Actual
MFG	GREENHECK	GREENHECK
Model Num	NA	G-200-VG
Serial Num	-	
Type	CRE DNBLAST	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	

Test Data		
	Design	Actual
CFM	4995	
Motor Frequency	-	
System SetPt	-	
RL Voltage	208	
RL Amperage	7.40	
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.25	
Brake Horse Power	-	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: FAN - Exhaust

Asset: EF-8

AREA:131 CONDITIONED STORAGE

Unit Data		
	Design	Actual
MFG	GREENHECK	GREENHECK
Model Num	NA	G-200-VG
Serial Num	-	
Type	CRE DNBLAST	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	

Test Data		
	Design	Actual
CFM	4995	
Motor Frequency	-	
System SetPt	-	
RL Voltage	208	
RL Amperage	7.40	
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.25	
Brake Horse Power	-	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: FAN - Exhaust

Asset: EF-9

AREA:FLR 1 RESTROOMS

Unit Data		
	Design	Actual
MFG	GREENHECK	GREENHECK
Model Num	NA	SQ-90-VG
Serial Num	-	
Type	INLINE	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	

Test Data		
	Design	Actual
CFM	275	
Motor Frequency	-	
System SetPt	-	
RL Voltage	115	
RL Amperage	1.38	
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.25	
Brake Horse Power	-	

Notes:

SUBMITTAL MAX AIRFLOW: 200 CFM  
GRILLE TOTAL: 275 CFM

Written By: Michael Gabbert on 01/13/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## FAN - Exhaust



Diffuser Ret/Exh (GRD)

### EF-9/FLR 1 RESTROOMS

Asset								
Asset Name	Location	Type	Size	DESIGN CFM	AK	CFM(1)	FINAL CFM	% to design
E9-1	108 GNR	E1	6X6	50				-
E9-2	107 GNSR	E1	6X6	50				-
E9-3	106 ADA SHOWER	E1	8X8	100				-
E9-4	109 UNIFORM STOR/LAUNDRY	22	6	75				-
Total				275		0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: FAN - Exhaust

Asset: EF-11

AREA:FLR 1 LOCKER ROOMS

Unit Data		
	Design	Actual
MFG	GREENHECK	GREENHECK
Model Num	NA	G-120-VG
Serial Num	-	
Type	CRE DNBLAST	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	

Test Data		
	Design	Actual
CFM	1500	
Motor Frequency	-	
System SetPt	-	
RL Voltage	115	
RL Amperage	2.85	
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.50	
Brake Horse Power	-	

Notes:

SUBMITTAL MAX AIRFLOW: 945 CFM  
GRILLE TOTAL: 1500 CFM

Written By: Michael Gabbert on 01/13/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## FAN - Exhaust

Diffuser Ret/Exh (GRD)

### EF-11/FLR 1 LOCKER ROOMS

Asset								
Asset Name	Location	Type	Size	DESIGN CFM	AK	CFM(1)	FINAL CFM	% to design
E11-1	112 WOMEN LOCKERROOM	E1	12X12	250				-
E11-2	112 WOMEN LOCKERROOM	E2	8	200				-
E11-3	112 WOMEN LOCKERROOM	E1	6X6	50				-
E11-4	112 WOMEN LOCKERROOM	E1	6X6	50				-
E11-5	112 WOMEN LOCKERROOM	E1	6X6	50				-
E11-6	112 WOMEN LOCKERROOM	E1	6X6	50				-
E11-7	112 WOMEN LOCKERROOM	E1	6X6	50				-
E11-8	116 JANITOR	E1	6X6	50				-
E11-9	111 MENS LOCKERROOM	E2	8	200				-
E11-10	111 MENS LOCKERROOM	E1	12X12	300				-
E11-11	111 MENS LOCKERROOM	E1	6X6	50				-
E11-12	111 MENS LOCKERROOM	E1	6X6	50				-
E11-13	111 MENS LOCKERROOM	E1	6X6	50				-
E11-14	111 MENS LOCKERROOM	E1	6X6	50				-
E11-15	111 MENS LOCKERROOM	E1	6X6	50				-
Total				1500		0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: FAN - Exhaust

Asset: EF-12

AREA:FLR 2 RESTROOMS

Unit Data		
	Design	Actual
MFG	GREENHECK	GREENHECK
Model Num	NA	G-095-VG
Serial Num	-	
Type	CRE DNBLAST	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	

Test Data		
	Design	Actual
CFM	525	
Motor Frequency	-	
System SetPt	-	
RL Voltage	115	
RL Amperage	2.20	
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.50	
Brake Horse Power	-	

Notes:

SCHEDULE MAX AIRFLOW: 300 CFM  
GRILLE TOTAL: 525 CFM

Written By: Michael Gabbert on 01/13/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## FAN - Exhaust



Diffuser Ret/Exh (GRD)

### EF-12/FLR 2 RESTROOMS

Asset								
Asset Name	Location	Type	Size	DESIGN CFM	AK	CFM(1)	FINAL CFM	% to design
E12-1	299 JANITOR	E2	6	50				-
E12-2	232 GNR	E2	6	50				-
E12-3	231 GNR	E2	6	50				-
E12-4	230 GNR	E2	6	50				-
E12-5	229 GNR	E2	6	50				-
E12-6	235 GNSR	E2	6	100				-
E12-7	234 GNSR	E2	6	100				-
E12-8	228 WORK ROOM	E2	6	75				-
Total				525		0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: FAN - Exhaust

Asset: EF-13

AREA:000 ELEVATOR SHAFT

Unit Data		
	Design	Actual
MFG	GREENHECK	GREENHECK
Model Num	NA	G-095-VG
Serial Num	-	
Type	CRE DNBLAST	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	

Test Data		
	Design	Actual
CFM	270	
Motor Frequency	-	
System SetPt	-	
RL Voltage	115	
RL Amperage	2.20	
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.50	
Brake Horse Power	-	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: FAN - Exhaust

Asset: EF-14

AREA:FLR 2 RESTROOMS

Unit Data		
	Design	Actual
MFG	GREENHECK	GREENHECK
Model Num	NA	G-095-VG
Serial Num	-	
Type	CRE DNBLAST	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	

Test Data		
	Design	Actual
CFM	250	
Motor Frequency	-	
System SetPt	-	
RL Voltage	115	
RL Amperage	2.20	
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.50	
Brake Horse Power	-	

Notes:

EF-14  
SCHEDULE MAX AIRFLOW: 200 CFM  
GRILLE TOTAL: 250 CFM

Written By: Michael Gabbert on 01/13/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)

## FAN - Exhaust



Diffuser Ret/Exh (GRD)

### EF-14/FLR 2 RESTROOMS

Asset								
Asset Name	Location	Type	Size	DESIGN CFM	AK	CFM(1)	FINAL CFM	% to design
E14-1	272 ADA SHOWER	E2	8	100				-
E14-2	271 PLOTTING	E2	6	50				-
E14-3	273 WOMEN RR	E2	8	50				-
E14-4	274 MENS RR	E2	8	50				-
Total				250		0	0	0%

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: FAN - Exhaust

Asset: EF-15

AREA: WASH BAY

Unit Data		
	Design	Actual
MFG	GREENHECK	GREENHECK
Model Num	NA	G-180-VG
Serial Num	-	
Type	CRE DNBLAST	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	

Test Data		
	Design	Actual
CFM	2750	
Motor Frequency	-	
System SetPt	-	
RL Voltage	115	
RL Amperage	8.80	
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.25	
Brake Horse Power	-	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: FAN - Exhaust

Asset: EF-16

AREA: WASH BAY

Unit Data		
	Design	Actual
MFG	GREENHECK	GREENHECK
Model Num	NA	G-180-VG
Serial Num	-	
Type	CRE DNBLAST	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	

Test Data		
	Design	Actual
CFM	2750	
Motor Frequency	-	
System SetPt	-	
RL Voltage	115	
RL Amperage	8.80	
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.25	
Brake Horse Power	-	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: FAN - Exhaust

Asset: EF-17

AREA: WASH BAY

Unit Data		
	Design	Actual
MFG	GREENHECK	NA
Model Num	NA	NA
Serial Num	-	
Type	CRE DNBLAST	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	

Test Data		
	Design	Actual
CFM	2750	
Motor Frequency	-	
System SetPt	-	
RL Voltage	115	
RL Amperage	-	
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.25	
Brake Horse Power	-	

Notes:

PHASE 2 - NO SUBMITTAL

Written By: Michael Gabbert on 01/13/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: FAN - Exhaust

Asset: EF-18

AREA: WASH BAY

Unit Data		
	Design	Actual
MFG	GREENHECK	NA
Model Num	NA	NA
Serial Num	-	
Type	CRE DNBLAST	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	

Test Data		
	Design	Actual
CFM	2750	
Motor Frequency	-	
System SetPt	-	
RL Voltage	115	
RL Amperage	-	
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.25	
Brake Horse Power	-	

Notes:

PHASE 2 - NO SUBMITTAL

Written By: Michael Gabbert on 01/13/2026

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: FAN - Exhaust

Asset: EF-19

AREA:BRINE BUILDING

Unit Data		
	Design	Actual
MFG	GREENHECK	GREENHECK
Model Num	NA	G-180-VG
Serial Num	-	
Type	CRE DNBLAST	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage (rated)	-	
Amperage (rated)	-	
Service Factor	-	

Test Data		
	Design	Actual
CFM	2300	
Motor Frequency	-	
System SetPt	-	
RL Voltage	115	
RL Amperage	8.80	
Suction ESP	-	
Discharge ESP	-	
Total ESP	0.25	
Brake Horse Power	-	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Pump

Asset: P-1

AREA: WASH BAY

Unit Data		
	Design	Actual
MFG	NA	NA
Model Num	NA	NA
Serial Num	-	
Service	-	HOT WATER
Type	-	
Configuration	-	
Pump RPM	-	
GPM/HD	25.0 / 50.0	
Impeller Diameter	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage	-	
Amperage	-	
Service Factor	-	
Efficiency	-	
Power Factor	-	

Test Data		
	Design	Actual
Pump Off Pres	-	
Pump Dead Head Pres	-	
Act Impeller Dia (IN)	-	
Valve Open GPM	-	
Valve Open Diff (FT)	-	
Final Suction Pres (FT)	-	
Final Discharge Pres (FT)	-	
Total Head Pres (FT)	50.0	
Final GPM	25.0	
Pump Rotation	-	
Motor RPM	-	
Pump RPM	-	
Motor Frequency	-	
System SetPt	-	
RL Voltage	208	
RL Amperage	-	
Brake Horse Power	-	

# National TAB

Project: Municipal Svcs Operations Campus PH1 MSO  
(Lawrence, MO)



## System/Unit: Pump

Asset: P-2

AREA: WASH BAY

Unit Data		
	Design	Actual
MFG	NA	NA
Model Num	NA	NA
Serial Num	-	
Service	-	HOT WATER
Type	-	
Configuration	-	
Pump RPM	-	
GPM/HD	25.0 / 50.0	
Impeller Diameter	-	

Motor Data		
	Design	Actual
Motor MFG	-	
Frame	-	
Horsepower	-	
Motor Rpm	-	
Phase	-	
Voltage	-	
Amperage	-	
Service Factor	-	
Efficiency	-	
Power Factor	-	

Test Data		
	Design	Actual
Pump Off Pres	-	
Pump Dead Head Pres	-	
Act Impeller Dia (IN)	-	
Valve Open GPM	-	
Valve Open Diff (FT)	-	
Final Suction Pres (FT)	-	
Final Discharge Pres (FT)	-	
Total Head Pres (FT)	50.0	
Final GPM	25.0	
Pump Rotation	-	
Motor RPM	-	
Pump RPM	-	
Motor Frequency	-	
System SetPt	-	
RL Voltage	208	
RL Amperage	-	
Brake Horse Power	-	