

REFER TO CIVIL DNGS. FOR CONTINUATION

GENERAL STOCK

RTU-5
S 1600 CFM

PATIENT SEATING

PHARMACY

GENERAL SALES


ELECTRIC ROOM

WALK IN COOLER/FREEZER

TRAINING ROOM

OFFICE

PHOTO



NOTE: RTU-2 THERMOSTAT IN OFFICE TO BE CONTROLLER, BUT LEAVE SENSOR WIRING WITHIN THE THERMOSTAT PROVIDE 6" SPACE BETWEEN THERMOSTATS FOR SERVICE.

SENSOR FOR RTU-2 TO BE MOUNTED IN RETURN AIR DUCT (WIRED TO OFFICE T-STAT FOR FUTURE USE.)

KEYED NOTE VALUE (K) TYPICAL