



TYPE 'A' 14" NECK  
RE-BALANCE TO 450  
CFM RETURN AIR

F14-930 TRANSFER  
BALANCE NO  
BALANCING DAMPER

AIR CURTAIN BEYOND WALL SWITCHES BY MECHANICAL. REFER  
TO AIR DOOR SCHEDULE AND AIR CURTAIN WIRING DIAGRAM  
FOR FURTHER INFORMATION. COORDINATE EXACT LOCATION  
FOR SWITCHES WITH KITCHEN EQUIPMENT AND PLANS.

NEW AIR CURTAIN ACHU MOUNTED IN CEILING 9'60"  
CENTERED ON THE DOOR AT 4" OFF THE EXTERIOR  
WALL. MECHANICAL CONTRACTOR SHALL ADJUST  
AIR DEFLECTORS TOWARD AIR DIVERTER BOX

NEW HOODHILL  
18"X18" UP @

NEW HOODHILL  
9"X9" UP @

EXISTING CONDITIONS SHOWN ARE FROM PREVIOUS DRAWINGS.  
MECHANICAL CONTRACTOR SHALL FIELD VERIFY EXACT  
LOCATIONS OF ALL DUCT AND DIFFUSERS. IF MAJOR DIFFERENCES  
OCCUR IN FIELD, CONTACT CHICK-FLEA CONSTRUCTION MANAGER

FIELD VERIFY EXISTING  
AIR DUCT NECK SIZE  
PRIOR TO ORDERING  
REPLACEMENT. TYPICAL