



### AIR BALANCE SCHEDULE

UNIT	AREA SERVED	HOOD ON OA		HOOD OFF OA		HOOD ON EXHAUST		HOOD OFF EXHAUST	
		DESIGN	ACTUAL	DESIGN	ACTUAL	DESIGN	ACTUAL	DESIGN	ACTUAL
RTU 1	SALES	800	871	350	342				
RTU-2	SALES	800	846	350	372				
RTU-3	BOH/KITCHEN	800	794	350	347				
EF-1	WOMEN'S RR					225	214	225	214
EF-2	MEN'S RR					525	432	525	432
EF-3	HOOD					1350	1422	0	0
<b>TOTALS</b>		<b>2400</b>	<b>2511</b>	<b>1050</b>	<b>1061</b>	<b>2100</b>	<b>2068</b>	<b>750</b>	<b>646</b>

### HOODS ON

#### NET AIRFLOW CALCULATION

TOTALS	DESIGN	ACTUAL
TOTAL OA	2400	2511
TOTAL EXHAUST	2100	2068
<b>NET AIRFLOW</b>	<b>300</b>	<b>443</b>

DOOR TESTED	BUILDING PRESSURE MEASUREMENTS
FRONT	0.022
SIDE	
REAR	
<b>AVERAGE</b>	<b>0.022</b>

### HOODS OFF

#### NET AIRFLOW CALCULATION

TOTALS	DESIGN	ACTUAL
TOTAL OA	1050	1061
TOTAL EXHAUST	750	646
<b>NET AIRFLOW</b>	<b>300</b>	<b>415</b>

DOOR TESTED	BUILDING PRESSURE MEASUREMENTS
FRONT	0.021
SIDE	
REAR	
<b>AVERAGE</b>	<b>0.021</b>

NOTES: