

Issue List

- RTU3 LOW AIR FLOW, LOUD NOISE



12-29-25 QT #1415 PHOENIX, AZ

Project Issue Information

Issue Name : RTU3 LOW AIR FLOW, LOUD NOISE
Description : Unit VFD won't stay at 38Hz unless put into LO/RE mode - even though it shows 38Hz, it was actually running at 33.62. Keeps reverting to 20.3 Hz if run w/o LO/RE. Unit is making a very loud noise. Cannot continue TAB.
Created By : National TAB **Assigned To :** National TAB - Dan Hertenstein
Status : Open
Priority : Urgent **Asset Tag :** RT-3
Originated Date : 01/02/2026 - Christine Weale - National TAB