



KEY NOTES: DMA/01

- PROVIDE FIRE RATED DAMPERS FOR ALL BRANCH DUCTWORK SERVING DEFENSES AND GRILLES.
- PROVIDE CABLE OPERATED DAMPERS IN INACCESSIBLE CEILINGS.

CONTRACTOR TO INSTALL (6) FIRE-RATED DAMPERS (FIELD W/ OWNER)

CONTRACTOR TO INSTALL (6) FIRE-RATED DAMPERS (FIELD W/ OWNER)

GAS RADIANT HEATER (SEE MECHANICAL SCHEDULE FOR ELECTRICAL AND GAS CONNECTIONS)

← BANK/ALLUO → BANK/RELATIVA →