

EXISTING 10 HD-REMAIN

RECOMMENDED AIR DEVICE LOCATIONS SHOULD BE VALIDATED IN FIELD WITH GC/MC BASED UPON FINAL WALL LOCATION & LIGHTING PLAN

NEW FRY HOOD

Any diffusers next to hoods to be perforated or directional so it does not direct airflow directly on the hood(s)

DIFFUSERS SHALL BE EQUAL TO EGGER MODEL EA306H 2MT, 24 X 24 SQUARE FACE, PATTERN AS INDICATED ON THE PLANS, 4 ROUND NECKS SIZED AS FOLLOWS:

NECK SIZE → **D 3/2** → CFM

A - 6 1/2" NECK  
 B - 8" NECK  
 C - 10" NECK  
 D - 12" NECK  
 E - 14" NECK  
 F - 16" NECK

DIFFUSERS SHALL BE EQUAL TO EGGER MODEL EA306H 2MT, 24 X 24 SQUARE FACE, PATTERN AS INDICATED ON THE PLANS, 4 ROUND NECKS SIZED AS FOLLOWS:

NECK SIZE → **F 6/20** → CFM

G - 16" NECK  
 H - 18" NECK

RETURN GRILLES SHALL BE 24x24 EQUAL TO EGGER EACRFORM-375 PERFORATED GRILLE WITH ROUND NECK, SIZED AS FOLLOWS:

GRILLE SIZE → **X 1**

Y - 10" NECK  
 X - 18" NECK

ALL DIFFUSERS ARE EGGER ADVANTAGE PLASTIC AND SHALL BE FURNISHED WITH INSULATING BACKS.


RECOMMEND HAVING ALL CEILING TILES ABOVE FREEZER & COOLER TO BE INSTALLED SO RTU DOES NOT PULL FROM CEILING.

NOTE: CONFIRM ALL SUPPLY & EXHAUST DUCT LOCATION AND SIZING WITH HOOD MANUFACTURER'S DRAWINGS

LOCATE THERMOSTATS IN OFFICE WITH REMOTE SENSORS AS INDICATED.


CONFERENCE / MEETING ROOM (SEPERATE FROM RESTAURANT)

HVAC PLAN  
SCALE: 1/4" = 1'-0"



A NEW BUILDING FOR  
**LAROSA'S PIZZERIA**  
 2216 LANTERN RIDGE DRIVE  
 RICHMOND, KY 40475  
 MADISON COUNTY

Pursuant to section 102 of the copyright act, 17 U.S.C., all concepts, ideas, designs, arrangements, drawings, and plans are the property of Million Architecture, PLLC (MA) and are copyrighted by MA, as such all concepts, ideas, designs, arrangements, drawings, and plans developed for it are the property of MA and were created, revised and developed for it and shall be used by or reproduced in any form without the written permission of MA. Reproduction hereof is a criminal offense under 17 U.S.C. sec. 506. Unauthorized disclosure or violation of 17 U.S.C. 2-31-71 et. seq. and other laws.



**ENGINEERING & DESIGN, PLLC**  
 PO Box 213 (Mailing) Phone (606)-364-2886  
 4236 HWY 3630 Fax (606)-364-5100  
 Annville, KY 40402 E-Mail: eric@enrngineers.com  
 Web Address: enrngineers.com

THE ELECTRICAL MECHANICAL PLUMBING, STRUCTURAL AND GENERAL CONTRACTORS SHALL COORDINATE THEIR WORK IN REGARDS TO ROUTING OF THEIR TRADES PIPING, CONDUIT, DUCTWORK, ETC. AND MAKE THE ARCHITECT/ENGINEER AWARE OF ANY CONFLICTS PRIOR TO FABRICATING OR INSTALLING ANY WORK.

ALL INSTALLATION SHALL BE ACCOMPLISHED IN A WORKMAN LIKE MANNER AND APPEARANCE.

Job No.	07/24/2019
Drawn by	EE
Checked by	EE
Revised by	EE
Date / Revision	01 / 12/17/19 / 011 REVISIONS
By	02 / 12/16/19 / 020 ALTERNATE
By	04 / 04/26/20 / 04021 CHANGES

M1.1



