

EXISTING 10 HD-REMAIN



RECOMMENDED AIR DEVICE LOCATIONS SHOULD BE VALIDATED IN FIELD WITH GC/ MC BASED UPON FINAL WALL LOCATION & LIGHTING PLAN

NEW FRY HOOD

Any diffusers next to hoods to be perforated or directional so it does not direct airflow directly on the hood(s)

CONFERENCE / MEETING ROOM (SEPERATE FROM RESTAURANT)

HVAC PLAN SCALE: 1/4" = 1'-0"