



Comfort. Under control.

01-23-23 NVA #283 - VINTON, VA

Project Issue Information

Issue Name : EF-3 NOT WORKING

Description : High/low was switch burnt out due to accidental wiring during installation replacement was ordered.

Created By : National TAB

Assigned To : National TAB - Andrew Loignon

Status : Open

Originated Date : 01/24/2023 - Andrew Loignon - National TAB

Project Issue File Details



EF-3.jpeg