


E5 HVAC PLAN
SCALE: 1/4" = 1'-0"



NOTE: ALL DUCTWORK TO BE LOCATED IN TRUSS SPACE WHERE POSSIBLE. SEE FRAMING PLAN.

HVAC SETTINGS RECOMMENDED BY CORPORATE OPERATIONAL GUIDELINES:
 1. LIVING: HEATING 70°, COOLING 72°
 2. KITCHEN: HEATING 68°, COOLING 74°

ALL MECHANICAL ROOF EQUIPMENT REQUIRE STRAPS TO RESIST THE WIND PRESSURES DETERMINED IN ACCORDANCE WITH THE FLORIDA BUILDING CODE. BUILDING: SEE STRUCTURAL PLANS FOR SPECIFICATIONS.