

## Issue List

- CAS Startup
- RTU-1 Disconnect
- RTU-2 Contactor Buzzing



## Wingstop (Redding, CA)

### Project Issue Information

**Issue Name :** CAS Startup  
**Description :** CAS startup not completed. Electrical connections still to be made in MAU.  
**Created By :** National TAB                      **Assigned To :** National TAB - Zack Eismin  
**Status :** Open  
**Priority :** [Medium](#)                      **Asset Tag :**  
**Originated Date :** 06/10/2024 - Jordan Best - National TAB



## Wingstop (Redding, CA)

### Project Issue Information

**Issue Name :** RTU-1 Disconnect  
**Description :** RTU-1 not equipped with disconnect at unit.  
**Created By :** National TAB                      **Assigned To :** National TAB - Zack Eismin  
**Status :** Open  
**Priority :** [Medium](#)                                      **Asset Tag :**  
**Originated Date :** 06/10/2024 - Jordan Best - National TAB



## Wingstop (Redding, CA)

### Project Issue Information

**Issue Name :** RTU-2 Contactor Buzzing  
**Description :** Contactor for condenser buzzes loudly when in cooling.  
**Created By :** National TAB                      **Assigned To :** National TAB - Zack Eismin  
**Status :** Open  
**Priority :** [Medium](#)                                      **Asset Tag :**  
**Originated Date :** 06/10/2024 - Jordan Best - National TAB