



ON WALL PER MANUFACTURERS RECOMMENDATIONS.

MOUNT AIR DOOR IN CEILING CENTERED ON DRIVE THRU DOOR OPENING, AND 4" OFF THE WALL. PROVIDE WITH CFA DIVERTER BOX, DIVERTER BOX AND AIR DOOR PROVIDED BY TOM BARROW COMPANY.

MR
LIP
PC

CEILING MOUNTED RECIRCULATING FAN ROUTE 12" DUCT AND DISCHARGE AT TYPE 'A' DIFFUSER IN TEAM ROOM AS SHOWN.

MOUNT BOTTOM OF FRAME OF GRILLES AT 10'-8" AFF IN PLAY AREA.

COOLER

FREEZER