



A MECHANICAL PLAN
SCALE: 1/4" = 1'-0"



SPECIFICATION SECTION 230593 TESTING, ADJUSTING, AND BALANCE REQUIRES AN INDEPENDENT TAB CONTRACTOR (NEBB OR AABC) TO TEST ALL EQUIPMENT TO ENSURE COMPLIANCE WITH DRAWINGS. OWNER'S REPRESENTATIVE SHALL RECEIVE REPORT / VERIFICATION.

NOTE:
PROVIDE SHORT RADIUS ELBOW (1 TIMES CENTERLINE 9" FOR ELBOW DOWN TO 12" ON EXPOSED DUCTWORK IN DINING ROOM. DIFFUSERS BE MINIMUM OF 9'-0" AND DETAIL.

NOTE:
REMOTE SENSORS WIRE TO THERMOSTAT. HUMIDITY SENSORS WIRE UP TO THE PRODIGY CONTROL PANEL. REFER TO HUMIDITY SENSOR INSTALLATION IN THE PRODIGY CONTROL PANEL FOR HUMIDITY LEVEL IS CONTROL ON THE PRODIGY CONTROL PANEL. CONTACT NA TECH GROUP AT 1-800-367-6285 FOR QUESTIONS.

NOTE:
RESTAURANT TECHNOLOGIES INC. TO PROVIDE AUTOMIST GREASE DUCT / HOOD CLEANING SYSTEM PANEL.

MECHANICAL LEGEND

MISC. SYMBOLS:

