

Issue List

- EF-1 NOT OPERATIONAL
- K-EF GREASE CUPS NOT INSTALLED
- KEF-1 LOW AIRFLOW
- SMART THERMOSTATS NOT INSTALLED



06-23-25 WHATABURGER #1586 INDIAN LAND, SC

Project Issue Information

Issue Name : EF-1 NOT OPERATIONAL
Description : When I arrived on site EF-1 was inoperable. Superintendent and electrical were notified. The problem was fixed.
Created By : National TAB **Assigned To :** National TAB - Brianna Biggs
Status : Closed
Priority : Urgent **Asset Tag :**
Originated Date : 06/25/2025 - Chistian Moller - National TAB



06-23-25 WHATABURGER #1586 INDIAN LAND, SC

Project Issue Information

Issue Name : K-EF GREASE CUPS NOT INSTALLED
Description : NEITHER GREASE CUP FOR KEF-1 AND 2 ARE INSTALLED. RECOMMEND INSTALLING IMMEDIATELY.
Created By : National TAB **Assigned To :** National TAB - Brianna Biggs
Status : Open
Priority : Urgent **Asset Tag :**
Originated Date : 06/25/2025 - Chistian Moller - National TAB

Project Issue File Details



06/25/2025



06/25/2025



06-23-25 WHATABURGER #1586 INDIAN LAND, SC

Project Issue Information

Issue Name : KEF-1 LOW AIRFLOW
Description : KEF-1 IS RUNNING AT FULL CAPACITY AND NEAR FULL LOAD AMPS YET IS UNDER DESIGN AIRFLOW. ROTATION, AMPS, AND PRESSURE (0.64" ACTUAL VS. 1.0" DESIGN) WERE CHECKED TO CONFIRM AND FLOW WAS TAKEN TWICE.
Created By : National TAB **Assigned To :** National TAB - Brianna Biggs
Status : Open
Priority : Urgent **Asset Tag :** KEF1
Originated Date : 06/23/2025 - Chistian Moller - National TAB



06-23-25 WHATABURGER #1586 INDIAN LAND, SC

Project Issue Information

Issue Name : SMART THERMOSTATS NOT INSTALLED
Description : THE SMART THERMOSTATS CONTROLLING THE UNITS TEMPERATURES WERE NOT INSTALLED BY THE TIME I LEFT THE SITE.
Created By : National TAB **Assigned To :** National TAB - Brianna Biggs
Status : Open
Priority : InfoOnly **Asset Tag :**
Originated Date : 06/25/2025 - Chistian Moller - National TAB