



MECHANICAL PLAN

- EXISTING EXHAUST FAN** / EXHAUST AIR GRILLE TO REMAIN AND BE REUSED. MECHANICAL CONTRACTOR SHALL REFURBISH TO PROPER WORKING CONDITIONS. ENSURE EXHAUST FAN / GRILLE IS SET TO SUPPLY A **MINIMUM 70 CFM EXHAUST AIR**. RE-BALANCE AS REQUIRED.