



### AIR BALANCE SCHEDULE

UNIT	AREA SERVED	HOOD ON OA		HOOD OFF OA		HOOD ON EXHAUST		HOOD OFF EXHAUST	
		DESIGN	ACTUAL	DESIGN	ACTUAL	DESIGN	ACTUAL	DESIGN	ACTUAL
RTU 1	SALES	800	813	350	359				
RTU-2	SALES	800	842	350	340				
RTU-3	BOH/KITCHEN	800	775	350	361				
EF-1	WOMEN'S RR					225	0	225	0
EF-2	MEN'S RR					525	367	525	367
EF-3	HOOD					1350	1335	0	0
<b>TOTALS</b>		<b>2400</b>	<b>2430</b>	<b>1050</b>	<b>1060</b>	<b>2100</b>	<b>1702</b>	<b>750</b>	<b>367</b>

### HOODS ON

#### NET AIRFLOW CALCULATION

TOTALS	DESIGN	ACTUAL
TOTAL OA	2400	2430
TOTAL EXHAUST	2100	1702
<b>NET AIRFLOW</b>	<b>300</b>	<b>728</b>

DOOR TESTED	BUILDING PRESSURE MEASUREMENTS
FRONT	0.026
SIDE	
REAR	0.023
<b>AVERAGE</b>	<b>0.0245</b>

### HOODS OFF

#### NET AIRFLOW CALCULATION

TOTALS	DESIGN	ACTUAL
TOTAL OA	1050	1060
TOTAL EXHAUST	750	367
<b>NET AIRFLOW</b>	<b>300</b>	<b>693</b>

DOOR TESTED	BUILDING PRESSURE MEASUREMENTS
FRONT	
SIDE	
REAR	
<b>AVERAGE</b>	

NOTES: