



5. Duct up for transition to RTU. Have an integral smoke detector to RTU-1 open.
6. Duct up from building supply connection in roof curb.
7. Duct up from building supply connection in roof curb.
8. Duct up through roof. Transit in roof curb.
9. Duct up from hood through in radius elbows with an inside view.
10. Duct up through roof to EF-2. Have an integral smoke detector to RTU-1 open.
11. 16" duct down to makeup a plenum opening size. Typical.
12. 8" dia. duct down to A/C PSF opening size. Typical. Cap up.
13. Install GridPoint thermostats location at 48" AFF. Coordinate wiring as shown in detail 8/E/10.
14. Install GridPoint zone sensor location 72" AFF directly to view equipment. Provide wiring as shown in detail 8/E/10.
15. Install GridPoint zone sensor location 66" AFF directly to view equipment. Provide wiring as shown in detail 8/E/10.
16. Install GridPoint supply probe ductwork upstream from the hood. Provide wiring as shown in detail 8/E/10.
17. Install GridPoint supply probe ductwork upstream from the hood. Provide wiring as shown in detail 8/E/10.
18. Install remote temperature sensor location with equipment. Provide wiring as shown in detail 8/E/10.
19. Install kitchen hood, HD-1. See instructions and as detailed in detail 8/E/10. Coordinate with the NEPA 96, the building code, have an integral duct collar for exhaust and makeup air fans duct system to be welded or brazed. Provide an integral Chipotle will provide an integral grease duct system.
20. Install remote condensing unit expansion valve, solenoid valve, pressure control, low ambient slope refrigerant lines per manufacturer's instructions through roof. In detail 15. Install the remote condenser. If the view conceal within a stable drawings.
21. Install remote condenser for architectural and structural details. Coordinate with the NEPA 96, the building code, have an integral duct collar for exhaust and makeup air fans duct system to be welded or brazed. Provide an integral Chipotle will provide an integral grease duct system.
22. Install rooftop equipment per detail in the architectural drawings.
23. Install Exhaust fan EF-1 per architectural drawings. Install Chipotle on exhaust fan. EF-1.
24. Provide supply diffuser connection in roof curb.
25. Provide audio/visual remote operated reset. Wire a unit box. Typical.
26. Install REME HALO air purifier. See electrical drawings for purifier stickers on face of enclosure through which the REME HALO air purifier is installed.
27. Maintain 10" clearance between intakes. Maintain 10" clearance and exhaust fan discharges. See water heater, flue and combustion drawings.
28. Adjust supply registers so that they are approximately 7" AFF with no