

Report By:

National TAB
1329 E. KEMPER ROAD
SUITE 4210
CINCINNATI, OH 45246



Report: ISSUE REPORT
Function: Test, Adjust, & Balance
Date: 03/11/2024

PROJECT
03-11-24 CULVERS MISHAWAKA, IN

12571 Mckinkey Hwy

Mishawaka, IN 46545

Client

Captive-Aire Region #60

Issue List

- DOAS RTUS: NOT OPERATIONAL



03-11-24 CULVERS MISHAWAKA, IN

Project Issue Information

Issue Name : DOAS RTUS: NOT OPERATIONAL
Description : DOAS RTUS ARE NOT OPERATIONAL. MAIN BOARDS ARE NOT POWERED. DIAGNOSED WITH CAS; TR-05, WHICH POWERS THE BOARD, HAS INCOMING VOLTAGE, BUT NO OUTPUT. TRANSFORMERS NEED REPLACEMENT. CONTACT CAPTIVE AIRE FOR SPECIFIC DETAILS.

Created By : National TAB **Assigned To :** National TAB - Michael McDonnell

Status : Open

Priority : Urgent **Asset Tag :**

Originated Date : 03/11/2024 - Michael McDonnell - National TAB