

Issue List

- DOAS RTUS: NOT OPERATIONAL



03-11-24 CULVERS MISHAWAKA, IN

Project Issue Information

Issue Name : DOAS RTUS: NOT OPERATIONAL
Description : DOAS RTUS ARE NOT OPERATIONAL. MAIN BOARDS ARE NOT POWERED. DIAGNOSED WITH CAS; TR-05, WHICH POWERS THE BOARD, HAS INCOMING VOLTAGE, BUT NO OUTPUT. TRANSFORMERS NEED REPLACEMENT. CONTACT CAPTIVE AIRE FOR SPECIFIC DETAILS.
Created By : National TAB **Assigned To :** National TAB - Michael McDonnell
Status : Open
Priority : Urgent **Asset Tag :**
Originated Date : 03/11/2024 - Michael McDonnell - National TAB