

TAB Punch List 05788

Prepared by Will Turnbough

Jun 16, 2025

Description

1 task in this report.

#48 [REFG 506] [NEW] WIF door sweep vs threshold.

Status

Open

Assignees

mhrdlicka@jefoster.com

Type

Planned Work

Watchers

mhrdlicka@jefoster.com

Description

WIF door sweep is not sealed tightly with threshold when door is closed. No light should be present inspecting from the inside out with box lights off.

Start Date

Oct 10, 2024

Created

Oct 14, 2024 8:49 AM
jacobd@nationaltab.com

Last Updated

Jun 16, 2025 11:18 AM

Comments

NOT CORRECTED

Jacob Davidson Apr 14, 2025

Photos

IMG_1557
Jacob Davidson
Apr 14, 2025 9:12 PM



IMG_9470
Jacob Davidson
Oct 14, 2024 8:52 AM