

AC3



AC2



AC1



AC3



EF3



AC3



AC2



AC1




EF1



HOOD3



HOOD1R



HOOD3



HOOD1L



HOOD1L



HOOD2



HOOD1L/HOOD1R




# HOOD2




# HOOD3



# EF/ STICKER



# AC/STICKER



AC1



AC1

Cat. No.: DE929 LGH20040H Y  
 Base Material: LGH2004 PKG LGH2004... PkgGE/05T

Revision Level: 4

Characteristics Values

Package Unit Product: Emergence  
 Package Unit Generation: 1st Generation  
 Package Unit Cabinet: C Cabinet  
 Package Unit Type: Gas Package Unit  
 Package Unit Tonnage: 25.0  
 Package Unit Efficiency: Standard Efficiency  
 Package Unit Refrigerant: R-410A  
 Package Unit Cabinet Height: Standard  
 Length: Package Unit Cabinet Standard Length  
 Door Type: Hinged Doors  
 Unit Orientation: Downflow  
 Unit Voltage: 208-230 Volt/3 Ph  
 Air Filter Type: 2" Pleat MERV8 - Filter  
 Supply Fan Type: Constant Volume  
 Unit Supply Fan Drive Type: Belt Drive  
 Belt Drive: Blower Motor  
 10 Hp Std. Blower Drive Kit  
 Drive Kit 7 (C Cabinet) Gas Heating  
 400K A.S. (Dual Stage) Outdoor Air Supply  
 Dual Enth. Economizer (Fac)  
 High Performance Economizer  
 Factory Installed Unit Exhaust  
 Std Static PEF (Fac) Coil System  
 Tube and Fin Coil System Humidifrol  
 Factory Installed Return Air Smoke  
 Detector Factory Installed  
 Phase Monitor Factory Installed  
 Blower Belt Auto Tensioner Factory Installed  
 Factory Installed Drain Pan Overflow  
 Switch Factory Installed  
 GFCI Factory Installed/Unit  
 Powered Disconnect  
 250 Fresh Air Tempering Kit  
 Factory Installed Blower Motor System  
 Standard Cap Crating  
 Wiring Blower Motor System System J1

AC2

Cat. No.: DZ172 LGH21040H Y  
 Base Material: LGH2104-PKG LGH2104... PkgGE/17...

Revision Level: 3

Characteristics Values

Package Unit Product: Emergence  
 Package Unit Generation: 1st Generation  
 Package Unit Cabinet: C Cabinet  
 Package Unit Type: Gas Package Unit  
 Package Unit Tonnage: 17.5  
 Package Unit Efficiency: High Efficiency  
 Package Unit Refrigerant: R-410A  
 Package Unit Cabinet Height: Standard  
 Length: Package Unit Cabinet Standard Length  
 Door Type: Hinged Doors  
 Unit Orientation: Downflow  
 Unit Voltage: 208-230 Volt/3 Ph  
 Air Filter Type: 2" Pleat MERV8 - Filter  
 Supply Fan Type: Constant Volume  
 Unit Supply Fan Drive Type: Belt Drive  
 Belt Drive: Blower Motor  
 5 Hp Std. Blower Drive Kit  
 Drive Kit 3 (C Cabinet) Gas Heating  
 400K A.S. (Dual Stage) Outdoor Air Supply  
 Dual Enth. Economizer (Fac)  
 High Performance Economizer  
 Factory Installed Unit Exhaust  
 Std Static PEF (Fac) Coil System  
 Tube and Fin Coil System Humidifrol  
 Factory Installed Return Air Smoke  
 Detector Factory Installed  
 Phase Monitor Factory Installed  
 Blower Belt Auto Tensioner Factory Installed  
 Factory Installed Drain Pan Overflow  
 Switch Factory Installed  
 GFCI Factory Installed/Unit  
 Powered Disconnect  
 150 Fresh Air Tempering Kit  
 Factory Installed Blower Motor System  
 Standard Cap Crating

AC/ STICKER

AC3

**NATIONAL TAB**

PHONE (855) 682 - 6822

BLOWER RPM / MSAV HI 745

MOTOR RPM / MSAV LOW 1765

L1 AMPS 7.7

L2 AMPS 7.2

L3 AMPS 7.3

O/A MIN SET POINT 35.8


FINAL TENSIONER TICK MARK 3<sup>rd</sup>

BELT SIZE 5VX660


DATE 9/22/22

TECH: DALE (PRINT NAME)

# AC3



# EF/ STICKER



# EF2



# EF1



AC2




STORE FRONT



HOOD1R




HOOD2




MARKED DAMPER



EF2



R1/R2/R3 RELAYS



R6 RELAY

