

Report By:

**National TAB
1329 E. KEMPER ROAD
SUITE 4210
CINCINNATI, OH 45246**



**Report: test one1
Function: Test, Adjust, & Balance
Date: 11/03/2022**

**PROJECT
DAYTON CHILDREN'S HOSPITAL (DAYTON,
OH)**

1 Childrens Plaza

Dayton, OH 45404

Client

Cinfab, LLC
5240 Lester Road
Cincinnati, OH 45213

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)

Table Of Contents

Section	Page #
Boiler	3
Chiller	6

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)

System/Unit: Boiler



Comfort. Under control.

Asset: BLR-26

AREA:PENTHOUSE

Unit Data		
	Design	Actual
MFG	NA	LOCHINVAR
Model Num	NA	FBN0751
Serial Num	-	2142 126561835

Test Data		
	Design	Actual
GPM	-	35
Hot Water Delta P	-	

Completed By: Michael Gabbert

Notes:

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)

System/Unit: Boiler



Comfort. Under control.

Asset: BLR-27

AREA:PENTHOUSE

Unit Data		
	Design	Actual
MFG	NA	LOCHINVAR
Model Num	NA	FBN1001
Serial Num	-	2142 126561833

Test Data		
	Design	Actual
GPM	-	70
Hot Water Delta P	-	

Completed By: Michael Gabbert

Notes:

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)

System/Unit: Boiler



Comfort. Under control.

Asset: BLR-28

AREA:PENTHOUSE

Unit Data		
	Design	Actual
MFG	NA	LOCHINVAR
Model Num	NA	FBN1001
Serial Num	-	2142 126561834

Test Data		
	Design	Actual
GPM	-	70
Hot Water Delta P	-	

Completed By: Michael Gabbert

Notes:

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)

System/Unit: Chiller



Comfort. Under control.

Asset: CH-11

AREA:ROOF

Unit Data		
	Design	Actual
MFG	NA	YORK
Model Num	NA	YVAA0308EVB46BAVB
Serial Num	-	11552N13694871
Type	SCREW	CHILLER

Test Data-Evaporator		
	Design	Actual
GPM	-	502
LWT (F)	-	42.0
CHW Delta P	-	21.9

Completed By: Michael Gabbert

Notes:

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)

System/Unit: Chiller



Comfort. Under control.

Asset: CH-12

AREA:ROOF

Unit Data		
	Design	Actual
MFG	NA	YORK
Model Num	NA	YVAA0308EUV46BAVB
Serial Num	-	11552N13694870
Type	SCREW	

Test Data-Evaporator		
	Design	Actual
GPM	-	502
LWT (F)	-	42.0
CHW Delta P	-	21.9

Completed By: Michael Gabbert

Notes: