

Report By:

**National TAB
1329 E. KEMPER ROAD
SUITE 4210
CINCINNATI, OH 45246**



**Report: test_1
Function: Test, Adjust, & Balance
Date: 06/07/2023**

PROJECT

Dayton Children's Hospital (Dayton, OH)

1 Childrens Plaza

Dayton, OH 45404

Client

Cinfab, LLC
5240 Lester Road
Cincinnati, OH 45213

National TAB

Project: Dayton Children's Hospital (Dayton, OH)

Table Of Contents

Section	Page #
Boiler	3
Chiller	6

National TAB

Project: Dayton Children's Hospital (Dayton, OH)

System/Unit: Boiler



Comfort. Under control.

Asset: BLR-26

AREA:PENTHOUSE

Unit Data		
	Design	Actual
MFG	NA	LOCHINVAR
Model Num	NA	FBN0751
Serial Num	-	2142 126561835

Test Data		
	Design	Actual
GPM	-	37.8

Completed By: Nick Payne on 12/23/2022

Notes: DESIGN GPM 35

Date: 01/13/2023

National TAB

Project: Dayton Children's Hospital (Dayton, OH)

System/Unit: Boiler



Comfort. Under control.

Asset: BLR-27

AREA:PENTHOUSE

Unit Data

	Design	Actual
MFG	NA	LOCHINVAR
Model Num	NA	FBN1001
Serial Num	-	2142 126561833

Test Data

	Design	Actual
GPM	-	68.2

Completed By: Nick Payne on 12/23/2022

Notes: DESIGN GPM 70

Date: 01/13/2023

National TAB

Project: Dayton Children's Hospital (Dayton, OH)

System/Unit: Boiler



Comfort. Under control.

Asset: BLR-28

AREA:PENTHOUSE

Unit Data

	Design	Actual
MFG	NA	LOCHINVAR
Model Num	NA	FBN1001
Serial Num	-	2142 126561834

Test Data

	Design	Actual
GPM	-	71.5

Completed By: Nick Payne on 12/23/2022

Notes: DESIGN GPM 70

Date: 01/13/2023

National TAB

Project: Dayton Children's Hospital (Dayton, OH)

System/Unit: Chiller



Comfort. Under control.

Asset: CH-11

AREA:ROOF

Unit Data		
	Design	Actual
MFG	NA	YORK
Model Num	NA	YVAA0308EVB46BAVB
Serial Num	-	11552N13694871
Type	SCREW	CHILLER

Test Data-Evaporator		
	Design	Actual

Completed By: Nick Payne on 12/22/2022

Notes: No ports to sample pressure drop *

Date: 12/23/2022

National TAB

Project: Dayton Children's Hospital (Dayton, OH)

System/Unit: Chiller



Comfort. Under control.

Asset: CH-12

AREA:ROOF

Unit Data

	Design	Actual
MFG	NA	YORK
Model Num	NA	YVAA0308EVV46BAVB
Serial Num	-	11552N13694870
Type	SCREW	SCREW

Test Data-Evaporator

	Design	Actual
--	--------	--------

Completed By: Nick Payne on 12/23/2022

Notes: No ports to sample pressure drop *

Date: 12/23/2022