

**Report By:**

**National TAB  
1329 E. KEMPER ROAD  
SUITE 4210  
CINCINNATI, OH 45246**



**Report: test one1  
Function: Test, Adjust, & Balance  
Date: 11/03/2022**

**PROJECT  
DAYTON CHILDREN'S HOSPITAL (DAYTON,  
OH)**

1 Childrens Plaza

Dayton, OH 45404

**Client**

Cinfab, LLC

5240 Lester Road

Cincinnati, OH 45213

# National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)

## Table Of Contents

Section	Page #
Boiler	3
Chiller	6

# National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)

System/Unit: Boiler



Comfort. Under control.

Asset: BLR-26

AREA:PENTHOUSE

Unit Data		
	Design	Actual
<b>MFG</b>	NA	LOCHINVAR
<b>Model Num</b>	NA	FBN0751
<b>Serial Num</b>	-	2142 126561835

Test Data		
	Design	Actual
<b>GPM</b>	-	35
<b>Hot Water Delta P</b>	-	

Completed By: Michael Gabbert

Notes:

# National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)

## System/Unit: Boiler



Comfort. Under control.

Asset: BLR-27

AREA:PENTHOUSE

Unit Data		
	Design	Actual
MFG	NA	LOCHINVAR
Model Num	NA	FBN1001
Serial Num	-	2142 126561833

Test Data		
	Design	Actual
GPM	-	70
Hot Water Delta P	-	

Completed By: Michael Gabbert

Notes:

# National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)

## System/Unit: Boiler



Comfort. Under control.

Asset: BLR-28

AREA:PENTHOUSE

### Unit Data

	Design	Actual
MFG	NA	LOCHINVAR
Model Num	NA	FBN1001
Serial Num	-	2142 126561834

### Test Data

	Design	Actual
GPM	-	70
Hot Water Delta P	-	

Completed By: Michael Gabbert

Notes:

# National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)

System/Unit: Chiller



Comfort. Under control.

Asset: CH-11

AREA:ROOF

Unit Data		
	Design	Actual
<b>MFG</b>	NA	YORK
<b>Model Num</b>	NA	YVAA0308EVB46BAVB
<b>Serial Num</b>	-	11552N13694871
<b>Type</b>	SCREW	CHILLER

Test Data-Evaporator		
	Design	Actual
<b>GPM</b>	-	502
<b>LWT (F)</b>	-	42.0
<b>CHW Delta P</b>	-	21.9

Completed By: Michael Gabbert

Notes:

# National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)

System/Unit: Chiller



Comfort. Under control.

Asset: CH-12

AREA:ROOF

Unit Data		
	Design	Actual
MFG	NA	YORK
Model Num	NA	YVAA0308EVV46BAVB
Serial Num	-	11552N13694870
Type	SCREW	

Test Data-Evaporator		
	Design	Actual
GPM	-	502
LWT (F)	-	42.0
CHW Delta P	-	21.9

Completed By: Michael Gabbert

Notes: