

Report By:

National TAB
1329 E. KEMPER ROAD
SUITE 4210
CINCINNATI, OH 45246



Report: SG

Function: Test, Adjust, & Balance

Date: 09/15/2023

PROJECT

Dayton Children's Hospital (Dayton, OH)

1 Childrens Plaza

Dayton, OH 45404

Client

Cinfab, LLC

5240 Lester Road

Cincinnati, OH 45213

National TAB

Project: Dayton Children's Hospital (Dayton, OH)

Table Of Contents

Section	Page #
VAV - Single Duct	3



National TAB

Project: Dayton Children's Hospital (Dayton, OH)

VAV - Single Duct

AHU-64/ABC

Asset									
Asset Name	Type	Inlet Size	Design Max CFM	Max CFM	Design Min CFM	Min CFM	Design Heat CFM	Heat CFM	Ak (max)
64-1-09	VAV	6"	315	310	205	204	205	207	505.8

Completed By: Nick Payne on 11/07/2022