

Report By:

**National TAB
1329 E. KEMPER ROAD
SUITE 4210
CINCINNATI, OH 45246**



**Report: test one
Function: Test, Adjust, & Balance
Date: 11/03/2022**

**PROJECT
DAYTON CHILDREN'S HOSPITAL (DAYTON,
OH)**

1 Childrens Plaza

Dayton, OH 45404

Client

Cinfab, LLC

5240 Lester Road

Cincinnati, OH 45213

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)

Table Of Contents

Section	Page #
Diffuser Supply (GRD)	3

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-1-10/6-1115

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-1-10-1	6-1116	A1	6"	100	206	101	101.0
63-1-10-2	6-1116	A1	6"	80	127	76	95.0
63-1-10-3	6-1114	A1	6"	150	130	148	98.7
63-1-10-4	6-1116	A1	6"	100	148	92	92.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-1-11/6-1115

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-1-11-1	6-1115	A1	8"	200	232	197	98.5

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-1-12/6-1110

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-1-12-1	6-1111	A1	6"	120	238	115	95.8
63-1-12-2	6-1113	A1	6"	120	22	128	106.7

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-1-13/6-1100

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-1-13-1	6-1110	A1	6"	120	145	129	107.5
63-1-13-2	6-1112	A1	6"	120	123	116	96.7

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-1-14/6-1100

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-1-14-1	6-1100	A1	6"	150	242	152	101.3
63-1-14-2	HALL	A1	6"	115	90	109	94.8
63-1-14-3	6-1100	A1	6"	150	226	149	99.3
63-1-14-4	6-1116	A1	6"	115	224	116	100.9

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-1-15/6-1109

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-1-15-1	6-1108	A1	6"	120	150	119	99.2
63-1-15-2	6-1109	A1	6"	120	140	130	108.3

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-1-16/6-1118

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-1-16-1	6-1106	A1	6"	120	43	125	104.2
63-1-16-2	6-1107	A1	6"	120	285	127	105.8

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-1-17/6-1118

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-1-17-1	6-1118	A1	6"	90	117	96	106.7
63-1-17-2	6-1119	A1	6"	90	108	95	105.6

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-1-18/6-1121

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-1-18-1	6-1120	A1	6"	90	91	93	103.3
63-1-18-2	6-1121	A1	6"	90	107	87	96.7

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-1-19/6-1319

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
SGRD1	6-1122	A1	6"	90	134	88	97.8
SGRD2	6-1123	A1	6"	50	11	50	100.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-1-01/6-1512

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-1-01-1	6-1006-1	A1	6"	155	198	153	98.7
63-1-01-2	6-1006-1	A1	6"	155	224	151	97.4
63-1-01-3	6-1006-1	A1	6"	155	203	166	107.1
63-1-01-4	6-1200	A1	6"	155	219	160	103.2
63-1-01-5	6-1200	A1	6"	160	198	169	105.6

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-1-02/2ND FLR CONNECTOR

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-1-02-1	1ST FLR CONNECTOR	S1	8"	165			-
63-1-02-2	1ST FLR CONNECTOR	S1	8"	165			-
63-1-02-3	1ST FLR CONNECTOR	S1	8"	165			-
63-1-02-4	1ST FLR CONNECTOR	S1	8"	165			-
63-1-02-5	1ST FLR CONNECTOR	S1	8"	165			-
63-1-02-6	1ST FLR CONNECTOR	S1	8"	165			-
63-1-02-7	1ST FLR CONNECTOR	S1	8"	165			-
63-1-02-8	1ST FLR CONNECTOR	S1	8"	165			-
63-1-02-9	1ST FLR CONNECTOR	S1	8"	165			-
63-1-02-10	1ST FLR CONNECTOR	S1	8"	165			-
63-1-02-11	1ST FLR CONNECTOR	S1	8"	160			-
63-1-02-12	1ST FLR CONNECTOR	S1	8"	160			-
63-1-02-13	1ST FLR CONNECTOR	A1	8"	225			-
63-1-02-14	1ST FLR CONNECTOR	A1	8"	225			-

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-1-03/6-1510

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-1-03-1	6-1002	A1	8"	190	253	197	103.7
63-1-03-2	6-1002	A1	8"	180	220	175	97.2
63-1-03-3	6-1002	A1	8"	180	198	173	96.1
63-1-03-4	6-1002	A1	8"	180	184	185	102.8
63-1-03-5	6-1002	A1	8"	180	166	182	101.1
63-1-03-6	6-1002	S1	10"	200	199	175	87.5
63-1-03-7	6-1002	S1	10"	200	202	198	99.0
63-1-03-8	6-1002	S1	10"	200	153	206	103.0
63-1-03-9	6-1002	S1	10"	200	201	212	106.0
63-1-03-10	6-1002	S1	10"	200	239	198	99.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-1-04/6-1004

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-1-04-1	6-1510	A1	6"	75	163	76	101.3
63-1-04-2	6-1501	A1	6"	75	177	70	93.3
63-1-04-3	6-1507-1	A1	6"	100	177	101	101.0
63-1-04-4	6-1500	A1	8"	200	44	197	98.5
63-1-04-5	6-1500	S1	10"	200	281	206	103.0
63-1-04-6	6-1513	A1	6"	100	163	109	109.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-1-05/6-1101

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-1-05-1	6-1004	A1	6"	135	164	134	99.3
63-1-05-2	6-1004	A1	6"	135	174	130	96.3
63-1-05-3	6-1004	A1	6"	135	164	139	103.0
63-1-05-4	6-1004	A1	6"	135	160	145	107.4
63-1-05-5	6-1004	A2	6"	130	161	127	97.7
63-1-05-6	6-1003	A1	6"	50	102	51	102.0
63-1-05-7	6-1002	A1	6"	75	148	76	101.3

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-1-06/6-1102

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-1-06-1	6-1101	A1	6"	125	176	137	109.6
63-1-06-2	6-1101	A1	6"	125	143	122	97.6
63-1-06-3	6-1101	A1	6"	125	171	122	97.6
63-1-06-4	6-1102A	A2	6"	75	143	70	93.3

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-1-07/6-1102

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-1-07-1	6-1103	A1	6"	50	83	48	96.0
63-1-07-2	6-1102	A1	6"	90	90	96	106.7

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-1-08/6-1104

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-1-08-1	6-1104	A1	10"	300	361	303	101.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-1-09/6-1512

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-1-09-1	6-1511	A1	6"	125	124	114	91.2
63-1-09-2	6-1512	A1	6"	120	138	129	107.5

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-2-10/6-2106

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-2-10-1	6-2105	A1	8"	175	263	182	104.0
63-2-10-2	6-2105	A1	8"	175	245	164	93.7
63-2-10-3	6-2105	A1	8"	175	241	165	94.3
63-2-10-4	6-2105	A1	8"	185	279	180	97.3
63-2-10-5	6-2105	A1	8"	175	199	176	100.6

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-2-11/6-2005

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-2-11-1	6-2106	A1	8"	220	18	207	94.1
63-2-11-2	6-2106	S1	10"	220	233	226	102.7
63-2-11-3	6-2106	A1	8"	220	282	230	104.5
63-2-11-4	6-2501	A1	8"	220	265	235	106.8
63-2-11-5	6-2502	A1	6"	75	34	71	94.7
63-2-11-6	6-2501	S1	10"	220	363	207	94.1

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-2-12/6-2005

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-2-12-1	6-2005	S1	12"	245	274	264	107.8
63-2-12-2	6-2005	S1	12"	245	289	251	102.4
63-2-12-3	6-2005	S1	12"	245	224	233	95.1
63-2-12-4	6-2005	S1	12"	245	276	251	102.4
63-2-12-5	6-2005	S1	12"	245	237	239	97.6
63-2-12-6	6-2005	S1	12"	245	281	249	101.6
63-2-12-7	6-2005	S1	12"	245	246	247	100.8

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-2-13/6-1002

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-2-13-1	6-2004	A1	8"	300	305		-
63-2-13-2	6-2003	S3	12"	450	439		-
63-2-13-3	6-2003	S3	12"	450	450		-

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-2-14/6-2105 OFFICE

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-2-14-1	6-2002-1	A1	6"	145			-
63-2-14-2	6-2002-1	A1	6"	150			-
63-2-14-3	6-2002-1	A1	6"	150			-
63-2-14-4	6-2002-1	S2	12"	255			-
63-2-14-5	6-2002-1	S2	12"	255			-
63-2-14-6	6-2002-1	S2	12"	255			-
63-2-14-7	6-2002-1	S2	12"	255			-
63-2-14-8	6-2002-1	S2	12"	255			-
63-2-14-9	STAIRWELL	S2	12"	275			-
63-2-14-10	STAIRWELL	S2	12"	275			-
63-2-14-11	STAIRWELL	S2	12"	275			-
63-2-14-12	STAIRWELL	S2	12"	275			-
63-2-14-13	STAIRWELL	S2	12"	275			-
63-2-14-14	STAIRWELL	S2	12"	275			-
63-2-14-15	STAIRWELL	S2	12"	275			-

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-2-15/6-2105 OFFICE

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-2-15-1	6-2105 OFFICE	A1	6"	100	156	99	99.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-2-16/6-2103

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-2-16-1	2ND FLR CONNECTOR	S2	8"	165	107	167	101.2
63-2-16-2	2ND FLR CONNECTOR	S2	8"	165	146	174	105.5
63-2-16-3	2ND FLR CONNECTOR	S2	8"	165	121	160	97.0
63-2-16-4	2ND FLR CONNECTOR	S2	8"	165	117	162	98.2
63-2-16-5	2ND FLR CONNECTOR	S2	8"	165	141	172	104.2
63-2-16-6	2ND FLR CONNECTOR	S2	8"	165	120	171	103.6
63-2-16-7	2ND FLR CONNECTOR	S2	8"	165	88	163	98.8
63-2-16-8	2ND FLR CONNECTOR	S2	8"	165	109	166	100.6
63-2-16-9	2ND FLR CONNECTOR	S2	8"	165	127	175	106.1
63-2-16-10	2ND FLR CONNECTOR	S2	8"	165	127	169	102.4
63-2-16-11	2ND FLR CONNECTOR	S2	8"	160	107	158	98.8
63-2-16-12	2ND FLR CONNECTOR	S2	8"	160	115	164	102.5
63-2-16-13	2ND FLR CONNECTOR	A1	8"	225	119	204	90.7
63-2-16-14	2ND FLR CONNECTOR	A1	8"	225	138	235	104.4

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-2-17/6-2103

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-2-17-1	6-2103	A1	6"	150	163	150	100.0

National TAB

Project:DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-2-18/6-2205

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-2-18-1	6-2205	P1	10"	300			-

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-2-19/6-2215

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-2-19-1	6-2213	A1	8"	185	225	187	101.1
63-2-19-2	6-2213	A1	8"	185	220	180	97.3

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-2-20/6-2215

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-2-30-1	6-2215	A1	6"	100	117	103	103.0
63-2-30-2	6-2215	A1	6"	100	120	93	93.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-2-01/6-2008

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-2-01-1	6-2008	A1	6"	110	201	115	104.5
63-2-01-2	6-2200	A1	8"	225	44	226	100.4
63-2-01-3	6-2008	A1	6"	115	166	112	97.4
63-2-01-4	6-2009	A1	6"	200	204	211	105.5
63-2-01-5	6-2011	A2	6"	50	86	54	108.0
63-2-01-6	6-2008	A1	6"	115	40	121	105.2
63-2-01-7	6-2010	A2	6"	50	184	54	108.0
63-2-01-8	6-2008	A1	6"	115	195	109	94.8

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-2-02/6-2211

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-2-02-1	6-2203	A1	6"	100	152	108	108.0
63-2-02-2	6-2204	A1	6"	100	136	98	98.0
63-2-02-3	6-2210	A1	6"	100	145	101	101.0
63-2-02-4	6-2211	A1	6"	100	162	94	94.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-2-03/6-2212

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
SGRD1	6-2201-2	A1	6"	65	102	64	98.5
SGRD2	6-2201-2	A1	6"	65	74	59	90.8
SGRD3	6-2212	A1	8"	205	223	211	102.9
SGRD4	6-2212	A1	8"	205	241	199	97.1
SGRD5	6-2212	A1	8"	200	227	208	104.0
SGRD6	6-2202-2	A1	6"	65	103	64	98.5
SGRD7	6-2300-1	A1	6"	65	108	63	96.9

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-2-04/6-2001

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-2-04-1	6-2001	A1	10"	325			-
63-2-04-2	6-2001	A1	10"	325			-

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-2-05/6-2007

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-2-05-1	6-2007	S3	12"	320	356	313	97.8
63-2-05-2	6-2007	S3	12"	320	299	310	96.9
63-2-05-3	6-2007	S3	12"	320	316	332	103.8
63-2-05-4	6-2007	S3	12"	320	338	335	104.7

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-2-06/6-2100

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-2-06-1	6-2005	A1	6"	150	170	154	102.7
63-2-06-2	6-2006	A1	8"	185	164	188	101.6
63-2-06-3	6-2006	A1	8"	185	183	191	103.2
63-2-06-4	6-2006	A1	8"	185	187	187	101.1
63-2-06-5	6-2006			185	179	176	95.1
63-2-06-6	6-2007	A1	8"	185	204	169	91.4
63-2-06-7	6-2007	A1	8"	185	162	180	97.3
63-2-06-8	6-2107	A1	6"	105	90	106	101.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-2-07/6-2100

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-2-07-1	6-2002-1	A1	8"	220	60	224	101.8
63-2-07-2	6-2002-1	A1	8"	220	480	240	109.1
63-2-07-3	6-2002-1	A1	8"	220	480	214	97.3
63-2-07-4	HALL	A1	8"	220	34	205	93.2
63-2-07-5	6-2111	A1	6"	75	32	77	102.7
63-2-07-6	6-2112	A1	6"	150	50	137	91.3
63-2-07-7	6-2102	A1	6"	110	248	111	100.9
63-2-07-8	6-2100	A1	8"	170	469	186	109.4
63-2-07-9	6-2100	A1	8"	170	53	163	95.9

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-2-08/6-2206

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-2-08-1	6-2206	A1	6"	100	123	102	102.0
63-2-08-2	6-2207	A1	6"	100	128	104	104.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-2-09/6-2208

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-2-09-1	6-2208	A1	8"	175	99		-

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-3-10/6-3000-1

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-3-10-1	6-3000-1	A1	8"	160	227	165	103.1
63-3-10-2	6-3001	A2	6"	50	94	52	104.0
63-3-10-3	6-3000-1	A1	8"	160	164	170	106.3
63-3-10-4	6-3000-1	A1	8"	160	195	161	100.6

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-3-11/6-3205

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-3-11-1	6-3205	A1	10"	300	196	311	103.7
63-3-11-2	6-3205	A1	10"	300	250	309	103.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-3-12/6-3126

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-3-12-1	6-3206 OFFICE	A1	10"	300	323	308	102.7
63-3-12-2	6-3206 OFFICE	A1	10"	300	346	318	106.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-3-13/6-3203

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-3-13-1	6-3129	A1	6"	100	138	98	98.0
63-3-13-2	6-3131	A1	6"	100	145	95	95.0
63-3-13-3	6-3125	A1	6"	100	162	105	105.0
63-3-13-4	6-3126	A1	6"	100	140	101	101.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-3-14/6-3203

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-3-14-1	6-3133	A1	6"	120	141	123	102.5
63-3-14-2	6-3203	A1	6"	135	159	139	103.0
63-3-14-3	6-3202	A2	6"	45	71	49	108.9
63-3-14-4	6-3228	A1	6"	125	110	121	96.8

National TAB

Project:DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-3-15/6-3104

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-3-15-1	6-3104	A1	8"	200	244	195	97.5

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-3-16/6-3121

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-3-16-1	6-3121	A1	8"	170	223	178	104.7
63-3-16-2	6-3136	A1	6"	90	118	92	102.2
63-3-16-3	6-3135-1	A1	6"	90	120	98	108.9

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-3-17/6-3112

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-3-17-1	6-3113	A1	6"	100	143	106	106.0
63-3-17-2	6-3117	A1	6"	100	144	104	104.0
63-3-17-3	6-3112	A1	6"	100	156	101	101.0
63-3-17-4	6-3116	A1	6"	100	150	103	103.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-3-18/6-3114

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-3-18-1	6-3118	A1	6"	75	115	72	96.0
63-3-18-2	6-3137	A1	6"	125	250	130	104.0
63-3-18-3	6-3122	A1	6"	50	75	52	104.0
63-3-18-4	6-3127	A1	6"	50	66	54	108.0
63-3-18-5	6-3114	A1	6"	140	105	148	105.7
63-3-18-6	6-3135-A	A1	6"	110	112	108	98.2
63-3-18-7	6-3135-2	A1	6"	105	77	105	100.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-3-19/6-3123

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-3-19-1	6-3123	A1	8"	200	229	206	103.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-3-20/6-3505

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-3-20-1	6-3502	A2	6"	50	134	52	104.0
63-3-20-2	6-3503	A2	6"	50	102	54	108.0
63-3-20-3	6-3135-1	A1	8"	185	227	187	101.1
63-3-20-4	6-3505	A1	6"	120	118	126	105.0
63-3-20-5	6-3501	S1	10"	220	266	213	96.8
63-3-20-6	6-3501	A1	8"	180	293	184	102.2

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-3-21/6-3106

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-3-21-1	6-3105	A1	8"	275	315	269	97.8
63-3-21-2	6-3105	A1	8"	275	303	280	101.8

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-3-22/6-3106

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-3-22-1	6-3106	A1	10"	300	330	309	103.0
63-3-22-2	6-3107	A1	10"	300	316	299	99.7

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-3-23/6-3504

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-3-23-1	6-3504	A1	8"	165	225	170	103.0
63-3-23-2	6-3504	A1	8"	165	242	168	101.8
63-3-23-3	6-3504	S1	10"	165	265	172	104.2
63-3-23-4	6-3504	S1	10"	165	218	165	100.0
63-3-23-5	6-3504	S1	10"	165	240	177	107.3

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-3-24/6-3109

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-3-34-1	6-3108	A1	10"	300	326	308	102.7
63-3-34-2	6-3109	A1	10"	300	327	303	101.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-3-25/6-3110

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-3-251	6-3110	A1	12"	365	516	377	103.3

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-3-26/6-3115

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-3-26-1	6-3102	A1	6"	100	139	109	109.0
63-3-26-2	6-3119	A1	6"	100	134	106	106.0
63-3-26-3	6-3115	A1	6"	100	140	107	107.0
63-3-26-4	6-3111	A1	6"	100	146	102	102.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-3-27/6-3101

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-3-37-1	6-3128	A1	8"	170	258	172	101.2
63-3-37-2	6-3101	A1	8"	170	260	178	104.7
63-3-37-3	HALL	A1	6"	145	105	150	103.4

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-3-28/6-3120

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-3-28-1	6-3124	A1	6"	125	116	126	100.8
63-3-28-2	6-3120	A1	8"	170	147	188	110.6

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-3-29/6-3209

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-3-29-1	6-3209	A1	6"	125	145	130	104.0
63-3-29-2	6-3210	A1	6"	125	137	126	100.8

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-3-01/6-3103

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-3-01-1	6-3002	A1	8"	165	222	169	102.4
63-3-01-2	6-3201	A1	6"	115	0	122	106.1
63-3-01-3	6-3201	A1	6"	110	0	108	98.2
63-3-01-4	6-3200	A1	8"	165	267	175	106.1
63-3-01-5	6-3003	A2	6"	50	114	52	104.0
63-3-01-6	6-3200	A1	8"	165	283	180	109.1

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-3-02/6-3222

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-3-02-1	6-3103	A1	8"	200	256	207	103.5
63-3-02-2	6-3103	A1	8"	200	272	211	105.5
63-3-02-3	6-3103	A1	8"	200	247	205	102.5
63-3-02-4	6-3103	A1	8"	200	283	209	104.5

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-3-03/6-3222

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-3-03-1	6-3223	A1	10"	300	335	302	100.7
63-3-03-2	6-3223	A1	10"	300	362	308	102.7
63-3-03-3	6-3223	A1	10"	300	348	311	103.7

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-3-04/6-3206 HALL

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-3-04-1	6-3204	A1	6"	100	118	108	108.0
63-3-04-2	6-3214	A1	6"	100	112	105	105.0
63-3-04-3	6-3216	A1	6"	100	116	102	102.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-3-05/6-3206 HALL

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-3-05-1	6-3207	A1	6"	135	135	140	103.7
63-3-05-2	6-3206	A1	6"	135	152	138	102.2
63-3-05-3	6-3206 HALL	A1	6"	130	220	125	96.2

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-3-06/6-3220

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-3-06-1	6-3320	A1	10"	300	318	302	100.7
63-3-06-2	6-3320	A1	10"	300	380	325	108.3

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-3-07/6-3224

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-3-07-1	6-3137	A1	6"	140	185	145	103.6
63-3-07-2	6-3229	A1	6"	120	169	126	105.0
63-3-07-3	6-3224	A2	6"	100	140	104	104.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-3-08/6-3225

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-3-08-1	6-3211	A1	8"	225	187	220	97.8
63-3-08-2	6-3225	A1	6"	125	164	126	100.8

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-3-09/6-3000-1

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-3-09-1	6-3000-1	S1	10"	185	208	186	100.5
63-3-09-2	6-3000-1	S1	10"	185	209	198	107.0
63-3-09-3	6-3000-1	S1	10"	185	236	194	104.9
63-3-09-4	6-3000-1	S1	10"	185	183	173	93.5
63-3-09-5	6-3000-1	S1	10"	185	160	177	95.7
63-3-09-6	6-3000-1	S1	10"	185	233	179	96.8
63-3-09-7	6-3000-1	S1	10"	185	204	182	98.4
63-3-09-8	6-3000-1	S1	10"	185	258	199	107.6
63-3-09-9	6-3000-1	S1	10"	185	234	198	107.0
63-3-09-10	6-3000-1	S1	10"	185	250	173	93.5

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-4-10/6-4123

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-4-10-1	6-4123	A1	8"	175	211	179	102.3

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-4-11/6-4000-3

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-4-11-1	6-4000-3	S1	12"	245	256	253	103.3
63-4-11-2	6-4000-3	S1	12"	245	271	247	100.8
63-4-11-3	6-4000-3	S1	12"	245	249	256	104.5
63-4-11-4	6-4000-3	S1	12"	245	305	262	106.9
63-4-11-5	6-4000-3	S1	12"	245	281	237	96.7
63-4-11-6	6-4000-3	S1	12"	245	235	249	101.6
63-4-11-7	6-4000-3	S1	12"	245	224	231	94.3

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-4-12/6-4104

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-4-12-1	6-4102	A1	8"	220	242	217	98.6
63-4-12-2	6-4100-2	A1	8"	200	206	204	102.0
63-4-12-3	6-4104	A1	8"	220	256	229	104.1

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-4-13/6-4103

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-4-13-1	6-4110	A1	6"	100	109	98	98.0
63-4-13-2	6-4109	A1	6"	100	121	95	95.0
63-4-13-3	6-4103	A1	6"	100	153	103	103.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-4-14/6-4111

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-4-14-1	6-4100-2	A1	8"	130	165	132	101.5
63-4-14-2	6-4111	A1	8"	200	225	205	102.5
63-4-14-3	6-4111	A1	8"	200	240	211	105.5
63-4-14-4	6-4101-1	A1	8"	130	150	138	106.2

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-4-15/6-4106

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-4-15-1	6-4105	A1	8"	220	270	217	98.6
63-4-15-2	6-4106	A1	8"	220	256	229	104.1

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-4-16/6-4107

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-4-16-1	6-4112	A1	8"	210	258	215	102.4
63-4-16-2	6-4112	A1	8"	205	262	209	102.0
63-4-16-3	6-4112	A1	8"	205	220	216	105.4

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-4-17/6-4107

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-4-17-1	6-4107	A1	8"	165	325	172	104.2
63-4-17-2	6-4107	A1	8"	160	44	168	105.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-4-18/6-4116

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-4-18-1	6-4113	A1	6"	100	131	106	106.0
63-4-18-2	6-4114	A1	6"	100	129	104	104.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-4-19/6-4116

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-4-19-1	6-4126	A1	6"	50	109	52	104.0
63-4-19-2	6-4101-2	A1	6"	150	146	158	105.3
63-4-19-3	6-4117	A1	6"	75	115	74	98.7
63-4-19-4	6-4100-1	A1	8"	200	184	209	104.5
63-4-19-5	6-4116	A1	6"	115	157	120	104.3
63-4-19-6	6-4100-3	A1	6"	90	99	92	102.2
63-4-19-7	6-4108	A2	6"	50	108	54	108.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-4-20/6-4125

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-4-20-1	6-4125	A1	8"	200	262	208	104.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-4-21/6-4505

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-4-21-1	6-4502	A2	6"	50	124	50	100.0
63-4-21-2	6-4503	A2	6"	50	130	46	92.0
63-4-21-3	HALL	A1	8"	185	315	175	94.6
63-4-21-4	6-4505	A1	6"	120	151	122	101.7
63-4-21-5	ELEV LOBBY	S1	10"	220	46	223	101.4
63-4-21-6	HALL	A1	8"	180	48	181	100.6

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-4-22/6-4118

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-4-22-1	6-4504	S1	10"	185	194	175	94.6
63-4-22-2	6-4504	A1	8"	180	129	186	103.3
63-4-22-3	6-4504	A1	8"	185	179	192	103.8
63-4-22-4	6-4504	S1	10"	185	178	194	104.9

National TAB

Project:DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-4-23/6-4118

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-4-23-1	6-4118	A1	6"	100	98	98	98.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-4-01/6-4210

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-4-01-1	6-4001	A1	6"	120	72	122	101.7
63-4-01-2	6-4210	A1	8"	195	215	191	97.9
63-4-01-3	6-4001	A1	6"	120	125	129	107.5
63-4-01-4	6-4001	A1	6"	120	128	121	100.8
63-4-01-5	6-4003	A2	6"	50	113	48	96.0
63-4-01-6	6-4001	A1	6"	135	121	125	92.6

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-4-02/6-4222

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-4-02-1	6-4220	A1	6"	100	117	104	104.0
63-4-02-2	6-4222	A1	6"	100	125	109	109.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-4-03/6-4212

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-4-03-1	6-4212	A1	8"	160	195	164	102.5

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-4-04/6-4000-1

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-4-04-1	6-4000-2	S1	185		156	168	-
63-4-04-2	6-4000-2	S1	185		153	201	-
63-4-04-3	6-4000-2	S1	185		169	182	-
63-4-04-4	6-4000-2	S1	185		208	169	-
63-4-04-5	6-4000-2	S1	185		187	194	-
63-4-04-6	6-4000-2	S1	185		231	196	-
63-4-04-7	6-4000-2	S1	185		234	201	-
63-4-04-8	6-4000-2	S1	185		186	191	-
63-4-04-9	6-4000-2	S1	185		235	189	-
63-4-04-10	6-4000-2	S1	185		192	184	-

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-4-05/6-4213

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-4-05-1	6-4000-2	A1	8"	210	217	216	102.9
63-4-05-2	6-4000-2	A1	8"	205	230	209	102.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-4-06/6-4213

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-4-06-1	6-4200-2	A1	8"	150	165	152	101.3
63-4-06-2	6-4213	A1	8"	205	268	210	102.4
63-4-06-3	6-4213	A1	8"	205	265	217	105.9
63-4-06-4	6-4213	A1	8"	210	312	211	100.5
63-4-06-5	6-4231	A1	6"	145	0	146	100.7

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-4-07/6-4119

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-4-07-1	6-4119	A1	6"	100			-
63-4-07-2	6-4203	A1	6"	100			-
63-4-07-3	6-4204	A1	6"	115			-

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-4-08/6-4206

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-4-08-1	6-4120	A1	6"	100	112	109	109.0
63-4-08-2	6-4121	A1	6"	100	118	105	105.0
63-4-08-3	6-4205	A1	6"	100	124	106	106.0
63-4-08-4	6-4206	A1	6"	100	108	108	108.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-4-09/6-4209

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-4-09-1	6-4122	A1	6"	100	124	105	105.0
63-4-09-2	6-4207	A1	6"	100	125	106	106.0
63-4-09-3	6-4208	A1	6"	100	116	99	99.0
63-4-09-4	6-4209	A1	6"	100	108	110	110.0

National TAB

Project:DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-5-01/5TH FLR WEST

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-5-01-1	5TH FLR NORTH	F1	24"X10"	400	492	421	105.3
63-5-01-2	5TH FLR NORTH	F1	24"X10"	400	487	409	102.3
63-5-01-3	5TH FLR NORTH	F1	24"X10"	400	521	414	103.5
63-5-01-4	5TH FLR NORTH	F1	24"X10"	400	501	424	106.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-5-02/5TH FLR WEST

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-5-02-1	6-5000-1	S1	10"	185			-
63-5-02-2	6-5000-1	S1	10"	185			-
63-5-02-3	6-5000-1	S1	10"	185			-
63-5-02-4	6-5000-1	S1	10"	185			-
63-5-02-5	6-5000-1	S1	10"	185			-
63-5-02-6	6-5000-1	S1	10"	185			-
63-5-02-7	6-5000-1	S1	10"	185			-
63-5-02-8	6-5000-1	S1	10"	185			-
63-5-02-9	6-5000-1	S1	10"	185			-
63-5-02-10	6-5000-1	S1	10"	185			-

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-6-01/6TH FLR SOUTHEAST

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
63-6-01-1	MECH RM	F1	16"X10"	500	549	498	99.6
63-6-01-2	MECH RM	F1	16"X10"	500	601	521	104.2
63-6-01-3	MECH RM	F1	16"X10"	500	571	514	102.8

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

63-6-02/6-6503

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
SGRD1	6-6503	F1	24"X12"	900	911	906	100.7

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-1-10/6-1416

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-1-10-1	6-1416	A1	6"	120	154	123	102.5
64-1-10-2	6-1416	A1	6"	125	165	125	100.0
64-1-10-3	6-1402	A1	6"	75	174	74	98.7
64-1-10-4	6-1416	A1	6"	120	154	123	102.5

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-1-11/6-1303

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-1-11-1	6-1418	A1	6"	100	121	91	91.0
64-1-11-2	6-1303	A1	6"	100	149	108	108.0
64-1-11-3	6-1200B	A1	6"	95	122	92	96.8
64-1-11-4	6-1200	A1	6"	75	123	72	96.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-1-12/6-1309

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
SGRD1	6-1302	A1	6"	100	121	102	102.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-1-13/6-1309

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-1-13-1	6-1325-2	A1	8"	155	206	144	92.9
64-1-13-2	6-1309	A1	8"	205	203	198	96.6
64-1-13-3	6-1309	A1	8"	205	190	200	97.6
64-1-13-4	6-1309	A1	8"	210	182	215	102.4
64-1-13-5	6-1300-1	A1	8"	155	161	161	103.9

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-1-14/6-1306

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-1-14-1	6-1306	A1	6"	100	129	104	104.0
64-1-14-2	6-1307	A1	6"	100	87	102	102.0
64-1-14-3	6-1308	A1	6"	100	116	109	109.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-1-15/6-1310

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-1-15-1	6-1310	A1	6"	155	179	154	99.4
64-1-15-2	6-1310	A1	6"	150	167	153	102.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-1-16/6-1311

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
SGRD1	6-1311	A1	8"	175	196	180	102.9

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-1-17/6-1320

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-1-17-1	6-1313	A1	6"	115	137	118	102.6
64-1-17-2	6-1320	A1	6"	115	139	112	97.4

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-1-18/6-1315

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-1-18-1	6-1317	A1	6"	160	71	161	100.6
64-1-18-2	6-1315	A1	6"	50	121	55	110.0
64-1-18-3	6-1314	A1	6"	75	109	72	96.0
64-1-18-4	6-1300-2	A1	6"	160	117	160	100.0
64-1-18-5	6-1216	A1	6"	50	108	55	110.0
64-1-18-6	6-1318	A2	6"	50	70	46	92.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-1-19/6-1315

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-1-19-1	6-1315	A1	8"	200	244	209	104.5

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-1-20/6-1505

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-1-20-1	6-1505	S1	8"	100	94	91	91.0
64-1-20-2	6-1505	S1	8"	100	227	108	108.0
64-1-20-3	6-1505	S1	8"	100	220	104	104.0
64-1-20-4	6-1508	A2	6"	75	88	77	102.7
64-1-20-5	6-1504	A2	6"	50	69	54	108.0
64-1-20-6	6-1507-2	A1	8"	105	109	108	102.9
64-1-20-7	6-1509	A2	6"	75	66	77	102.7
64-1-20-8	6-1503	A2	6"	50	51	46	92.0
64-1-20-9	6-1502	A1	6"	50	49	53	106.0
64-1-20-10	6-1507-2	A1	6"	100	108	100	100.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-1-21/6-1506

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-1-21-1	6-1506	A1	10"	320	488	347	108.4
64-1-21-2	6-1506	A1	8"	315	49	282	89.5
64-1-21-3	6-1506	A1	10"	315	498	308	97.8

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-1-22/6-1211

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-1-22-1	6-1210	A1	6"	100	127	93	93.0
64-1-22-2	6-1211	A1	6"	100	95	105	105.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-1-23/6-1207

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-1-23-1	6-1209	A1	6"	100	154	93	93.0
64-1-23-2	6-1207	A1	8"	205	158	202	98.5

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-1-24/6-1205

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-1-24-1	6-1205	A1	6"	150	178	158	105.3
64-1-24-2	6-1202	A1	6"	115	187	109	94.8
64-1-24-3	6-1201	A1	6"	115	139	121	105.2

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-1-25/6-1301

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-1-25-1	6-1204	A2	6"	90	142	93	103.3
64-1-25-2	6-1325-1	A1	6"	100	165	108	108.0
64-1-25-3	6-1301	A1	6"	100	156	100	100.0
64-1-25-4	6-1213	A1	6"	105	143	107	101.9

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-1-26/6-1208

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-1-26-1	6-1206	A1	6"	100	115	97	97.0
64-1-26-2	6-1208	A1	6"	100	120	108	108.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-1-27/6-1215

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-1-27-1	6-1215	A1	8"	200	219	216	108.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-1-28/6-1214

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
SGRD1	6-1214	A1	6"	75	124	81	108.0
SGRD2	HALL	A1	6"	155	145	158	101.9

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-1-29/6-1304

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-1-29-1	6-1303	A1	8"	190	206	193	101.6

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-1-30/6-2401

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-1-30-1	6-1305	A1	6"	100	156	107	107.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-1-01/6-1319

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-1-01-1	6-1319	A1	8"	160	202	175	109.4
64-1-01-2	6-1319	A1	8"	165	187	156	94.5

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-1-02/6-1322

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-1-02-1	6-1322	A1	8"	200	285	191	95.5
64-1-02-2	6-1321	A1	8"	200	252	204	102.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-1-03/6-1323

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-1-03-1	6-1324	A1	8"	200	276	215	107.5
64-1-03-2	6-1323	A1	8"	200	255	206	103.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-1-04/6-1415

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-1-04-1	6-1415	BOOTH	6"	100	178	108	108.0
64-1-04-2	6-1415	A1	6"	150	169	144	96.0
64-1-04-3	6-1417	A1	6"	150	181	146	97.3
64-1-04-4	6-1417	BOOTH	6"	100	152	93	93.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-1-05/6-1412

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-1-05-1	6-1412	BOOTH	6"	100	109	103	103.0
64-1-05-2	6-1412	A1	8"	175	375	172	98.3
64-1-05-3	6-1413	A1	6"	150	185	151	100.7
64-1-05-4	6-1413	BOOTH	6"	100	109	93	93.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-1-06/6-1408

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-1-06-1	6-1409	A1	8"	225	352	222	98.7
64-1-06-2	6-1408	A1	8"	225	362	212	94.2

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-1-07/6-1407

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-1-07-1	6-1407	A1	8"	225	293	240	106.7
64-1-07-2	6-1406	A1	8"	225	365	232	103.1
64-1-07-3	6-1405	A1	8"	175	282	169	96.6

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-1-08/6-1401

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-1-08-1	6-1400-2	A1	6"	100			-
64-1-08-2	6-1400-2	A1	6"	100			-
64-1-08-3	6-1400-1	A1	6"	100			-
64-1-08-4	6-1401	A1	6"	140			-
64-1-08-5	6-1400-1	A1	6"	85			-
64-1-08-6	6-1404	A1	6"	75			-

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-1-09/6-1410

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-1-09-1	6-1411	A1	6"	100	107	101	101.0
64-1-09-2	6-1414	A1	6"	115	130	108	93.9

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-2-10/6-2318

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-2-10-1	HALL	A1	8"	165	186	163	98.8
64-2-10-2	6-2410	A1	8"	155	179	157	101.3
64-2-10-3	6-2408	A1	8"	185	92	166	89.7
64-2-10-4	6-2418	A2	6"	50	70	55	110.0
64-2-10-5	6-2419	A1	6"	50	140	48	96.0
64-2-10-6	6-2400	A1	8"	90	151	91	101.1
64-2-10-7	6-2401	A1	6"	90	82	87	96.7
64-2-10-8	6-2402	A1	12"	365	323	371	101.6

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-2-11/6-2318

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-2-11-1	6-2318	A1	8"	200	224	202	101.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-2-12/6-2219

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-2-12-1	6-2309	A1	6"	100	125	103	103.0
64-2-12-2	6-2310	A1	6"	100	95	96	96.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-2-13/6-2311

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-2-13-1	6-2302	A1	6"	100	113	100	100.0
64-2-13-2	6-2303	A1	6"	100	122	98	98.0
64-2-13-3	6-2220	A1	6"	100	164	102	102.0
64-2-13-4	6-2219	A1	6"	100	156	96	96.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-2-14/6-2221

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-2-14-1	6-2301-1	A1	6"	130	133	125	96.2
64-2-14-2	6-2301-1	A1	6"	130	130	130	100.0
64-2-14-3	6-2311	A1	8"	205	273	210	102.4
64-2-14-4	HALL	A1	6"	135	137	133	98.5
64-2-14-5	6-2311	A1	8"	200	275	187	93.5
64-2-14-6	6-2311	A1	8"	205	235	188	91.7
64-2-14-7	6-2300-1	A1	6"	130	119	127	97.7

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-2-15/6-2221

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-2-15-1	6-2223	A1	6"	100	122	103	103.0
64-2-15-2	6-2222	A1	6"	100	128	97	97.0
64-2-15-3	6-2221	A1	6"	100	140	98	98.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-2-16/6-2306

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-2-16-1	6-2306	A1	6"	100	117	95	95.0
64-2-16-2	6-2305	A1	6"	100	130	100	100.0
64-2-16-3	6-2304	A1	6"	100	104	91	91.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-2-17/6-2224

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-2-17-1	6-2224	A1	8"	175	193		-

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-2-18/6-2307

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-2-18-1	6-2307	A1	8"	175	211	179	102.3

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-2-19/6-2314

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-2-19-1	6-2312	A1	6"	150	163	148	98.7
64-2-19-2	6-2312	A1	6"	155	175	155	100.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-2-20/6-2314

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-2-20-1	6-2314	A1	6"	100	125	102	102.0
64-2-20-2	6-2313	A1	6"	100	95	97	97.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-2-21/6-2317

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-2-21-1	6-2325	A2	6"	50	45	54	108.0
64-2-21-2	6-2301-2	A1	6"	110	33	117	106.4
64-2-21-3	6-2317	A1	6"	85	225	90	105.9
64-2-21-4	HALL	A1	6"	105	164	109	103.8
64-2-21-5	6-2315	A1	6"	75	154	74	98.7
64-2-21-6	6-2300-1	A1	6"	110	104	104	94.5

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-2-23/6-2227

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-2-23-1	6-2227	A1	6"	60	114	55	91.7
64-2-23-2	6-2202-1	A1	6"	100	25	108	108.0
64-2-23-3	6-2218	A1	6"	75	113	74	98.7
64-2-23-4	6-2201-1	A1	6"	130	145	130	100.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-2-24/6-2226

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-2-24-1	6-2226	A1	8"	200	232	192	96.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-2-25/6-2217

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-2-25-1	6-2217	A1	6"	135	147	138	102.2

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-2-26/6-2316

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-2-26-1	6*-2316	A1	8"	165	203	172	104.2

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-2-27/6-2506

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-2-27-1	6-2326	A1	8"	185	187	184	99.5

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-2-28/6-2506

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-2-28-1	6-2506	S1	8"	175	266	162	92.6
64-2-28-2	6-2506	S1	8"	175	214	175	100.0
64-2-28-3	6-2506	S1	8"	175	194	189	108.0
64-2-28-4	6-2506	S1	8"	175	223	159	90.9
64-2-28-5	6-2505	A2	6"	50	19	48	96.0
64-2-28-6	HALL	A1	8"	175	155	167	95.4
64-2-28-7	6-2504	A2	6"	50	58	49	98.0
64-2-28-8	6-2503	A1	6"	50	75	54	108.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-2-29/6-2507

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-2-29-1	6-2507	S1	10"	200	62	213	106.5
64-2-29-2	6-2507	S1	10"	200	410	214	107.0
64-2-29-3	6-2507	S1	10"	200	282	204	102.0
64-2-29-4	6-2507	A1	8"	200	211	207	103.5
64-2-29-5	6-2507	S1	10"	200	41	210	105.0
64-2-29-6	6-2507	S1	10"	200	403	201	100.5
64-2-29-7	6-2507	S1	10"	200	52	189	94.5
64-2-29-8	6-2507	A1	8"	200	214	185	92.5
64-2-29-9	6-2507	A1	8"	200	249	212	106.0
64-2-29-10	6-2507	S1	10"	200	379	198	99.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-2-01/6-2320

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-2-01-1	6-2324	A1	8"	205	272	203	99.0
64-2-01-2	6-2324	A1	8"	210	322	226	107.6

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-2-02/6-2420

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-2-02-1	6-2323	A1	8"	225	224	240	106.7
64-2-02-2	6-2322	A1	8"	225	242	206	91.6
64-2-02-3	6-2321	A1	8"	225	261	214	95.1
64-2-02-4	6-2320	A1	8"	225	230	226	100.4

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-2-03/6-2319

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-2-03-1	6-2420	A1	6"	125	149	133	106.4

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-2-04/6-2319

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-2-04-1	6-2319	A1	8"	200	245	205	102.5
64-2-04-2	6-2319	A1	8"	200	293	220	110.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-2-05/6-2416

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-2-05-1	6-2416	A1	10"	310	378	295	95.2
64-2-05-2	6-2416	A1	10"	375	403	387	103.2
64-2-05-3	6-2416	A1	10"	375	363	385	102.7

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-2-06/6-2415

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-2-06-1	6-2415	A1	8"	225	239	221	98.2
64-2-06-2	6-2415	A1	8"	225	236	221	98.2
64-2-06-3	6-2412	A1	6"	100	124	101	101.0
64-2-06-4	6-2413	A2	6"	50	24	48	96.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-2-07/6-2411

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-2-07-1	6-2407	A2	6"	50	97	46	92.0
64-2-07-2	6-2406	A1	10"	270	370	286	105.9
64-2-07-3	6-2405	A1	10"	270	310	282	104.4
64-2-07-4	6-2404	A2	6"	50	61	49	98.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-2-08/6-2411

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-2-08-1	6-2411	A1	10"	300	299	290	96.7
64-2-08-2	6-2411	A1	10"	300	336	315	105.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-2-09/6-2403

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-2-09-1	6-2403	A1	12"	435	380	433	99.5
64-2-09-2	6-2403	A1	12"	435	376	420	96.6
64-2-09-3	6-2409	A2	6"	25	97	24	96.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-3-10/6-3305

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-3-10-1	6-3305	A1	6"	100	144	100	100.0
64-3-10-2	6-3227	A1	6"	115	142	118	102.6
64-3-10-3	6-3227	A1	6"	100	113	103	103.0
64-3-10-4	6-3302	A1	6"	50	118	51	102.0
64-3-10-5	6-3216	A1	6"	100	137	96	96.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-3-11/6-3308

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-3-11-1	6-3306	A1	8"	200	214	206	103.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-3-12/6-3308

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-3-12-1	6-3307	A1	6"	100	122	92	92.0
64-3-12-2	6-3301-1	A1	6"	95	137	95	100.0
64-3-12-3	6-3308	A1	6"	100	146	108	108.0
64-3-12-4	HALL	A1	6"	90	124	96	106.7

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-3-13/6-3304

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-3-13-1	6-3303	A1	6"	100	111	97	97.0
64-3-13-2	6-3304	A1	6"	100	123	108	108.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-3-14/6-3313

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-3-14-1	6-3226	A2	6"	50	67	49	98.0
64-3-14-2	6-3301-2	A1	8"	170	124	166	97.6
64-3-14-3	6-3311	A2	6"	25	56	27	108.0
64-3-14-4	6-3313	A1	6"	100	71	91	91.0
64-3-14-5	6-3319	A2	6"	50	62	54	108.0
64-3-14-6	HALL	A1	8"	170	193	174	102.4

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-3-15/6-3312

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-3-15-1	6-3312	A1	8"	200	242	204	102.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-3-16/6-3320

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-3-16-1	6-3320	A1	8"	200	302	197	98.5

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-3-17/6-3509

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-3-17-1	3509	S1	8	175	184	169	96.6
64-3-17-2	3509	S1	8	175	215	186	106.3
64-3-17-3	3509	S1	8	175	217	183	104.6
64-3-17-4	3509	S1	8	175	223	178	101.7
64-3-17-5	3508	A2	6	50	33	48	96.0
64-3-17-6	HALLWAY	A1	6	100	50	93	93.0
64-3-17-7	3507	A2	6	50	22	54	108.0
64-3-17-8	3506	A1	6	50	49	52	104.0
64-3-17-9	HALLWAY	A1	6	100	80	93	93.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-3-18/6-3510

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-3-18-1	6-3510	A1	8"	200	149	194	97.0
64-3-18-2	6-3510	S1	10"	200	266	216	108.0
64-3-18-3	6-3510	A1	8"	200	30	184	92.0
64-3-18-4	6-3510	A1	8"	200	221	213	106.5
64-3-18-5	6-3510	S1	10"	200	328	193	96.5
64-3-18-6	6-3510	S1	10"	200	294	204	102.0
64-3-18-7	6-3510	S1	10"	200	304	189	94.5
64-3-18-8	6-3510	S1	10"	200	297	201	100.5
64-3-18-9	6-3510	S1	10"	200	335	179	89.5
64-3-18-10	6-3510	S1	10"	200	305	188	94.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-3-19/6-3310

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-3-19-1	6-3309	A1	6"	100	109	91	91.0
64-3-19-2	6-3310	A1	6"	100	128	107	107.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-3-20/6-3218

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-3-20-1	6-3219	A1	6"	100	130	100	100.0
64-3-20-2	6-3218	A1	6"	100	98	93	93.0
64-3-20-3	6-3215	A1	6"	100	134	97	97.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-3-01/6-3317

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-3-01-1	6-3318	A1	10"	310	299	308	99.4

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-3-02/6-3406

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-3-02-1	6-3317	A1	8"	250	230	248	99.2
64-3-02-2	6-3317	A1	8"	245	234	256	104.5
64-3-02-3	6-3317	A1	8"	250	263	249	99.6
64-3-02-4	6-3316	A1	10"	310	312	315	101.6

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-3-03/6-3314

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-3-03-1	6-3314	A1	8"	220	270	224	101.8

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-3-04/6-3401-1

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-3-04-1	6-3406	S1	10"	210	240	215	102.4
64-3-04-2	6-3406	S1	10"	210	263	204	97.1
64-3-04-3	6-3406	S1	10"	210	290	209	99.5
64-3-04-4	6-3406	S1	10"	210	243	221	105.2
64-3-04-5	6-3406A	S1	6"	0	0	0	-

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-3-05/6-3401-1

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-3-05-1	6-3401-1	A1	8"	150	220	158	105.3
64-3-05-2	6-3401-1	A1	8"	150	260	154	102.7
64-3-05-3	6-3401-1	S1	8"	160	54	169	105.6
64-3-05-4	6-3401-1	S1	8"	160	201	154	96.3
64-3-05-5	6-3401-1	S1	8"	160	231	162	101.3
64-3-05-6	6-3401-1	S1	8"	160	195	149	93.1
64-3-05-7	6-3401-1	S1	8"	160	182	152	95.0
64-3-05-8	6-3401-1	S1	8"	160	215	172	107.5
64-3-05-9	6-3401-1	S1	8"	160	216	174	108.8
64-3-05-10	6-3401-1	S1	8"	160	189	169	105.6
64-3-05-11	6-3401-1	S1	8"	160	240	163	101.9

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-3-06/6-3404

Asset									
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design	AK	CFM(2)
64-3-06-1	6-3401-1	A1	8"	165	182	170	103.0		
64-3-06-2	6-3401-1	A1	8"	165	185	161	97.6		
64-3-06-3	6-3401-1	S1	8"	160	208	153	95.6		
64-3-06-4	6-3401-1	S1	8"	160	133	171	106.9		
64-3-06-5	6-3401-1	S1	8"	160	92	164	102.5		
64-3-06-6	6-3401-1	S1	8"	160	147	152	95.0		
64-3-06-7	6-3401-1	S1	8"	160	246	154	96.3		
64-3-06-8	6-3401-1	S1	8"	160	225	171	106.9		
64-3-06-9	6-3401-1	S1	8"	160	283	167	104.4		
64-3-06-10	6-3401-1	S1	8"	160	251	162	101.3		
64-3-06-11	6-3401-1	S1	8"	160	275	157	98.1		
64-3-06-SGRD12	6-3401-1	S1	8"	160					
64-3-06-SGRD13	6-3401-1	S1	8"	160					
64-3-06-SGRD14	6-3401-1	S1	8"	160					

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-3-07/6-3404

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-3-07-1	6-3404	F1	18"X10"	515	753	507	98.4

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-3-08/6-3403

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-3-08-1	6-3403	A1	8"	270	262	257	95.2
64-3-08-2	HALL	A2	6"	125	51	117	93.6
64-3-08-3	6-3403	A1	8"	270	273	261	96.7
64-3-08-4	6-3405	A1	6"	125	56	114	91.2
64-3-08-5	6-3403	A1	8"	270	373	267	98.9
64-3-08-6	6-3402	A2	6"	50	121	48	96.0
64-3-08-7	6-3401-1	A1	8"	270	387	281	104.1
64-3-08-8	6-3401-1	A1	8"	270	377	276	102.2
64-3-08-9	6-3401-1	A1	8"	270	371	272	100.7
64-3-08-10	6-3401-1	A2	6"	0	0	0	-

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-3-09/6-3315

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-3-09-1	6-3315	A1	10"	360	410	361	100.3

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-4-10/6-4408

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-4-10-1	6-4406	A1	10"	315	351	315	100.0
64-4-10-2	6-4408	A1	10"	315	340	303	96.2
64-4-10-3	6-4411	A1	10"	315	343	312	99.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-4-11/6-4403

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-4-11-1	6-4403	A1	12"	445	375	451	101.3
64-4-11-2	6-4404	A1	10"	315	429	313	99.4

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-4-12/6-4405

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-4-12-1	6-4400	A1	6"	70	92	74	105.7
64-4-12-2	6-4407	A1	6"	75	75	70	93.3
64-4-12-3	HALL	A1	6"	70	90	77	110.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-4-13/6-4409

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-4-13-1	6-4409	A1	8"	200	227	187	93.5
64-4-13-2	6-4405	A1	6"	75	117	79	105.3

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-4-14/6-4413

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-4-14-1	6-4413	A1	6"	50	81	51	102.0
64-4-14-2	HALL	A1	8"	60	83	64	106.7
64-4-14-3	6-4401	A1	6"	55	88	54	98.2
64-4-14-4	HALL	A1	6"	60	33	55	91.7
64-4-14-5	6-4415	A1	6"	75	67	75	100.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-4-15/6-4410

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-4-15-1	6-4410	A1	8"	210	244	216	102.9

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-4-16/6-4414

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-4-16-1	6-4414	A1	8"	175	207	169	96.6

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-4-17/6-4312

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-4-17-1	6-4300-2	A1	6"	145	144	138	95.2
64-4-17-2	6-4300-2	A1	6"	145	149	148	102.1
64-4-17-3	6-4312	A1	8"	205	201	200	97.6
64-4-17-4	6-4312	A1	8"	205	201	194	94.6
64-4-17-5	6-4301-2	A1	6"	145	335	139	95.9
64-4-17-6	6-4312	A1	8"	205	90	211	102.9
64-4-17-7	6-4301-2	A1	6"	145	138	146	100.7

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-4-18/6-4302

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-4-18-1	6-4305	A1	8"	100	122	107	107.0
64-4-18-2	6-4304	A1	8"	100	133	103	103.0
64-4-18-3	6-4303	A1	6"	100	90	95	95.0
64-4-18-4	6-4302	A1	6"	100	85	102	102.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-4-19/6-4223

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-4-19-1	6-4223	A1	8"	175	206	173	98.9

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-4-20/6-4226

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-4-20-1	6-4306	A1	6"	100	107	107	107.0
64-4-20-2	6-4224	A1	6"	100	92	92	92.0
64-4-20-3	6-4225	A1	6"	100	109	109	109.0
64-4-20-4	6-4226	A1	6"	100	93	93	93.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-4-21/6-4307

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-4-21-1	6-4307	A1	8"	175	196	186	106.3

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-4-22/6-4315

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-4-22-1	6-4313	A1	6"	155	162	147	94.8
64-4-22-2	6-4313	A1	6"	150	172	145	96.7

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-4-23/6-4326

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-4-23-1	6-4314	A1	6"	100	128	102	102.0
64-4-23-2	6-4315	A1	6"	115	119	105	91.3

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-4-24/6-4316

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-4-24-1	HALL	A1	8"	170	170	169	99.4
64-4-24-2	6-4318	A2	6"	75	83	77	102.7
64-4-24-3	6-4317	A1	6"	75	91	69	92.0
64-4-24-4	6-4301-1	A1	8"	170	190	173	101.8
64-4-24-5	6-4326	A1	8"	175	171	172	98.3
64-4-24-6	6-4325	A2	6"	50	96	51	102.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-4-25/6-4316

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-4-25-1	6-4316	a1	8"	200	241	198	99.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-4-26/6-4509

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-4-26-1	6-4510	A1	8"	200	158	200	100.0
64-4-26-2	6-4510	A1	8"	200	159	197	98.5
64-4-26-3	6-4510	A1	8"	200	222	203	101.5
64-4-26-4	6-4510	S1	10"	200	207	218	109.0
64-4-26-5	6-4510	S1	10"	200	279	214	107.0
64-4-26-6	6-4510	S1	10"	200	371	210	105.0
64-4-26-7	6-4510	S1	10"	200	318	213	106.5
64-4-26-8	6-4510	S1	10"	200	308	194	97.0
64-4-26-9	6-4510	S1	10"	200	240	204	102.0
64-4-26-10	6-4510	S1	10"	200	268	212	106.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-4-27/6-4509

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-4-27-1	6-4501	A1	6"	90	92	91	101.1
64-4-27-2	6-4506	A2	6"	50	60	49	98.0
64-4-27-3	6-4507	A2	6"	50	53	53	106.0
64-4-27-4	6-4501	A1	6"	95	95	92	96.8
64-4-27-5	6-4508	A2	6"	50	70	46	92.0
64-4-27-6	6-4509	S1	8"	175	157	154	88.0
64-4-27-7	6-4509	S1	8"	175	182	172	98.3
64-4-27-8	6-4509	S1	8"	175	251	189	108.0
64-4-27-9	6-4509	S1	8"	175	216	173	98.9

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-4-28/6-4219

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-4-28-1	6-4219	A1	8"	200	237	201	100.5

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-4-29/6-4214

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-4-29-1	6-4217	A1	6"	150	117	143	95.3
64-4-29-2	6-4218	A1	6"	115	102	118	102.6
64-4-29-3	6-4201-2	A1	6"	145	127	142	97.9
64-4-29-4	6-4221	A1	6"	75	123	72	96.0
64-4-29-5	6-4228	A2	6"	50	103	46	92.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-4-30/6-4214

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-4-30-1	6-4214	A1	8"	150	123	142	94.7
64-4-30-2	6-4214	A1	8"	155	239	158	101.9

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-4-31/6-4310

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-4-31-1	6-4215	A1	6"	100	109	98	98.0
64-4-31-2	6-4216	A1	6"	100	123	109	109.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-4-32/6-4310

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-4-32-1	6-4310	A1	6"	100	139	97	97.0
64-4-32-2	6-4311	A1	6"	100	107	94	94.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-4-01/6-4324

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-4-01-1	6-4324	A1	10"	340	394	338	99.4

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-4-02/6-4322

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-4-02-1	6-4323	A1	8"	220	241	218	99.1
64-4-02-2	6-4322	A1	8"	220	198	225	102.3

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-4-03/6-4321

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-4-03-1	6-4321	A1	6"	100	138	103	103.0
64-4-03-2	6-4320	A1	6"	100	96	101	101.0

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-4-04/6-4320

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-4-04-1	6-4320	A1	8"	220	287	223	101.4

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-4-05/6-4422

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-4-05-1	6-4422	A1	8"	200	188	195	97.5
64-4-05-2	6-4422	A1	8"	205	226	211	102.9

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-4-06/6-4420

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-4-06-1	6-4420	A1	8"	175	200	170	97.1
64-4-06-2	6-4418	A1	8"	175	228	172	98.3

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-4-07/6-4419

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-4-07-1	6-4421	A1	10	320	487	323	100.9
64-4-07-2	6-4419	A1	12	445	355	441	99.1

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-4-08/6-4417

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-4-08-1	6-4417	A1	10"	345	415	351	101.7

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-4-09/6-4416

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-4-09-1	6-4416	A1	6"	130	87	122	93.8
64-4-09-2	6-4416	S1	8"	145	234	149	102.8
64-4-09-3	6-4416	S1	8"	145	171	147	101.4
64-4-09-4	6-4416	S1	8"	145	204	150	103.4
64-4-09-5	6-4416	S1	8"	145	162	148	102.1

National TAB

Project:DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-5-01/5TH FLR SOUTH

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-5-01-1	5TH FLR SOUTH	F1	24"X10"	400	439	409	102.3
64-5-01-2	5TH FLR SOUTH	F1	24"X10"	400	420	389	97.3
64-5-01-3	5TH FLR SOUTH	F1	24"X10"	400	405	405	101.3
64-5-01-4	5TH FLR SOUTH	F1	24"X10"	400	467	410	102.5

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

64-5-02/5TH FLR SOUTH

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
64-5-02-1	5TH FLR SOUTH	DUCT	8"X12"	1200	1662	1214	101.2

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

AC-6-02/6-6534

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
AC6-02-1	F1	10"X6"	250		205	230	-
AC6-02-2	F1	10"X6"	250		194	237	-
AC6-02-3	F1	10"X6"	250		187	241	-
AC6-02-4	F1	10"X6"	250		197	232	-

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

SAF-1/EAST STAIRWELL

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
SAF1-1	EAST STAIR FLR 1	F1	20"X36"	2250			-
SAF1-2	EAST STAIR FLR 3	F1	20"X36"	2250			-
SAF1-3	EAST STAIR FLR 5	F1	20"X36"	2250			-

National TAB

Project: DAYTON CHILDREN'S HOSPITAL (DAYTON, OH)



Comfort. Under control.

Diffuser Supply (GRD)

SAF-2/WEST STAIRWELL

Asset							
Asset Name	Location	Type	Size	DESIGN CFM	CFM(1)	FINAL CFM	% to design
SAF2-1	WEST STAIR FLR 1	F1	32"X24"	1675			-
SAF2-2	WEST STAIR FLR 3	F1	32"X24"	1675			-
SAF2-3	WEST STAIR FLR 5	F1	32"X24"	1650			-