

Report By:

**National TAB
1329 E. KEMPER ROAD
SUITE 4210
CINCINNATI, OH 45246**



**Report: test_1
Function: Test, Adjust, & Balance
Date: 06/07/2023**

PROJECT

Dayton Children's Hospital (Dayton, OH)

1 Childrens Plaza

Dayton, OH 45404

Client

Cinfab, LLC
5240 Lester Road
Cincinnati, OH 45213

National TAB

Project: Dayton Children's Hospital (Dayton, OH)

Table Of Contents

| Section | Page # |
|---------|--------|
| Boiler | 3 |

National TAB

Project: Dayton Children's Hospital (Dayton, OH)

System/Unit: Boiler



Comfort. Under control.

Asset: BLR-26

AREA:PENTHOUSE

| Unit Data | | |
|------------|--------|----------------|
| | Design | Actual |
| MFG | NA | LOCHINVAR |
| Model Num | NA | FBN0751 |
| Serial Num | - | 2142 126561835 |

| Test Data | | |
|-----------|--------|--------|
| | Design | Actual |
| GPM | - | 37.8 |

Completed By: Nick Payne on 12/23/2022

Notes: DESIGN GPM 35

Date: 01/13/2023

National TAB

Project: Dayton Children's Hospital (Dayton, OH)

System/Unit: Boiler



Comfort. Under control.

Asset: BLR-27

AREA:PENTHOUSE

Unit Data

| | Design | Actual |
|-------------------|--------|----------------|
| MFG | NA | LOCHINVAR |
| Model Num | NA | FBN1001 |
| Serial Num | - | 2142 126561833 |

Test Data

| | Design | Actual |
|------------|--------|--------|
| GPM | - | 68.2 |

Completed By: Nick Payne on 12/23/2022

Notes: DESIGN GPM 70

Date: 01/13/2023

National TAB

Project: Dayton Children's Hospital (Dayton, OH)

System/Unit: Boiler



Comfort. Under control.

Asset: BLR-28

AREA:PENTHOUSE

Unit Data

| | Design | Actual |
|-------------------|--------|----------------|
| MFG | NA | LOCHINVAR |
| Model Num | NA | FBN1001 |
| Serial Num | - | 2142 126561834 |

Test Data

| | Design | Actual |
|------------|--------|--------|
| GPM | - | 71.5 |

Completed By: Nick Payne on 12/23/2022

Notes: DESIGN GPM 70

Date: 01/13/2023