



Comfort. Under control.

NATIONAL TAB

AIR DUCT LEAKAGE TEST SUMMARY



Tested: 9/15/2023

PROJECT: Westover Hills Baptist Hospital, San Antonio, TX
 ASSET: AHU
 LEAKAGE CLASS 6
 SPECIFIED TEST PRESSURE (P1) 2"
 DUCT CONSTRUCTION PRESSURE CLASS (Pc) C

DESIGN DATA				FIELD TEST DATA RECORD						
SUBJECT DUCT	SURFACE AREA IN FT ²	ALLOWABLE LEAKAGE		DIAMETER		PRESSURE " W.G.	DATE	PERFORMED BY	WITNESSED BY	ACTUAL CFM
		LIMIT	CFM	ORIFICE	TUBE	DUCT				
			(TEST SECTION)							
RETURN DUCT										
1 [AHU 2-1}	609	0.094	57.25	3.75	4	-2.040	9/15/2023	WJ	Charles Eubanks	50.39
	609		57.25							50.39

REMARKS

TAB TEAM: National TAB
 CONSTRUCTION TEAM: Robins & Morton

DATE: 9/15/2023