







# National TAB

**Project: CW 3501 - Kintetsu**  
**Address: 3501 Olymps Blvd, Suite 140**

**Asset: FCU1-20**

**Area: HUDDLE**

Unit Data	
<b>MFG</b>	MITSUBISHI
<b>Model Num</b>	TPEFYP008MA144A
<b>Serial Num</b>	2XR0180830P90V

Test Data		
	Design	Actual
<b>SA CFM</b>	150	154
<b>Fan Speed</b>		MED-LOW
<b>OA CFM</b>	45	0
<b>RA CFM</b>	105	154
<b>RL Voltage</b>	230	214
<b>RL Amperage</b>		0.3
<b>Suction ESP</b>		0.01
<b>Discharge ESP</b>		0.19
<b>Total ESP</b>		0.2

Motor Data	
<b>Motor MFG</b>	INTERTEK
<b>Horsepower</b>	0.114
<b>Motor Rpm</b>	NL
<b>Phase</b>	1
<b>Voltage (rated)</b>	208
<b>Amperage (rated)</b>	1.75

Asset	Area Served	Type	Size	DESIGN CFM	Prelim CFM	FINAL CFM	% to design
SGRD1	104	A	8	150	154	154	1.03
				<b>150</b>	154	<b>154</b>	<b>1.03</b>

**NOTES:**  
 No Outside Air Damper







