

Report By:

Chetu Development
Test add 11
Test add 22
Noida, AL 44444



Report: NOV Report
Function: Test, Adjust, & Balance
Date: 11/18/2024
Completed By: Chetu Development

PROJECT
17 April Project

Address1

City, AK 11111

Client

Accurex
400 Ross Ave
Schofield, WI 54476

Chetu Development

Project: 17 April Project

Table Of Contents

| Section | Page # |
|------------------------|--------|
| AHU/RTU | 3 |
| Boiler | 11 |
| Diffuser Ret/Exh (GRD) | 15 |
| Diffuser Supply (GRD) | 16 |
| VAV - Dual Duct | 17 |
| VAV - Single Duct | 25 |



Chetu Development

Project: 17 April Project

System/Unit: AHU/RTU



Asset: AHU1

AREA:

| Unit Data | | |
|---------------------|--------|--------|
| | Design | Actual |
| MFG | AH | AH |
| Serial Num | - | |
| Model Num | AH | AH |
| Inventory Tag ID | - | |
| Type | - | |
| Series | - | |
| Configuration | - | |
| Num OA Filters 1 | - | |
| OA Filter Size 1 | - | |
| Num OA Filters 2 | - | |
| OA Filter Size 2 | - | |
| Num PreFilter 1 | - | |
| PreFilter Size 1 | - | |
| Num PreFilter 2 | - | |
| PreFilter Size 2 | - | |
| Num Final Filter 1 | - | |
| Final Filter Size 1 | - | |
| Num Final Filter 2 | - | |
| Final Filter Size 2 | - | |

| Motor Data | | |
|----------------|--------|--------|
| | Design | Actual |
| Motor MFG | - | |
| Frame | - | |
| Horsepower | - | |
| Motor Rpm | - | |
| Phase | - | |
| Rated Voltage | - | |
| Rated Amperage | - | |
| Frequency | - | |
| Service Factor | - | |
| Efficiency | - | |
| Power Factor | - | |

| Test Data | | |
|--------------------------|--------|--------|
| | Design | Actual |
| SF CFM (Initial) | - | |
| SF CFM | - | |
| SF RPM (Initial) | - | |
| SF RPM | - | |
| RA CFM | - | |
| OA CFM | - | |
| Exhaust CFM | - | |
| Relief CFM | - | |
| RL Voltage | - | |
| RL Amperage | - | |
| SF Rotation | - | |
| VFD Max SetPt | - | |
| VFD Min SetPt | - | |
| SF Motor Freq(HZ) | - | |
| SF Flow Station (Kv) | - | |
| OA Flow Station (Kv) | - | |
| SF System SetPt | - | |
| RA Flow Station (Kv) | - | |
| Relief Flow Station (Kv) | - | |
| RA Damper Position | - | |
| RA Damper Type | - | |
| MA Damper Position | - | |
| MA Damper Type | - | |
| OA Damper Position | - | |
| OA Damper Type | - | |
| Min OA Damper Position | - | |
| Min OA Damper Type | - | |
| Econo Damper Position | - | |
| Econo Damper Type | - | |
| Relief Damper Position | - | |
| Relief Damper Type | - | |
| OA Enthalpy Setpt | - | |
| Brake Horse Power | - | |

| Drive Data | |
|--------------------|--------|
| | Actual |
| Motor Sheave MFG | |
| Motor Sheave Size | |
| Motor Bore Size | |
| Motor Sheave SetPt | |
| Fan Sheave MFG | |
| Fan Sheave Size | |
| Fan Sheave Bore | |
| Belt CL Distance | |
| Num of Belts | |
| Belt Size | |
| Belt MFG | |
| Belt Deflection | |
| Belt Alignment | |

| Condensor Fan | |
|-----------------|--------|
| | Actual |
| Fan 1 Motor RLA | |
| Fan 1 Motor RLV | |
| Fan 2 Motor RLA | |
| Fan 2 Motor RLV | |

| Gas Heat | | |
|-----------------------------------|--------|--------|
| | Design | Actual |
| Output MBH (rated) | - | |
| Gas Inlet Pres (wc) | - | |
| Gas Low Fire Pres (wc) | - | |
| Gas High Fire Pres (wc) | - | |
| Pilot Ignition Status (pass/fail) | - | |
| Single or Dual Bank | - | |
| Staged or Modulating | - | |
| Heater Operates (y/n) | - | |
| Combustion Blower Operates (y/n) | - | |
| Flame Status (pass/fail) | - | |
| High Limit Temp Cut-off SetPt | - | |
| Inlet Temp SetPt | - | |
| Discharge Temp SetPt | - | |
| Temp Rise SetPt | - | |
| Air Flow Switch SetPt | - | |
| Air Flow Switch Actual | - | |
| Air Flow Switch CTRL Voltage | - | |
| Air Switch Proved (Pass/Fail) | - | |
| Space Temp SetPt-ON | - | |
| Space Temp SetPt-OFF | - | |
| Flame Modulates (y/n) | - | |

| Performance Data | | |
|-------------------------|--------|--------|
| | Design | Actual |
| Return Duct SP | - | |
| MA Plenum SP | - | |
| Fan Suction SP | - | |
| Fan Discharge SP | - | |
| Supply Duct SP | - | |
| Total ESP | - | |
| Fan Total SP | - | |
| Pre-Filter P.D. | - | |
| Final Filters P.D. | - | |
| Cooling Coil P.D. | - | |
| CHW Coil P.D. | - | |
| PreHeat Coil P.D. | - | |
| HW Coil P.D. | - | |
| Steam Coil P.D. | - | |
| Heat Wheel (Exh) P.D. | - | |
| Heat Wheel (Sup) P.D. | - | |
| OA Temp (db/wb) | - | |
| RA Temp (db/wb) | - | |
| MA Temp (db/wb) | - | |
| SA Temp (db/wb) | - | |
| HW Coil Delta T | - | |
| CW Coil Delta T | - | |
| Coil Delta T | - | |
| Heat Wheel(Exh) Delta T | - | |
| Heat Wheel(Sup) Delta T | - | |

| General | |
|---------------------------------|--------|
| | Actual |
| Unit free of Damage | |
| Unit Completely Assembled | |
| Unit Leveled | |
| Curb & Unit Installed Air Tight | |
| Controls Complete | |
| Fan Rotation Correct | |
| Fan Belt Condition | |
| Unit Filters Clean | |
| Evap Coil Clean | |
| Evap Coil Free of Frost | |
| Condensor Coil Clean | |
| Condensor Fins Straight | |
| Refr Sight Glass Dry | |
| Condensate Drain Installed | |
| Crankcase Heaters Operate | |

| Compressors | |
|-------------------------|--------|
| | Actual |
| Refrigerant Charge | |
| Refrigerant Type | |
| Comp 1 RLA | |
| Comp 2 RLA | |
| Comp 1 Suction Pres | |
| Comp 2 Suction Pres | |
| Comp 1 Discharge Pres | |
| Comp 2 Discharge Pres | |
| Circuit 1 Superheat | |
| Circuit 2 Superheat | |
| Comp 1 Liquid Line Temp | |
| Comp 2 Liquid Line Temp | |
| Circuit 1 SubCooling | |
| Circuit 2 SubCooling | |

| Electric Heat | | |
|-------------------------------|--------|--------|
| | Design | Actual |
| KW (TOTAL) | - | |
| Num of Stages | - | |
| Voltage | - | |
| Stage 1 RLA | - | |
| Stage 2 RLA | - | |
| Stage 3 RLA | - | |
| Stage 4 RLA | - | |
| Stage 5 RLA | - | |
| Stage 6 RLA | - | |
| EAT (db/wb) | - | |
| LAT (db/wb) | - | |
| Coil Delta T | - | |
| Inlet SP | - | |
| Discharge SP | - | |
| Coil Delta SP | - | |
| High Limit Temp Cut-off SetPt | - | |
| Inlet Temp SetPt | - | |
| Discharge Temp SetPt | - | |
| Temp Rise SetPt | - | |
| Airflow Switch SP | - | |
| Airflow Switch CTRL Voltage | - | |
| Space Temp SetPt-ON | - | |
| Space Temp SetPt-OFF | - | |

| Electrical | |
|-------------------------------|--------|
| | Actual |
| Evap Fan Overload size/setpt | |
| Cond Fan Overload size/setpt | |
| VFD Phase Voltage (line) | |
| VFD Min Setpt | |
| VFD Max Setpt | |
| Phase Brownout Dial Setpt (v) | |
| Phase Brownout Volt Variance | |
| Control Voltage (v) | |
| System Fused (y/n) | |
| Fuse Size (amps) | |
| Freeze Stat Setpt | |
| Compressor Lockout Setpt | |

| Combustion Fan Motor Data | | |
|---------------------------|--------|--------|
| | Design | Actual |
| Voltage | - | |
| Amperage | - | |

| Combustion Gas Duct | |
|----------------------------|--------|
| | Actual |
| Duct Type | |
| Gauge & Material | |
| Size | |
| Min Rise:Run | |
| Room properly ventilated | |
| Space pres condition | |
| Flue backdrafts eliminated | |
| Flue Terminates Properly | |



Chetu Development

Project:17 April Project

AHU/RTU



VAV - Dual Duct

AHU1/

| Asset | MFG | Model Num | Serial Num | Design Service | Service | Type | Inlet Size |
|--------------|--------------------------|-------------------------|--------------------------------|-------------------------|-----------------------------|----------------------|--------------------------------|
| AHU1-DDVAV1 | VA | VA | | | | | |
| | Design Max CFM | Max CFM | Design Min CFM | Min CFM | Ak (max) | Ak (min) | SetPt (max) |
| | | | - | - | - | - | - |
| | SetPt (Min) | Design Max CFM | Design EAT-Cold Deck (db/wb) | EAT-Cold Deck (db/wb) | Design EAT-Hot Deck (db/wb) | EAT-Hot Deck (db/wb) | Design LAT-Max Cooling (db/wb) |
| | - | | - | - | - | - | - |
| | LAT-Max Cooling (db/wb) | LAT-Min Cooling (db/wb) | Design LAT-Max Heating (db/wb) | LAT-Max Heating (db/wb) | LAT-Min Heating (db/wb) | Inlet - Cold Deck SP | Inlet - Hot Deck SP |
| | - | - | - | - | - | - | - |
| Discharge SP | Mixing Damper Functional | | | | | | |
| AHU1-DDVAV2 | VA | VA | | | | | |
| | Design Max CFM | Max CFM | Design Min CFM | Min CFM | Ak (max) | Ak (min) | SetPt (max) |
| | | | - | - | - | - | - |
| | SetPt (Min) | Design Max CFM | Design EAT-Cold Deck (db/wb) | EAT-Cold Deck (db/wb) | Design EAT-Hot Deck (db/wb) | EAT-Hot Deck (db/wb) | Design LAT-Max Cooling (db/wb) |
| | - | | - | - | - | - | - |
| | LAT-Max Cooling (db/wb) | LAT-Min Cooling (db/wb) | Design LAT-Max Heating (db/wb) | LAT-Max Heating (db/wb) | LAT-Min Heating (db/wb) | Inlet - Cold Deck SP | Inlet - Hot Deck SP |
| | - | - | - | - | - | - | - |
| Discharge SP | Mixing Damper Functional | | | | | | |

Diffuser Supply (GRD)

AHU1-DDVAV1/

| Asset | Location | a7 | FINAL CFM | % to design |
|-------------------|----------|----|-----------|-------------|
| Asset Name | | | | |
| AHU1-DDVAV1-SGRD1 | | | | |
| AHU1-DDVAV1-SGRD2 | | | | |
| AHU1-DDVAV1-SGRD3 | | | | |
| Total | | | 0 | |

Diffuser Ret/Exh (GRD)

AHU1-DDVAV1/

| Asset | | | | | | | | | | | | |
|-------------------|------------------|------------|-------------|-------------|-------------------|-----------|---------------|---------------|---------------|---------------|------------------|--------------------|
| Asset Name | Model Num | MFG | Type | Size | DESIGN CFM | AK | VEL(1) | CFM(1) | VEL(2) | CFM(2) | FINAL CFM | % to design |
| AHU1-DDVAV1-EGRD1 | DF | DF | | | | | | | | | | |
| AHU1-DDVAV1-EGRD2 | DF | DF | | | | | | | | | | |
| AHU1-DDVAV1-EGRD3 | DF | DF | | | | | | | | | | |
| Total | | | | | 0 | | | 0 | | 0 | 0 | 0% |



Chetu Development

Project: 17 April Project

System/Unit: AHU/RTU



Asset: AHU2

AREA:

| Unit Data | | |
|---------------------|--------|--------|
| | Design | Actual |
| MFG | AH | AH |
| Serial Num | - | |
| Model Num | AH | AH |
| Inventory Tag ID | - | |
| Type | - | |
| Series | - | |
| Configuration | - | |
| Num OA Filters 1 | - | |
| OA Filter Size 1 | - | |
| Num OA Filters 2 | - | |
| OA Filter Size 2 | - | |
| Num PreFilter 1 | - | |
| PreFilter Size 1 | - | |
| Num PreFilter 2 | - | |
| PreFilter Size 2 | - | |
| Num Final Filter 1 | - | |
| Final Filter Size 1 | - | |
| Num Final Filter 2 | - | |
| Final Filter Size 2 | - | |

| Motor Data | | |
|----------------|--------|--------|
| | Design | Actual |
| Motor MFG | - | |
| Frame | - | |
| Horsepower | - | |
| Motor Rpm | - | |
| Phase | - | |
| Rated Voltage | - | |
| Rated Amperage | - | |
| Frequency | - | |
| Service Factor | - | |
| Efficiency | - | |
| Power Factor | - | |

| Drive Data | |
|--------------------|--------|
| | Actual |
| Motor Sheave MFG | |
| Motor Sheave Size | |
| Motor Bore Size | |
| Motor Sheave SetPt | |
| Fan Sheave MFG | |
| Fan Sheave Size | |
| Fan Sheave Bore | |
| Belt CL Distance | |
| Num of Belts | |
| Belt Size | |
| Belt MFG | |
| Belt Deflection | |
| Belt Alignment | |

| Test Data | | |
|--------------------------|--------|--------|
| | Design | Actual |
| SF CFM (Initial) | - | |
| SF CFM | - | |
| SF RPM (Initial) | - | |
| SF RPM | - | |
| RA CFM | - | |
| OA CFM | - | |
| Exhaust CFM | - | |
| Relief CFM | - | |
| RL Voltage | - | |
| RL Amperage | - | |
| SF Rotation | - | |
| VFD Max SetPt | - | |
| VFD Min SetPt | - | |
| SF Motor Freq(HZ) | - | |
| SF Flow Station (Kv) | - | |
| OA Flow Station (Kv) | - | |
| SF System SetPt | - | |
| RA Flow Station (Kv) | - | |
| Relief Flow Station (Kv) | - | |
| RA Damper Position | - | |
| RA Damper Type | - | |
| MA Damper Position | - | |
| MA Damper Type | - | |
| OA Damper Position | - | |
| OA Damper Type | - | |
| Min OA Damper Position | - | |
| Min OA Damper Type | - | |
| Econo Damper Position | - | |
| Econo Damper Type | - | |
| Relief Damper Position | - | |
| Relief Damper Type | - | |
| OA Enthalpy Setpt | - | |
| Brake Horse Power | - | |

| Condensor Fan | |
|-----------------|--------|
| | Actual |
| Fan 1 Motor RLA | |
| Fan 1 Motor RLV | |
| Fan 2 Motor RLA | |
| Fan 2 Motor RLV | |

| Gas Heat | | |
|-----------------------------------|--------|--------|
| | Design | Actual |
| Output MBH (rated) | - | |
| Gas Inlet Pres (wc) | - | |
| Gas Low Fire Pres (wc) | - | |
| Gas High Fire Pres (wc) | - | |
| Pilot Ignition Status (pass/fail) | - | |
| Single or Dual Bank | - | |
| Staged or Modulating | - | |
| Heater Operates (y/n) | - | |
| Combustion Blower Operates (y/n) | - | |
| Flame Status (pass/fail) | - | |
| High Limit Temp Cut-off SetPt | - | |
| Inlet Temp SetPt | - | |
| Discharge Temp SetPt | - | |
| Temp Rise SetPt | - | |
| Air Flow Switch SetPt | - | |
| Air Flow Switch Actual | - | |
| Air Flow Switch CTRL Voltage | - | |
| Air Switch Proved (Pass/Fail) | - | |
| Space Temp SetPt-ON | - | |
| Space Temp SetPt-OFF | - | |
| Flame Modulates (y/n) | - | |

| Electric Heat | | |
|-------------------------------|--------|--------|
| | Design | Actual |
| KW (TOTAL) | - | |
| Num of Stages | - | |
| Voltage | - | |
| Stage 1 RLA | - | |
| Stage 2 RLA | - | |
| Stage 3 RLA | - | |
| Stage 4 RLA | - | |
| Stage 5 RLA | - | |
| Stage 6 RLA | - | |
| EAT (db/wb) | - | |
| LAT (db/wb) | - | |
| Coil Delta T | - | |
| Inlet SP | - | |
| Discharge SP | - | |
| Coil Delta SP | - | |
| High Limit Temp Cut-off SetPt | - | |
| Inlet Temp SetPt | - | |
| Discharge Temp SetPt | - | |
| Temp Rise SetPt | - | |
| Airflow Switch SP | - | |
| Airflow Switch CTRL Voltage | - | |
| Space Temp SetPt-ON | - | |
| Space Temp SetPt-OFF | - | |

| Performance Data | | |
|-------------------------|--------|--------|
| | Design | Actual |
| Return Duct SP | - | |
| MA Plenum SP | - | |
| Fan Suction SP | - | |
| Fan Discharge SP | - | |
| Supply Duct SP | - | |
| Total ESP | - | |
| Fan Total SP | - | |
| Pre-Filter P.D. | - | |
| Final Filters P.D. | - | |
| Cooling Coil P.D. | - | |
| CHW Coil P.D. | - | |
| PreHeat Coil P.D. | - | |
| HW Coil P.D. | - | |
| Steam Coil P.D. | - | |
| Heat Wheel (Exh) P.D. | - | |
| Heat Wheel (Sup) P.D. | - | |
| OA Temp (db/wb) | - | |
| RA Temp (db/wb) | - | |
| MA Temp (db/wb) | - | |
| SA Temp (db/wb) | - | |
| HW Coil Delta T | - | |
| CW Coil Delta T | - | |
| Coil Delta T | - | |
| Heat Wheel(Exh) Delta T | - | |
| Heat Wheel(Sup) Delta T | - | |

| General | |
|---------------------------------|--------|
| | Actual |
| Unit free of Damage | |
| Unit Completely Assembled | |
| Unit Leveled | |
| Curb & Unit Installed Air Tight | |
| Controls Complete | |
| Fan Rotation Correct | |
| Fan Belt Condition | |
| Unit Filters Clean | |
| Evap Coil Clean | |
| Evap Coil Free of Frost | |
| Condensor Coil Clean | |
| Condensor Fins Straight | |
| Refr Sight Glass Dry | |
| Condensate Drain Installed | |
| Crankcase Heaters Operate | |

| Compressors | |
|-------------------------|--------|
| | Actual |
| Refrigerant Charge | |
| Refrigerant Type | |
| Comp 1 RLA | |
| Comp 2 RLA | |
| Comp 1 Suction Pres | |
| Comp 2 Suction Pres | |
| Comp 1 Discharge Pres | |
| Comp 2 Discharge Pres | |
| Circuit 1 Superheat | |
| Circuit 2 Superheat | |
| Comp 1 Liquid Line Temp | |
| Comp 2 Liquid Line Temp | |
| Circuit 1 SubCooling | |
| Circuit 2 SubCooling | |

| Electrical | |
|-------------------------------|---------------|
| | Actual |
| Evap Fan Overload size/setpt | |
| Cond Fan Overload size/setpt | |
| VFD Phase Voltage (line) | |
| VFD Min Setpt | |
| VFD Max Setpt | |
| Phase Brownout Dial Setpt (v) | |
| Phase Brownout Volt Variance | |
| Control Voltage (v) | |
| System Fused (y/n) | |
| Fuse Size (amps) | |
| Freeze Stat Setpt | |
| Compressor Lockout Setpt | |

| Combustion Fan Motor Data | | |
|----------------------------------|---------------|---------------|
| | Design | Actual |
| Voltage | - | |
| Amperage | - | |

| Combustion Gas Duct | |
|----------------------------|---------------|
| | Actual |
| Duct Type | |
| Gauge & Material | |
| Size | |
| Min Rise:Run | |
| Room properly ventilated | |
| Space pres condition | |
| Flue backdrafts eliminated | |
| Flue Terminates Properly | |



Chetu Development

Project: 17 April Project

System/Unit: Boiler



Asset: BLR1

AREA:

| Unit Data | | |
|------------|--------|--------|
| | Design | Actual |
| MFG | BO | BO |
| Model Num | BO | BO |
| Serial Num | - | |
| Service | - | |
| Type | - | |
| Size | - | |

| Test Data | | |
|------------------------|--------|--------|
| | Design | Actual |
| Water Treatment Type | - | |
| Water Treatment % | - | |
| Water Temp | - | |
| GPM | - | |
| Cv | - | |
| Balance Valve Setting | - | |
| Balance Valve Delta P | - | |
| EWT (F) | - | |
| LWT (F) | - | |
| Water Temp Delta T (F) | - | |
| ENT Water Pres | - | |
| LVG Water Pres | - | |
| Hot Water Delta P | - | |
| BTUH | - | |

| Gas Heat | | |
|---------------------------------------|--------|--------|
| | Design | Actual |
| Gas Type | - | |
| Burner Type | - | |
| Burner Construction | - | |
| Gas Inlet Pres (wc) | - | |
| Gas Low Fire Pres (wc) | - | |
| Input BTUH (rated) | - | |
| Output BTUH (rated) | - | |
| Num of Passes | - | |
| Single or Dual Bank | - | |
| Staged or Modulating | - | |
| Num of Safety Valves | - | |
| Safety Valve Setting | - | |
| High Limit Setting | - | |
| Operating CTRL Setting | - | |
| High Fire SetPt | - | |
| High Fire CTRL Voltage | - | |
| High Fire Delta T (F) Rise | - | |
| Low Fire SetPt | - | |
| Low Fire CTRL SetPt | - | |
| Low Fire Delta T (F) Rise | - | |
| Ignition Type | - | |
| Pilot Ignition Status (pass/fail) | - | |
| Gas Valve Pilot Ignition CTRL Voltage | - | |
| Flame Proving Switch Type | - | |
| Flame proof CTRL Voltage | - | |
| Heater Operates (y/n) | - | |
| Combustion Blower Operates (y/n) | - | |
| Flame Status (pass/fail) | - | |
| EWT Temp SetPt | - | |
| LWT Temp SetPt | - | |
| Water Temp Max Rise SetPt | - | |
| GPM Flow Switch SetPt | - | |
| GPM Flow Switch Actual | - | |
| GPM Flow Switch CTRL Voltage | - | |
| GPM Switch Proved (Pass/Fail) | - | |
| Flame Modulates Properly | - | |
| Safety Controls - Check | - | |

| Combustion Fan Motor Data | | |
|---------------------------|--------|--------|
| | Design | Actual |
| Motor MFG | - | |
| Frame | - | |
| Horsepower | - | |
| Phase | - | |
| Voltage | - | |
| Amperage | - | |

| Combustion Gas Duct | |
|----------------------------|--------|
| | Actual |
| Duct Type | |
| Gauge & Material | |
| Size | |
| Minimum Rise:Run | |
| Room properly ventilated | |
| Space pres condition | |
| Flue backdrafts eliminated | |
| Flue Terminates Properly | |



Chetu Development

Project: 17 April Project

System/Unit: Boiler



Asset: BLR2

AREA:

| Unit Data | | |
|------------|--------|--------|
| | Design | Actual |
| MFG | BO | BO |
| Model Num | BO | BO |
| Serial Num | - | |
| Service | - | |
| Type | - | |
| Size | - | |

| Gas Heat | | |
|---------------------------------------|--------|--------|
| | Design | Actual |
| Gas Type | - | |
| Burner Type | - | |
| Burner Construction | - | |
| Gas Inlet Pres (wc) | - | |
| Gas Low Fire Pres (wc) | - | |
| Input BTUH (rated) | - | |
| Output BTUH (rated) | - | |
| Num of Passes | - | |
| Single or Dual Bank | - | |
| Staged or Modulating | - | |
| Num of Safety Valves | - | |
| Safety Valve Setting | - | |
| High Limit Setting | - | |
| Operating CTRL Setting | - | |
| High Fire SetPt | - | |
| High Fire CTRL Voltage | - | |
| High Fire Delta T (F) Rise | - | |
| Low Fire SetPt | - | |
| Low Fire CTRL SetPt | - | |
| Low Fire Delta T (F) Rise | - | |
| Ignition Type | - | |
| Pilot Ignition Status (pass/fail) | - | |
| Gas Valve Pilot Ignition CTRL Voltage | - | |
| Flame Proving Switch Type | - | |
| Flame proof CTRL Voltage | - | |
| Heater Operates (y/n) | - | |
| Combustion Blower Operates (y/n) | - | |
| Flame Status (pass/fail) | - | |
| EWT Temp SetPt | - | |
| LWT Temp SetPt | - | |
| Water Temp Max Rise SetPt | - | |
| GPM Flow Switch SetPt | - | |
| GPM Flow Switch Actual | - | |
| GPM Flow Switch CTRL Voltage | - | |
| GPM Switch Proved (Pass/Fail) | - | |
| Flame Modulates Properly | - | |
| Safety Controls - Check | - | |

| Test Data | | |
|------------------------|--------|--------|
| | Design | Actual |
| Water Treatment Type | - | |
| Water Treatment % | - | |
| Water Temp | - | |
| GPM | - | |
| Cv | - | |
| Balance Valve Setting | - | |
| Balance Valve Delta P | - | |
| EWT (F) | - | |
| LWT (F) | - | |
| Water Temp Delta T (F) | - | |
| ENT Water Pres | - | |
| LVG Water Pres | - | |
| Hot Water Delta P | - | |
| BTUH | - | |

| Combustion Fan Motor Data | | |
|---------------------------|--------|--------|
| | Design | Actual |
| Motor MFG | - | |
| Frame | - | |
| Horsepower | - | |
| Phase | - | |
| Voltage | - | |
| Amperage | - | |

| Combustion Gas Duct | |
|----------------------------|--------|
| | Actual |
| Duct Type | |
| Gauge & Material | |
| Size | |
| Minimum Rise:Run | |
| Room properly ventilated | |
| Space pres condition | |
| Flue backdrafts eliminated | |
| Flue Terminates Properly | |



Chetu Development

Project: 17 April Project

System/Unit: Boiler



Asset: SGRD2-BLR1

AREA:

| Unit Data | | |
|------------|--------|--------|
| | Design | Actual |
| MFG | BO | BO |
| Model Num | BO | BO |
| Serial Num | - | |
| Service | - | |
| Type | - | |
| Size | - | |

| Gas Heat | | |
|---------------------------------------|--------|--------|
| | Design | Actual |
| Gas Type | - | |
| Burner Type | - | |
| Burner Construction | - | |
| Gas Inlet Pres (wc) | - | |
| Gas Low Fire Pres (wc) | - | |
| Input BTUH (rated) | - | |
| Output BTUH (rated) | - | |
| Num of Passes | - | |
| Single or Dual Bank | - | |
| Staged or Modulating | - | |
| Num of Safety Valves | - | |
| Safety Valve Setting | - | |
| High Limit Setting | - | |
| Operating CTRL Setting | - | |
| High Fire SetPt | - | |
| High Fire CTRL Voltage | - | |
| High Fire Delta T (F) Rise | - | |
| Low Fire SetPt | - | |
| Low Fire CTRL SetPt | - | |
| Low Fire Delta T (F) Rise | - | |
| Ignition Type | - | |
| Pilot Ignition Status (pass/fail) | - | |
| Gas Valve Pilot Ignition CTRL Voltage | - | |
| Flame Proving Switch Type | - | |
| Flame proof CTRL Voltage | - | |
| Heater Operates (y/n) | - | |
| Combustion Blower Operates (y/n) | - | |
| Flame Status (pass/fail) | - | |
| EWT Temp SetPt | - | |
| LWT Temp SetPt | - | |
| Water Temp Max Rise SetPt | - | |
| GPM Flow Switch SetPt | - | |
| GPM Flow Switch Actual | - | |
| GPM Flow Switch CTRL Voltage | - | |
| GPM Switch Proved (Pass/Fail) | - | |
| Flame Modulates Properly | - | |
| Safety Controls - Check | - | |

| Test Data | | |
|------------------------|--------|--------|
| | Design | Actual |
| Water Treatment Type | - | |
| Water Treatment % | - | |
| Water Temp | - | |
| GPM | - | |
| Cv | - | |
| Balance Valve Setting | - | |
| Balance Valve Delta P | - | |
| EWT (F) | - | |
| LWT (F) | - | |
| Water Temp Delta T (F) | - | |
| ENT Water Pres | - | |
| LVG Water Pres | - | |
| Hot Water Delta P | - | |
| BTUH | - | |

| Combustion Fan Motor Data | | |
|---------------------------|--------|--------|
| | Design | Actual |
| Motor MFG | - | |
| Frame | - | |
| Horsepower | - | |
| Phase | - | |
| Voltage | - | |
| Amperage | - | |

| Combustion Gas Duct | |
|----------------------------|--------|
| | Actual |
| Duct Type | |
| Gauge & Material | |
| Size | |
| Minimum Rise:Run | |
| Room properly ventilated | |
| Space pres condition | |
| Flue backdrafts eliminated | |
| Flue Terminates Properly | |



Chetu Development

Project: 17 April Project

System/Unit: Boiler



Asset: SGRD2-BLR2

AREA:

| Unit Data | | |
|------------|--------|--------|
| | Design | Actual |
| MFG | BO | BO |
| Model Num | BO | BO |
| Serial Num | - | |
| Service | - | |
| Type | - | |
| Size | - | |

| Gas Heat | | |
|---------------------------------------|--------|--------|
| | Design | Actual |
| Gas Type | - | |
| Burner Type | - | |
| Burner Construction | - | |
| Gas Inlet Pres (wc) | - | |
| Gas Low Fire Pres (wc) | - | |
| Input BTUH (rated) | - | |
| Output BTUH (rated) | - | |
| Num of Passes | - | |
| Single or Dual Bank | - | |
| Staged or Modulating | - | |
| Num of Safety Valves | - | |
| Safety Valve Setting | - | |
| High Limit Setting | - | |
| Operating CTRL Setting | - | |
| High Fire SetPt | - | |
| High Fire CTRL Voltage | - | |
| High Fire Delta T (F) Rise | - | |
| Low Fire SetPt | - | |
| Low Fire CTRL SetPt | - | |
| Low Fire Delta T (F) Rise | - | |
| Ignition Type | - | |
| Pilot Ignition Status (pass/fail) | - | |
| Gas Valve Pilot Ignition CTRL Voltage | - | |
| Flame Proving Switch Type | - | |
| Flame proof CTRL Voltage | - | |
| Heater Operates (y/n) | - | |
| Combustion Blower Operates (y/n) | - | |
| Flame Status (pass/fail) | - | |
| EWT Temp SetPt | - | |
| LWT Temp SetPt | - | |
| Water Temp Max Rise SetPt | - | |
| GPM Flow Switch SetPt | - | |
| GPM Flow Switch Actual | - | |
| GPM Flow Switch CTRL Voltage | - | |
| GPM Switch Proved (Pass/Fail) | - | |
| Flame Modulates Properly | - | |
| Safety Controls - Check | - | |

| Test Data | | |
|------------------------|--------|--------|
| | Design | Actual |
| Water Treatment Type | - | |
| Water Treatment % | - | |
| Water Temp | - | |
| GPM | - | |
| Cv | - | |
| Balance Valve Setting | - | |
| Balance Valve Delta P | - | |
| EWT (F) | - | |
| LWT (F) | - | |
| Water Temp Delta T (F) | - | |
| ENT Water Pres | - | |
| LVG Water Pres | - | |
| Hot Water Delta P | - | |
| BTUH | - | |

| Combustion Fan Motor Data | | |
|---------------------------|--------|--------|
| | Design | Actual |
| Motor MFG | - | |
| Frame | - | |
| Horsepower | - | |
| Phase | - | |
| Voltage | - | |
| Amperage | - | |

| Combustion Gas Duct | |
|----------------------------|--------|
| | Actual |
| Duct Type | |
| Gauge & Material | |
| Size | |
| Minimum Rise:Run | |
| Room properly ventilated | |
| Space pres condition | |
| Flue backdrafts eliminated | |
| Flue Terminates Properly | |



Chetu Development

Project:17 April Project



Diffuser Ret/Exh (GRD)

AHU1-DDVAV1/

| Asset | | | | | | | | | | |
|-------------------|------|------|------------|----|--------|--------|--------|--------|-----------|-------------|
| Asset Name | Type | Size | DESIGN CFM | AK | VEL(1) | CFM(1) | VEL(2) | CFM(2) | FINAL CFM | % to design |
| AHU1-DDVAV1-EGRD1 | | | | | | | | | | |
| AHU1-DDVAV1-EGRD2 | | | | | | | | | | |
| AHU1-DDVAV1-EGRD3 | | | | | | | | | | |
| Total | | | 0 | | | 0 | | 0 | 0 | 0% |

DDVAV1/

| Asset | | | | | | | | | | |
|--------------|------|------|------------|----|--------|--------|--------|--------|-----------|-------------|
| Asset Name | Type | Size | DESIGN CFM | AK | VEL(1) | CFM(1) | VEL(2) | CFM(2) | FINAL CFM | % to design |
| DDVAV1-EGRD1 | | | | | | | | | | |
| DDVAV1-EGRD2 | | | | | | | | | | |
| Total | | | 0 | | | 0 | | 0 | 0 | 0% |

Test QA/

| Asset | | | | | | | | | | |
|------------|------|------|------------|----|--------|--------|--------|--------|-----------|-------------|
| Asset Name | Type | Size | DESIGN CFM | AK | VEL(1) | CFM(1) | VEL(2) | CFM(2) | FINAL CFM | % to design |
| EGRD1 | | | | | | | | | | |
| EGRD2 | | | | | | | | | | |
| Total | | | 0 | | | 0 | | 0 | 0 | 0% |



Chetu Development

Project:17 April Project



Diffuser Supply (GRD)

AHU1-DDVAV1/

| Asset | | | | |
|-------------------|----------|----|-----------|-------------|
| Asset Name | Location | a7 | FINAL CFM | % to design |
| AHU1-DDVAV1-SGRD1 | | | | |
| AHU1-DDVAV1-SGRD2 | | | | |
| AHU1-DDVAV1-SGRD3 | | | | |
| Total | | | 0 | |

DDVAV1/

| Asset | | | | |
|--------------|----------|----|-----------|-------------|
| Asset Name | Location | a7 | FINAL CFM | % to design |
| DDVAV1-SGRD1 | | | | |
| DDVAV1-SGRD2 | | | | |
| Total | | | 0 | |

Test QA/

| Asset | | | | |
|------------|----------|----|-----------|-------------|
| Asset Name | Location | a7 | FINAL CFM | % to design |
| SGRD1 | | | | |
| SGRD2 | | | | |
| Total | | | 0 | |



Chetu Development

Project:17 April Project

VAV - Dual Duct



AHU1/

| Asset | Serial Num | Design Service | Service | Type | Inlet Size | Design Max CFM | Max CFM |
|--------------------------------|------------------------------|-------------------------|-----------------------------|----------------------|--------------------------------|--------------------------|-------------------------|
| DDVAV1 | | | | | | | |
| | Design Min CFM | Min CFM | Ak (max) | Ak (min) | SetPt (max) | SetPt (Min) | Design Max CFM |
| | | | | | | | |
| | Max CFM | Design Min CFM | Min CFM | Ak (max) | Ak (min) | SetPt (max) | SetPt (Min) |
| | | | | | | | |
| | Design EAT-Cold Deck (db/wb) | EAT-Cold Deck (db/wb) | Design EAT-Hot Deck (db/wb) | EAT-Hot Deck (db/wb) | Design LAT-Max Cooling (db/wb) | LAT-Max Cooling (db/wb) | LAT-Min Cooling (db/wb) |
| | | | | | | | |
| Design LAT-Max Heating (db/wb) | LAT-Max Heating (db/wb) | LAT-Min Heating (db/wb) | Inlet - Cold Deck SP | Inlet - Hot Deck SP | Discharge SP | Mixing Damper Functional | |
| | | | | | | | |



Chetu Development

Project:17 April Project

VAV - Dual Duct



Test QA/

| Asset | Serial Num | Design Service | Service | Type | Inlet Size | Design Max CFM | Max CFM |
|--------|--------------------------------|-------------------------|-----------------------------|----------------------|--------------------------------|-------------------------|--------------------------|
| DDVAV1 | Design Min CFM | Min CFM | Ak (max) | Ak (min) | SetPt (max) | SetPt (Min) | Design Max CFM |
| | Max CFM | Design Min CFM | Min CFM | Ak (max) | Ak (min) | SetPt (max) | SetPt (Min) |
| | Design EAT-Cold Deck (db/wb) | EAT-Cold Deck (db/wb) | Design EAT-Hot Deck (db/wb) | EAT-Hot Deck (db/wb) | Design LAT-Max Cooling (db/wb) | LAT-Max Cooling (db/wb) | LAT-Min Cooling (db/wb) |
| | Design LAT-Max Heating (db/wb) | LAT-Max Heating (db/wb) | LAT-Min Heating (db/wb) | Inlet - Cold Deck SP | Inlet - Hot Deck SP | Discharge SP | Mixing Damper Functional |
| | | | | | | | |
| | | | | | | | |

Diffuser Supply (GRD)

DDVAV1/

| Asset | Asset Name | Location | a7 | FINAL CFM | % to design |
|-------|--------------|----------|----|-----------|-------------|
| | DDVAV1-SGRD1 | | | | |
| | DDVAV1-SGRD2 | | | | |
| | Total | | | 0 | |

Diffuser Ret/Exh (GRD)

DDVAV1/

| Asset | Asset Name | Model Num | MFG | Type | Size | DESIGN CFM | AK | VEL(1) | CFM(1) | VEL(2) | CFM(2) | FINAL CFM | % to design |
|-------|--------------|-----------|-----|------|------|------------|----|--------|--------|--------|--------|-----------|-------------|
| | DDVAV1-EGRD1 | DF | DF | | | | | | | | | | |
| | DDVAV1-EGRD2 | DF | DF | | | | | | | | | | |
| | Total | | | | | 0 | | | 0 | | 0 | 0 | 0% |



Chetu Development

Project:17 April Project

VAV - Dual Duct



AHU1/

| Asset | Serial Num | Design Service | Service | Type | Inlet Size | Design Max CFM | Max CFM |
|--------------------------------|------------------------------|-------------------------|-----------------------------|----------------------|--------------------------------|--------------------------|-------------------------|
| DDVAV2 | | | | | | | |
| | Design Min CFM | Min CFM | Ak (max) | Ak (min) | SetPt (max) | SetPt (Min) | Design Max CFM |
| | | | | | | | |
| | Max CFM | Design Min CFM | Min CFM | Ak (max) | Ak (min) | SetPt (max) | SetPt (Min) |
| | | | | | | | |
| | Design EAT-Cold Deck (db/wb) | EAT-Cold Deck (db/wb) | Design EAT-Hot Deck (db/wb) | EAT-Hot Deck (db/wb) | Design LAT-Max Cooling (db/wb) | LAT-Max Cooling (db/wb) | LAT-Min Cooling (db/wb) |
| | | | | | | | |
| Design LAT-Max Heating (db/wb) | LAT-Max Heating (db/wb) | LAT-Min Heating (db/wb) | Inlet - Cold Deck SP | Inlet - Hot Deck SP | Discharge SP | Mixing Damper Functional | |
| | | | | | | | |



Chetu Development

Project:17 April Project

VAV - Dual Duct



Test QA/

| Asset | Serial Num | Design Service | Service | Type | Inlet Size | Design Max CFM | Max CFM |
|---------|--------------------------------|-------------------------|-----------------------------|----------------------|--------------------------------|-------------------------|--------------------------|
| DDVAV/2 | Design Min CFM | Min CFM | Ak (max) | Ak (min) | SetPt (max) | SetPt (Min) | Design Max CFM |
| | Max CFM | Design Min CFM | Min CFM | Ak (max) | Ak (min) | SetPt (max) | SetPt (Min) |
| | Design EAT-Cold Deck (db/wb) | EAT-Cold Deck (db/wb) | Design EAT-Hot Deck (db/wb) | EAT-Hot Deck (db/wb) | Design LAT-Max Cooling (db/wb) | LAT-Max Cooling (db/wb) | LAT-Min Cooling (db/wb) |
| | Design LAT-Max Heating (db/wb) | LAT-Max Heating (db/wb) | LAT-Min Heating (db/wb) | Inlet - Cold Deck SP | Inlet - Hot Deck SP | Discharge SP | Mixing Damper Functional |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |



Chetu Development

Project:17 April Project

VAV - Dual Duct



AHU1/

| Asset | Serial Num | Design Service | Service | Type | Inlet Size | Design Max CFM | Max CFM |
|-------------|--------------------------------|-------------------------|-----------------------------|----------------------|--------------------------------|-------------------------|--------------------------|
| AHU1-DDVAV1 | Design Min CFM | Min CFM | Ak (max) | Ak (min) | SetPt (max) | SetPt (Min) | Design Max CFM |
| | Max CFM | Design Min CFM | Min CFM | Ak (max) | Ak (min) | SetPt (max) | SetPt (Min) |
| | Design EAT-Cold Deck (db/wb) | EAT-Cold Deck (db/wb) | Design EAT-Hot Deck (db/wb) | EAT-Hot Deck (db/wb) | Design LAT-Max Cooling (db/wb) | LAT-Max Cooling (db/wb) | LAT-Min Cooling (db/wb) |
| | Design LAT-Max Heating (db/wb) | LAT-Max Heating (db/wb) | LAT-Min Heating (db/wb) | Inlet - Cold Deck SP | Inlet - Hot Deck SP | Discharge SP | Mixing Damper Functional |
| | | | | | | | |
| | | | | | | | |



Chetu Development

Project:17 April Project

VAV - Dual Duct



Test QA/

| Asset | | | | | | | |
|-------------|--------------------------------|-------------------------|-----------------------------|----------------------|--------------------------------|-------------------------|--------------------------|
| AHU1-DDVAV1 | Serial Num | Design Service | Service | Type | Inlet Size | Design Max CFM | Max CFM |
| | Design Min CFM | Min CFM | Ak (max) | Ak (min) | SetPt (max) | SetPt (Min) | Design Max CFM |
| | Max CFM | Design Min CFM | Min CFM | Ak (max) | Ak (min) | SetPt (max) | SetPt (Min) |
| | Design EAT-Cold Deck (db/wb) | EAT-Cold Deck (db/wb) | Design EAT-Hot Deck (db/wb) | EAT-Hot Deck (db/wb) | Design LAT-Max Cooling (db/wb) | LAT-Max Cooling (db/wb) | LAT-Min Cooling (db/wb) |
| | Design LAT-Max Heating (db/wb) | LAT-Max Heating (db/wb) | LAT-Min Heating (db/wb) | Inlet - Cold Deck SP | Inlet - Hot Deck SP | Discharge SP | Mixing Damper Functional |
| | | | | | | | |
| | | | | | | | |

Diffuser Supply (GRD)

AHU1-DDVAV1/

| Asset | | | | |
|-------------------|----------|----|-----------|-------------|
| Asset Name | Location | a7 | FINAL CFM | % to design |
| AHU1-DDVAV1-SGRD1 | | | | |
| AHU1-DDVAV1-SGRD2 | | | | |
| AHU1-DDVAV1-SGRD3 | | | | |
| Total | | | 0 | |

Diffuser Ret/Exh (GRD)

AHU1-DDVAV1/

| Asset | | | | | | | | | | | | |
|-------------------|-----------|-----|------|------|------------|----|--------|--------|--------|--------|-----------|-------------|
| Asset Name | Model Num | MFG | Type | Size | DESIGN CFM | AK | VEL(1) | CFM(1) | VEL(2) | CFM(2) | FINAL CFM | % to design |
| AHU1-DDVAV1-EGRD1 | DF | DF | | | | | | | | | | |
| AHU1-DDVAV1-EGRD2 | DF | DF | | | | | | | | | | |
| AHU1-DDVAV1-EGRD3 | DF | DF | | | | | | | | | | |
| Total | | | | | 0 | | | 0 | | 0 | 0 | 0% |



Chetu Development

Project:17 April Project

VAV - Dual Duct



AHU1/

| Asset | Serial Num | Design Service | Service | Type | Inlet Size | Design Max CFM | Max CFM |
|-------------|--------------------------------|-------------------------|-----------------------------|----------------------|--------------------------------|-------------------------|--------------------------|
| AHU1-DDVAV2 | Design Min CFM | Min CFM | Ak (max) | Ak (min) | SetPt (max) | SetPt (Min) | Design Max CFM |
| | Max CFM | Design Min CFM | Min CFM | Ak (max) | Ak (min) | SetPt (max) | SetPt (Min) |
| | Design EAT-Cold Deck (db/wb) | EAT-Cold Deck (db/wb) | Design EAT-Hot Deck (db/wb) | EAT-Hot Deck (db/wb) | Design LAT-Max Cooling (db/wb) | LAT-Max Cooling (db/wb) | LAT-Min Cooling (db/wb) |
| | Design LAT-Max Heating (db/wb) | LAT-Max Heating (db/wb) | LAT-Min Heating (db/wb) | Inlet - Cold Deck SP | Inlet - Hot Deck SP | Discharge SP | Mixing Damper Functional |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |



Chetu Development

Project:17 April Project

VAV - Dual Duct



Test QA/

| Asset | Serial Num | Design Service | Service | Type | Inlet Size | Design Max CFM | Max CFM |
|-------------|--------------------------------|-------------------------|-----------------------------|----------------------|--------------------------------|-------------------------|--------------------------|
| AHU1-DDVAV2 | Design Min CFM | Min CFM | Ak (max) | Ak (min) | SetPt (max) | SetPt (Min) | Design Max CFM |
| | Max CFM | Design Min CFM | Min CFM | Ak (max) | Ak (min) | SetPt (max) | SetPt (Min) |
| | Design EAT-Cold Deck (db/wb) | EAT-Cold Deck (db/wb) | Design EAT-Hot Deck (db/wb) | EAT-Hot Deck (db/wb) | Design LAT-Max Cooling (db/wb) | LAT-Max Cooling (db/wb) | LAT-Min Cooling (db/wb) |
| | Design LAT-Max Heating (db/wb) | LAT-Max Heating (db/wb) | LAT-Min Heating (db/wb) | Inlet - Cold Deck SP | Inlet - Hot Deck SP | Discharge SP | Mixing Damper Functional |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |



Chetu Development

Project:17 April Project



VAV - Single Duct

Test QA/

| Asset | Serial Num | Design Service | Service | Type | Inlet Size | Design Max CF M | Max CFM |
|-------|----------------|------------------|---------------------|---------------------------|-----------------|---------------------------|-----------------|
| VAV1 | Design Min CFM | Min CFM | Design Heat CF M | Heat CFM | Ak (max) | Ak (min) | Ak (heat) |
| | Damper SetPt | Diversity Test 1 | Diversity Test 2 | Design EAT (F - db/wb) | EAT (F - db/wb) | Design LAT (F - db/wb) | LAT (F - db/wb) |
| | Inlet SP | Discharge SP | | | | | |
| | Serial Num | Design Service | Service | Type | Inlet Size | Design Max CF M | Max CFM |
| | Design Min CFM | Min CFM | Design Heat CF M | Heat CFM | Ak (max) | Ak (min) | Ak (heat) |
| | Damper SetPt | Diversity Test 1 | Diversity Test 2 | Design EAT (F - db/wb) | EAT (F - db/wb) | Design LAT (F - db/wb) | LAT (F - db/wb) |
| VAV2 | Inlet SP | Discharge SP | | | | | |