

**Report By:**

National TAB  
1329 E. KEMPER ROAD  
SUITE 4210  
CINCINNATI, OH 45246



**Report: Issue Data**  
**Function: Test, Adjust, & Balance**  
**Date: 02/05/2026**  
**Completed By: National TAB**

**PROJECT**  
**CW 9111 - OCC Expansion (Coppell, TX)**

91111 CYPRESS WATERS BLVD

COPPELL, TX

**Client**

Venture Mechanical Inc  
1644 W Crosby Rd  
Carrollton, TX 75006

# National TAB

Project: CW 9111 - OCC Expansion (Coppell, TX)

## Table Of Contents

Section	Page #
Issue Data	3

## **Issue List**

- VAV5-10 NOT OPERATIONAL (VAV-2A-10 CONTROLS LABEL)
- VAV5-3 NOT OPERATIONAL (VAV-2A-30 CONTROLS LABEL)



## CW 9111 - OCC Expansion (Coppell, TX)

### Project Issue Information

**Issue Name :** VAV5-10 NOT OPERATIONAL (VAV-2A-10 CONTROLS LABEL)  
**Description :** Unit is assumed to be VAV-2A-10 via controls graphics based on thermostat address. Unit is showing "NR" on controls graphics, unable to calibrate or balance this unit due to that issue.


**Created By :** National TAB                      **Assigned To :** National TAB - Dan Hertenstein

**Status :** Open


**Priority :** Urgent                                      **Asset Tag :**

**Originated Date :** 02/06/2026 - Bayley Morvant - National TAB

#### Project Issue File Details



02/06/2026



02/06/2026



02/06/2026



## CW 9111 - OCC Expansion (Coppell, TX)

### Project Issue Information

**Issue Name :** VAV5-3 NOT OPERATIONAL (VAV-2A-30 CONTROLS LABEL)  
**Description :** Unit is not operational. Unit is showing "NR" on controls graphics. Unit is wired for power and power switch is in ON position. Scrolling through thermostat options and it shows "No Custom Codes". This leads to believe this box has not been programmed. Box shows up on controls graphics matrix for the floor but not on the floor layout page.

**Created By :** National TAB                      **Assigned To :** National TAB - Dan Hertenstein

**Status :** Open

**Priority :** Urgent                                      **Asset Tag :**

**Originated Date :** 02/06/2026 - Bayley Morvant - National TAB


#### Project Issue File Details



02/06/2026



02/06/2026



02/06/2026