

Report By:

National TAB
1329 E. KEMPER ROAD
SUITE 4210
CINCINNATI, OH 45246



Report: LIFE SAFETY INSPECTION TEST

Function: Life Safety

Date: 04/09/2024

PROJECT
ARI TEST TRAINING

1 MAIN SUITE A

KANSAS CITY, MO 64116

Client

Developer Test Org

National TAB

Project: ARI TEST TRAINING

Table Of Contents

Section	Page #
KVS SUPPRESSION SYSTEM	3
FIRE EXTINGUISHER	4

National TAB

Project: ARI TEST TRAINING



System/Unit: KVS SUPPRESSION SYSTEM

Asset: KVS_EXT1

AREA:

UNIT DATA		
	Design	Actual
MANUFACTURER	AMEREX	AMEREX
MODEL	KP475	KP475
TAG/SERIAL #	-	KH1/KH2
UL 710 LISTED ASSEMBLY	-	UL300/UL710
AGENT TYPE	-	WET CHEMICAL
ACTIVATION TYPE	MECHANICAL	MECHANICAL

SYSTEM CAPACITY		
	Design	Actual
SIZE	450 DEG	450 DEG
TANKS	1-4.8 GALLON	1-4.8 GALLON
FLOW POINTS CAPACITY	28FP	28FP
FLOW POINTS IN USE	-	25FP

COMPLIANCE TEST		
	Design	Actual
DATE COMMISSIONED	-	1/1/2023
CURRENT INSP_DATE	-	6/1/2024
CURRENT INSP_STATUS	-	PASS
TECH NAME	-	DAN HERTENSTEIN
COMPANY NAME	-	AAA EXTINGUISHING
GREEN OR RED TAG APPLIED	-	.GREEN
NEXT INSP_DUE DATE	-	12/1/2024
REMAINING OPEN ISSUES	-	NONE

National TAB

Project:ARI TEST TRAINING



FIRE EXTINGUISHER

folder/

Asset									
Asset Name	LOCATION	SIZE	AGENT	ANNUAL	RECHARGE/R EFILL	6 YR. MAINTENANC E	HYDROTEST	NEW	ADDITIONAL SERVICE / PARTS
FIRE_EXT1	FRONT EXIT DOOR	2.5 GALLON	WET CHEMICAL	01/01/24	100 PSI	01/01/30	06/06/24	01/01/24	MOUNTING BRACKET
FIRE_EXT2	SIDE DOOR EXIT	2.5 GALLON	WET CHEMICA	01/01/24	100 PSI	01/01/30	06/06/24	01/01/24	MOUNTING BRACKET
FIRE_EXT3	REAR DOOR EXIT	2.5 GALLON	WET CHEMICA	01/01/24	100 PSI	01/01/30	06/06/24	01/01/24	MOUNTING BRACKET