



NOTE: SEE OVAL DRAWINGS FOR EXISTING CONC. CURBS, SINKS, AND PARTITIONS TO BE RELOCATED OR REPLACED WITH NEW FOR NEW PHARMACY LOCATIONS. LOCATIONS SHOWN.

REMOVE EXISTING PHARMACY SINKS AND PARTITIONS TO BE RELOCATED OR REPLACED WITH NEW FOR NEW PHARMACY LOCATIONS. LOCATIONS SHOWN.

NOTE: SEE OVAL DRAWINGS FOR EXISTING CONC. CURBS, SINKS, AND PARTITIONS TO BE RELOCATED OR REPLACED WITH NEW FOR NEW PHARMACY LOCATIONS. LOCATIONS SHOWN.

INSULATE ALL DUCT WITH EXTERNAL 2" VAPOR BARRIER WRAP

CONTRACTOR MAY REROUTE DUCT IN MEZZ. AREA TO ACCOMPLISH THE REQUIRED AIR DISTRIBUTION

CONTRACTOR MUST BALANCE TO A NEGATIVE PRESSURE IN TOILETS.

INSULATE ALL DUCT WITH EXTERNAL 2" VAPOR BARRIER WRAP

H-1 KITCHEN HOOD EXHAUST ONLY INTERLOCK RTU-1 TO OPERATE WITH HOOD.

INSULATE ALL DUCT WITH EXTERNAL 2" VAPOR BARRIER WRAP

CONC. CURB, BELOW (6" W/4" TYPICAL)

CONC. CURB, BELOW (6" W/4" TYPICAL)

CONC. CURB, BELOW (6" W/4" TYPICAL)

CONC. CURB, BELOW (6" W/4" TYPICAL)

CONC. CURB, BELOW (6" W/4" TYPICAL)

CONC. CURB, BELOW (6" W/4" TYPICAL)

CONC. CURB, BELOW (6" W/4" TYPICAL)

CONC. CURB, BELOW (6" W/4" TYPICAL)

CONC. CURB, BELOW (6" W/4" TYPICAL)

STORE # Y-630
   
 8415 WEST MAZDAWAY
   
 LITTLE ROCK, AR
   
 sheet title: HVAC PLAN
   
 SCALE: 1/8" = 1'-0"
   
 ALLEN ENGINEERING SERVICES, PLLC
   
 Arkansas Engineer's Reg. No. 7022
   
 220 Gibson Ave., West Memphis, AR 72301
   
 phone 870-733-7001 fax 870-733-0737
   
 date: August 05, 2008 revision:
   
 commission:
   
 810-7633-00
   
 H.1.2