



11-11-24 FREDDY'S - EL DORADO, KS - RENEW

**Project Issue Information**

**Issue Name :** Rtu not running in cooling or heating

**Description :** Rtu2, furthest rtu from ladder wouldnt come on no matter what I did on thermostat. Blower Fan came on briefly and then shut off and that's it. Let manager know. Leads for multimeter stopped working so couldn't further diagnose.


**Created By :** National TAB **Assigned To :** National TAB - Kyle Henry

**Status :** Open

**Priority :** Urgent **Asset Tag :**

**Originated Date :** 11/13/2024 - Kyle Henry - National TAB

Project Issue File Details



11/13/2024