

Belts - Size and quantity	NA
Note if any modifications made to AHU set points to operate in full capacity.	
Electrical connections - Visual assessment. Document motor Voltage and Amperage.	NA
Heating Coil(s) - Visual assessment and photo documentation.	NA
Cooling Coil(s) - Visual assessment and photo documentation.	NA
Condensate Pan(s) - Visual assessment and photo documentation.	NA
Any unusual operation observed? (including vibration, over-pressure, etc.)	NA
Exhaust System Status (on/off). If this does not apply for this AHU, "N/A"	NA
Visually inspect outdoor air intake louvers, bird screens, mist eliminators, and adjacent areas for cleanliness and integrity.	NA
Note ALL visible debris or visible biological material observed, physical damage to louvers, screens, or mist eliminators, and if such damage impairs the item from providing the required outdoor air entry.	NA
List any found deficiencies. Note any remarks or comments, including corrective actions. Include photo documentation of any relevant findings.	NA