

HES. SYSTEM

MECHANICAL CONTRACTOR TO PROVIDE ALL NEW DUCTWORK AND FITTINGS. ALL NEW HOODS SHALL BE INSTALLED IN ACCORDANCE WITH THE INTERLOCK WIRING DIAGRAM ON SHEET M-11 FOR MORE INFORMATION.

AIR OUTLET/REMOTE WALL SWITCHES BY MECHANICAL. REFER TO AIR OUTLET SCHEDULE AND REMOTE WALL SWITCH DIAGRAM FOR FILTER INFORMATION, COORDINATE EXACT LOCATION FOR SWITCHES WITH KITCHEN EQUIPMENT AND PLANS.

NEW AIR OUTLET/ACM HOODS MOUNTED IN CEILING 5'8" CENTERED ON THE DOOR AT 4" OFF THE EXTERIOR WALL. MECHANICAL CONTRACTOR SHALL ADJUST AIR DEFLECTORS TOWARD AIR DIVERTER BOX.

HOLD DUCT AT ACM AS HIGH AS POSSIBLE DUE TO LIMITED CLEARANCE ABOVE CEILING.

EXISTING CONDITIONS SHOWN ARE FROM PREVIOUS DRAWINGS. MECHANICAL CONTRACTOR SHALL FIELD VERIFY EXACT LOCATIONS OF ALL DUCT AND DIFFUSERS. IF MAJOR DIFFERENCES OCCUR IN FIELD, CONTACT CHECK-FILE A CONSTRUCTION MANAGER.

FIELD VERIFY EXISTING AIR SERVICE NECK SIZE PRIOR TO ORDERING REPLACEMENT. TYPICAL.

LEGEND	
A-12-400	TYPE - NECK SIZE - CON
+	SPAN FITTING, MTD, NO SCOOP
Ⓢ	REMOTE TEMPERATURE SENSOR
Ⓜ	REMOTE HUMIDITY SENSOR

SHEET NOTES

GO TO LEGEND AND OBTAIN INFORMATION ON CLEANING CONTRACTOR CERTIFIED BY NATIONAL AIR DUCT CLEANERS ASSOCIATION (NADCA) TO CLEAN ALL EXISTING DUCTWORK THAT IS TO REMAIN.

KEY NOTES (THIS SHEET ONLY)

1 MECHANICAL FLOOR PLAN
SCALE: 1/4" = 1'-0"

