1 FLOOR PLAN - MECHANICAL
1/8" = 1'-0"

2 MEZZANINE PLAN - MECHANICAL
1/8" = 1'-0"

KEY NOTES:

1. MECHANICAL CONTRACTOR TO INSTALL NEW PLENUM STYLE SUPPLY DIFFUSERS IN NEW CEILING HEIGHT IN SPACE (SEALED AREA). PROVIDE MECHANICAL DUCTWORK SHALL BE RUNNING IN PLENUM TO IN NEW NON CEILING HEIGHT. MECHANICAL CONTRACTOR SHALL VERIFY EXACT LOCATIONS AND CONDITIONS IN FIELD.

2. MECHANICAL CONTRACTOR TO RE-ROUTE EXISTING EXHAUST HOOD ABOVE COOKING FROM EXISTING MECHANICAL CONDITIONS EXACT LOCATION OF EXHAUST HOOD WITH ARCHITECTURAL PLANS. INSTALL NEW EXHAUST FAN FOR EXHAUST HOOD. EXHAUST FAN SHALL BE INSTALLED ON ROOF 18" ALL CURB ON ROOF IS A LOCATION MORE THAN 10'-0" FROM ANY OUTSIDE AIR INTAKE FOR ROOFTOP UNITS. MECHANICAL CONTRACTOR SHALL INSTALL NEW CITY EXHAUST DUCTWORK BETWEEN HOOD AND FAN TO MEET CODE REQUIREMENTS FOR A TYPE 1 HOOD. MECHANICAL CONTRACTOR SHALL INSTALL NEW CITY EXHAUST DUCTWORK BETWEEN FAN AND OUTSIDE TO MEET CODE REQUIREMENTS. PROVIDE CONDUIT FOR MECHANICAL CONTRACTOR TO WIRING AND INSTALL EXHAUST FAN. MECHANICAL CONTRACTOR SHALL VERIFY EXACT LOCATIONS AND CONDITIONS IN FIELD. COORDINATE INSTALLATION REQUIREMENTS WITH MANUFACTURERS INSTALLATION MANUALS.

3. MECHANICAL CONTRACTOR TO INSTALL NEW 1-HR EXHAUST DUCTWORK AND EXHAUST FAN FOR NEW DOUBLE WALL GAS COOKING HOOD. CONTRACTOR SHALL VERIFY EXACT LOCATIONS OF EXHAUST HOOD WITH ARCHITECTURAL PLANS. NEW EXHAUST FAN SHALL BE INSTALLED ON ROOF 18" ALL CURB ON ROOF IS A LOCATION MORE THAN 10'-0" FROM ANY OUTSIDE AIR INTAKE FOR ROOFTOP UNITS. MECHANICAL CONTRACTOR SHALL INSTALL NEW CITY EXHAUST DUCTWORK BETWEEN HOOD AND FAN TO MEET CODE REQUIREMENTS FOR A TYPE 1 HOOD. MECHANICAL CONTRACTOR SHALL INSTALL NEW CITY EXHAUST DUCTWORK BETWEEN FAN AND OUTSIDE TO MEET CODE REQUIREMENTS. PROVIDE CONDUIT FOR MECHANICAL CONTRACTOR TO WIRING AND INSTALL EXHAUST FAN. MECHANICAL CONTRACTOR SHALL VERIFY EXACT LOCATIONS AND CONDITIONS IN FIELD. COORDINATE INSTALLATION REQUIREMENTS WITH MANUFACTURERS INSTALLATION MANUALS.

4. MECHANICAL CONTRACTOR TO INSTALL NEW 1-HR EXHAUST DUCTWORK AND EXHAUST FAN FOR NEW DOUBLE WALL GAS COOKING HOOD. CONTRACTOR SHALL VERIFY EXACT LOCATIONS OF EXHAUST HOOD WITH ARCHITECTURAL PLANS. NEW EXHAUST FAN SHALL BE INSTALLED ON ROOF 18" ALL CURB ON ROOF IS A LOCATION MORE THAN 10'-0" FROM ANY OUTSIDE AIR INTAKE FOR ROOFTOP UNITS. MECHANICAL CONTRACTOR SHALL INSTALL NEW CITY EXHAUST DUCTWORK BETWEEN HOOD AND FAN TO MEET CODE REQUIREMENTS FOR A TYPE 1 HOOD AND WITH NEWLY INSTALLED CITY EXHAUST DUCTWORK. MECHANICAL CONTRACTOR SHALL INSTALL NEW CITY EXHAUST DUCTWORK BETWEEN FAN AND OUTSIDE TO MEET CODE REQUIREMENTS. PROVIDE CONDUIT FOR MECHANICAL CONTRACTOR TO WIRING AND INSTALL EXHAUST FAN. MECHANICAL CONTRACTOR SHALL VERIFY EXACT LOCATIONS AND CONDITIONS IN FIELD. COORDINATE INSTALLATION REQUIREMENTS WITH MANUFACTURERS INSTALLATION MANUALS.

5. MECHANICAL CONTRACTOR TO INSTALL NEW 1-HR EXHAUST DUCTWORK AND EXHAUST FAN FOR NEW DOUBLE WALL GAS COOKING HOOD. CONTRACTOR SHALL VERIFY EXACT LOCATIONS OF EXHAUST HOOD WITH ARCHITECTURAL PLANS. NEW EXHAUST FAN SHALL BE INSTALLED ON ROOF 18" ALL CURB ON ROOF IS A LOCATION MORE THAN 10'-0" FROM ANY OUTSIDE AIR INTAKE FOR ROOFTOP UNITS. MECHANICAL CONTRACTOR SHALL INSTALL NEW CITY EXHAUST DUCTWORK BETWEEN HOOD AND FAN TO MEET CODE REQUIREMENTS FOR A TYPE 1 HOOD AND WITH NEWLY INSTALLED CITY EXHAUST DUCTWORK. MECHANICAL CONTRACTOR SHALL INSTALL NEW CITY EXHAUST DUCTWORK BETWEEN FAN AND OUTSIDE TO MEET CODE REQUIREMENTS. PROVIDE CONDUIT FOR MECHANICAL CONTRACTOR TO WIRING AND INSTALL EXHAUST FAN. MECHANICAL CONTRACTOR SHALL VERIFY EXACT LOCATIONS AND CONDITIONS IN FIELD. COORDINATE INSTALLATION REQUIREMENTS WITH MANUFACTURERS INSTALLATION MANUALS.

6. MECHANICAL CONTRACTOR TO INSTALL NEW DUPLICATE NEW DUPLICATE HOOD IN POLK-A-DOT AREA. INTERLOCK SUPPLY FAN WITH HOOD. VERIFY EXACT LOCATIONS AND CONDITIONS IN FIELD. COORDINATE INSTALLATION REQUIREMENTS WITH MANUFACTURERS INSTALLATION MANUALS.

7. MECHANICAL CONTRACTOR SHALL PROVIDE EXISTING 4-WAY SUPPLY DIFFUSER IN EXISTING SALON CHECKOUT AREA. REPLACE REMAINING DIFFUSERS WITH NEW DIFFUSERS. MECHANICAL CONTRACTOR SHALL VERIFY EXACT LOCATIONS AND CONDITIONS IN FIELD.

8. MECHANICAL CONTRACTOR SHALL PROVIDE EXISTING DIFFUSERS IN NEW CEILING HEIGHT. MECHANICAL CONTRACTOR SHALL VERIFY EXACT LOCATIONS AND CONDITIONS IN FIELD.

9. MECHANICAL CONTRACTOR SHALL PROVIDE EXISTING SUPPLY DIFFUSERS AND EXISTING EXTENSION IN EXISTING BAKERY AREA FOR NEW CEILING HEIGHT. MECHANICAL CONTRACTOR SHALL VERIFY EXACT LOCATIONS AND CONDITIONS IN FIELD.

ANDY D. MIN
ARCHITECT
3414 S. OCEAN BLVD.
PALOS PARK, IL 60464
TEL: 847-409-0663

metro market
ROUNDY'S SUPERMARKETS INC.
TEL: (414) 231-5000
275 EAST WISCONSIN AVENUE
MILWAUKEE, WI 53202
FAX: (414) 231-7939

GENERAL OFFICE:
1014 VINE STREET
CINCINNATI, OHIO 45202
TEL: (513) 762-4000 FAX: (513) 762-4183

INTERIOR REMODEL
METRO MARKET MM-179
261 JUNCTION ROAD
MADISON, WI 53717

ISSUED FOR PLAN REVIEW	PERMIT SET 03.30.23
ISSUED FOR BIDDING	10.17.2022
ISSUED	
REVISIONS	
1	11/08/2022
2	12/05/2022
3	12/12/2022
4	03/17/2023

PROJECT NO. 2025
DRAWING
MECHANICAL PLAN

M1.1