

CheckList List

- SMOKE DETECTOR TEST



Ossur (Orlando, Fl)

CheckList Information

Name : SMOKE DETECTOR TEST **Status :** Not Completed
Assigned Organization : National TAB **Asset :**
Requesting Organization : National TAB
Created Date : 08/07/2023 - Will Turnbough - National TAB

CheckList Item Details

RTU-1 SMOKE DETECTOR: MANUFACTURER / MODEL / ACCEPTABLE STATIC PRESSURE RANGE / MEASURED STATIC PRESSURE Pass

Comment:

TELAIRE / SUPERDUCT / 0.005" - 1.00" / 0.007"

RTU-2 SMOKE DETECTOR: MANUFACTURER / MODEL / ACCEPTABLE STATIC PRESSURE RANGE / MEASURED STATIC PRESSURE Pass

Comment:

TELAIRE / SUPERDUCT / 0.005" - 1.00" / 0.006"

RTU-3 SMOKE DETECTOR: MANUFACTURER / MODEL / ACCEPTABLE STATIC PRESSURE RANGE / MEASURED STATIC PRESSURE Pass

Comment:

TELAIRE / SUPERDUCT / 0.005" - 1.00" / 0.007"

RTU-4 SMOKE DETECTOR: MANUFACTURER / MODEL / ACCEPTABLE STATIC PRESSURE RANGE / MEASURED STATIC PRESSURE Pass

Comment:

TELAIRE / SUPERDUCT / 0.005" - 1.00" / 0.12"

RTU-5 SMOKE DETECTOR: MANUFACTURER / MODEL / ACCEPTABLE STATIC PRESSURE RANGE / MEASURED STATIC PRESSURE Pass

Comment:

TELAIRE / SUPERDUCT / 0.005" - 1.00" / 0.19"

RTU-6 SMOKE DETECTOR: MANUFACTURER / MODEL / ACCEPTABLE STATIC PRESSURE RANGE / MEASURED STATIC PRESSURE Pass

Comment:

TELAIRE / SUPERDUCT / 0.005" - 1.00" / 0.010"

RTU-7 SMOKE DETECTOR: MANUFACTURER / MODEL / ACCEPTABLE STATIC PRESSURE RANGE / MEASURED STATIC PRESSURE Pass

Comment:

TELAIRE / SUPERDUCT / 0.005" - 1.00" / 0.49"

RTU-8 SMOKE DETECTOR: MANUFACTURER / MODEL / ACCEPTABLE STATIC PRESSURE RANGE / MEASURED STATIC PRESSURE Pass

Comment:

TELAIRE / SUPERDUCT / 0.005" - 1.00" / 0.26"

RTU-9 SMOKE DETECTOR: MANUFACTURER / MODEL / ACCEPTABLE STATIC PRESSURE RANGE / MEASURED STATIC PRESSURE Pass

Comment:

TELAIRE / SUPERDUCT / 0.005" - 1.00" / 0.20"

RTU-10 SMOKE DETECTOR: MANUFACTURER / MODEL / ACCEPTABLE STATIC PRESSURE RANGE / MEASURED STATIC PRESSURE Pass

Comment:

TELAIRE / SUPERDUCT / 0.005" - 1.00" / 0.08"

RTU-11 SMOKE DETECTOR: MANUFACTURER / MODEL / ACCEPTABLE STATIC PRESSURE RANGE / MEASURED STATIC PRESSURE Pass

Comment:

TELAIRE / SUPERDUCT / 0.005" - 1.00" / 0.10"

RTU-12 SMOKE DETECTOR: MANUFACTURER / MODEL / ACCEPTABLE STATIC PRESSURE RANGE / MEASURED STATIC PRESSURE Pass

Comment:

TELAIRE / SUPERDUCT / 0.005" - 1.00" / 0.09"

RTU-13 SMOKE DETECTOR: MANUFACTURER / MODEL / ACCEPTABLE STATIC PRESSURE RANGE / MEASURED STATIC PRESSURE Pass

Comment:

TELAIRE / SUPERDUCT / 0.005" - 1.00" / 0.09"

AHU-2 SMOKE DETECTOR: MANUFACTURER / MODEL / ACCEPTABLE STATIC PRESSURE RANGE / MEASURED STATIC PRESSURE Pass

Comment:

SYSTEM SENSOR / D4120 / 0.01" - 1.11" / 0.05"