



CW 7-11 3200 Hackenberry (Irving, TX)

Project Issue Information

Issue Name : Vav's in area 3009 - plans
Description : There are total of 6-boxes VAV that are in open office 3009 & the offices next to area 3010 that have no thermostat located in space
Created By : National TAB **Assigned To :** National TAB - Joe Hertenstein
Status : Open
Priority : Medium **Asset Tag :**
Originated Date : 02/08/2024 - Joe Hertenstein - National TAB

Project Issue File Details




image.jpg

Project Issue Response Details

- 02/08/2024 National TAB - Joe Hertenstein
 - Very low actual airflow for these 6 boxes. Dampers all state 100% open in controls but cfm total is 79 CFM for all 6 boxes