



REFER TO WIRING DIAGRAM ON SHEET M-501 FOR MORE INFORMATION.

MOUNT AIR DOOR IN CEILING, CENTERED ON DRIVE THRU DOOR OPENING, AND 4" OFF THE WALL. PROVIDE 2" AIR DUCT TO DIVERTER BOX AND AIR DOOR PROVIDED BY TOM BARROW COMPANY.

MC  
LMC  
LN  
PD

MOUNT BOTTOM OF FRAME OF GRILLES AT 10'-8" AFF IN PLAY AREA.

CEILING MOUNTED RECIRCULATING FAN ROUTE 12" DUCT AND DISCHARGE AT TYPE A DIFFUSER IN TEAM ROOM AS SHOWN.