



ROUTE REFRIGERANT PIPING FROM FREEZER CONDENSING UNIT ON ROOF TO EMPIORATOR PER MANUFACTURER'S INSTRUCTIONS

ROUTE REFRIGERANT FROM COOLER COND ON ROOF TO EMPIORATOR PER MANUFACTURER'S INSTRUCTIONS

DOAS-5

DOAS-7

DOAS-6

DOAS-9

DOAS-10

DOAS-11

RTU-1, RTU-2, & DOAS-1 THERMOSTATS

12" EA DUCT UP TO KEF-1 (74.1) ON ROOF. OFFSET DUCTWORK AS REQUIRED TO AVOID STRUCTURE. MAINTAIN 10" CLEARANCE FROM ALL OUTDOOR AIR INTAKES

10" EA DUCT UP TO KEF-2 (74.2) ON ROOF. OFFSET DUCTWORK AS REQUIRED TO AVOID STRUCTURE. MAINTAIN 10" CLEARANCE FROM ALL OUTDOOR AIR INTAKES

RTU-2 TEMPERATURE/HUMIDITY SENSOR. LOCATE 7'-0" AFF

PROVIDE REFRIGERANT PIPING FROM ICE MACHINE TO REMOTE CONDENSING UNIT ON ROOF PER MANUFACTURER'S INSTRUCTIONS.

DOAS-1 TEMPERATURE/HUMIDITY SENSOR. LOCATE 7'-0" AFF

RTU-1 TEMPERATURE/HUMIDITY SENSOR. LOCATE 7'-0" AFF

PROVIDE REFRIGERANT PIPING FROM ICE MACHINE TO REMOTE CONDENSING UNIT ON ROOF PER MANUFACTURER'S INSTRUCTIONS.

101% EA DUCT UP TO ROOF CAP

ROUTE IN TRUSS SPACE

HVAC PLAN KEYED NOTES