

- TAGGED NOTES**
- M3 EXISTING RETURN DUCTWORK SHALL REMAIN AND BE PROTECTED FROM DAMAGE. THE RETURN DUCTWORK SERVES AN EXISTING SYSTEM TO REMAIN.
 - M14 PROVIDE VAV CONDENSING UNIT. PROVIDE EQUIPMENT SUPPORTS PER SPECIFICATIONS. USE EXISTING MECHANICAL PAD AS ABLE. MODIFY MECHANICAL PAD AS NECESSARY. CONTRACTOR SHALL VERIFY SIZE ON SITE AND COORDINATE WITH EQUIPMENT PRIOR TO BID.
 - M15 LOUVERED DOOR IS EXISTING TO REMAIN. COORDINATE WITH ARCHITECTURAL PLANS.
 - M20 COORDINATE 3X3 CASSETTES TO BE CENTERED IN THE CEILING GRID SYSTEM.
 - M21 COORDINATE 2X2 CASSETTES TO BE LOCATED WITHIN THE CEILING GRID SYSTEM.
 - M22 PROVIDE EXHAUST GRILLE WITH BALANCING DAMPER ACCESSIBLE FROM FRONT OF GRILLE IN ROOM.
 - M39 PROVIDE MANUAL BALANCING DAMPER.
 - M43 PROVIDE VAV CONTROL PANEL IN THIS LOCATION.
 - M46 PROVIDE BUILDING PRESSURE SENSOR IN THIS ROOM. CONTRACTOR TO PROPOSE LOCATION FOR ENGINEER REVIEW.

MSA DESIGN
 CINCINNATI | COLUMBUS
 msadec.com | 855.241.5666

STATE OF OHIO
 REGISTERED PROFESSIONAL ENGINEER
 THOMAS ANDERSON
 PE 85520

CMTA
 A LEADERSHIP COMPANY
 1100 Sycamore St.
 Cincinnati, OH 45202
 513.404.4404


SETON HALL IMPROVEMENTS
MOUNT ST. JOSEPH UNIVERSITY
 5701 DELHI ROAD,
 CINCINNATI OH 45233-1670

R,G,D RUNOUT SCHEDULE

MARK	DUCT BRANCH SIZE
E-1	22"x22"
E-2	10"x8"
R-1	22"x22"
R-1F	22"x22"
R-2	22"x22"
S-1	6"Ø
S-1A	6"Ø
S-2	8"Ø
S-3	10"Ø
S-4	12"Ø
S-5	12"x8"

This drawing and the design concepts represented, as instruments of service, are the sole property of MSA DESIGN, and may not be used, reproduced, or copied in whole or part, for any purpose without the written authorization of MSA DESIGN.
 Copyright MSA DESIGN
 MSA DESIGN All Rights Reserved
 MSA SPORT is a division of MSA DESIGN

NO.	DATE	ISSUED REVISION
	10/24/25	CD Set
1	11/14/2025	ADDENDUM 03
4	02/06/2026	BULLETIN #1



GROUND FLOOR MECHANICAL PHASE 2
 1/8" = 1'-0"

PROJECT NO. 24167.00
 DRAWING TITLE:
 GROUND FLOOR MECHANICAL AIR PLAN

M2.00

